

DESTIN EXECUTIVE, FL, USA

WMO: 722069

Lat: 30.400N

Lon: 86.472W

Elev: 7

StdP: 101.24

Time Zone: -6.00 (NAC)

Period: 97-19

WBAN: 53853

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.7	2.6	-10.0	1.6	3.4	-7.2	2.1	5.8	10.5	7.4	9.1	9.5	4.6	0	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.3	33.3	25.7	32.5	25.7	32.0	25.7	27.7	31.0	27.2	30.7	26.7	30.3	3.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.9	22.5	29.5	26.2	21.6	29.3	25.7	21.0	29.2	87.9	31.4	85.5	30.7	83.3	30.0	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.5	6.7	-2.9	35.4	2.4	1.3	-4.6	36.3	-6.0	37.1	-7.3	37.8	-9.1	38.7		
(5)			-5.0	28.3	2.0	0.8	-6.5	28.9	-7.7	29.4	-8.8	29.9	-10.3	30.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	20.9	12.1	13.7	16.5	20.2	24.4	27.5	28.4	26.8	22.2	16.9	13.5	(6)	
(7)		DBStd	6.80	4.94	4.33	3.80	2.80	2.31	1.46	1.46	1.51	2.05	3.58	4.08	4.66	(7)
(8)		HDD10.0	74	35	14	3	0	0	0	0	0	0	0	3	18	(8)
(9)		HDD18.3	671	199	136	78	14	1	0	0	0	0	11	72	159	(9)
(10)		CDD10.0	4060	99	119	205	307	447	524	571	569	503	377	210	128	(10)
(11)		CDD18.3	1614	6	7	22	71	189	274	313	311	253	129	29	11	(11)
(12)		CDH23.3	15967	8	6	25	205	1490	3099	3813	3728	2571	907	107	8	(12)
(13)	CDH26.7	5639	2	0	1	12	293	1116	1578	1554	894	184	5	0	(13)	
(14)	Wind	WSAvg	3.0	3.5	3.4	3.4	3.2	2.9	2.5	2.3	2.3	2.9	3.1	3.2	3.5	(14)
(15)	Precipitation	PrecAvg	1457	93	116	118	128	81	129	168	172	149	82	104	132	(15)
(16)		PrecMax	1856	206	228	227	489	206	339	439	308	383	333	255	253	(16)
(17)		PrecMin	938	22	41	7	19	2	56	42	84	24	7	14	38	(17)
(18)		PrecStd	277	44	61	69	124	65	69	107	67	83	82	59	57	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.0	24.4	25.6	27.9	31.9	33.6	34.5	34.4	33.7	31.3	27.4	24.5	(19)
(20)			MCWB	22.2	20.2	19.6	21.5	22.7	24.9	26.5	25.8	24.5	23.7	22.5	21.7	(20)
(21)		2%	DB	21.8	22.5	23.8	26.4	30.0	32.3	33.1	33.1	32.4	29.9	26.0	23.1	(21)
(22)			MCWB	19.6	19.6	19.6	21.4	23.8	25.4	26.3	26.1	24.6	23.5	21.7	20.9	(22)
(23)		5%	DB	20.6	21.2	22.8	25.5	29.0	31.4	32.4	32.4	31.4	28.7	24.5	22.3	(23)
(24)			MCWB	18.7	18.8	19.3	21.1	23.6	25.4	26.1	26.1	24.7	23.0	20.9	20.2	(24)
(25)		10%	DB	19.2	19.9	22.0	24.4	28.2	30.9	31.6	31.9	30.8	27.5	23.2	21.1	(25)
(26)			MCWB	17.4	17.6	18.9	20.6	23.3	25.1	25.8	26.0	24.6	22.5	19.6	19.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.6	21.6	22.5	25.2	27.0	28.5	28.4	28.3	27.5	26.2	24.4	22.7	(27)
(28)			MCDWB	24.2	22.8	23.7	25.8	28.2	29.9	31.8	32.0	30.3	28.8	26.2	24.1	(28)
(29)		2%	WB	20.2	20.4	21.3	23.7	25.6	27.3	27.7	27.6	26.6	25.2	23.1	21.6	(29)
(30)			MCDWB	21.2	22.0	22.7	25.7	28.1	29.8	31.5	31.2	29.7	28.1	24.9	22.8	(30)
(31)		5%	WB	19.2	19.4	20.5	22.7	24.9	26.7	27.1	27.0	25.9	24.5	21.8	20.7	(31)
(32)			MCDWB	20.2	20.6	22.0	24.5	27.8	29.7	31.0	30.8	29.3	27.5	23.9	21.9	(32)
(33)		10%	WB	17.9	18.4	19.5	21.8	24.3	26.1	26.6	26.6	25.5	23.7	20.7	19.3	(33)
(34)			MCDWB	18.9	19.4	21.2	23.5	27.4	29.4	30.4	30.5	29.1	26.7	22.8	20.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.4	7.9	7.8	7.2	6.8	6.3	6.3	6.4	7.1	8.4	8.9	8.3	(35)
(36)			MCDBR	7.5	7.1	7.3	7.4	7.2	6.9	7.0	7.1	7.6	8.3	8.3	7.5	(36)
(37)			MCWBR	6.3	5.5	4.8	4.3	3.7	3.2	3.1	3.2	3.3	3.9	5.7	6.2	(37)
(38)		5% WB	MCDWB	6.8	6.4	5.9	5.6	5.9	6.0	6.6	6.4	6.5	6.8	7.1	7.0	(38)
(39)			MCWBR	6.3	6.0	4.7	3.9	3.4	3.4	3.4	3.3	3.3	4.4	6.0	6.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.335	0.349	0.370	0.398	0.437	0.466	0.503	0.496	0.438	0.386	0.357	0.342	(40)	
(41)		taud	2.541	2.505	2.442	2.372	2.297	2.268	2.181	2.196	2.334	2.457	2.477	2.529	(41)	
(42)		Ebn at Noon	899	916	915	896	858	828	796	799	837	863	863	870	(42)	
(43)		Edh at Noon	86	97	111	123	133	137	148	145	122	101	91	84	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.12	3.74	5.06	6.08	6.75	6.33	5.97	5.54	5.17	4.58	3.54	2.75	(44)	
(45)		RadStd	0.23	0.48	0.40	0.48	0.39	0.52	0.37	0.41	0.31	0.43	0.31	0.27	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.88	N/A	N/A	N/A	N/A	N/A	N/A	-158	+337	+215
(47)	Regional (37 neighbors)	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+150	+91

Nomenclature: See separate page