

CHICKASHA, OK, USA

WMO: 722071

Lat: 35.096N

Lon: 97.966W

Elev: 351

StdP: 97.18

Time Zone: -6.00 (NAC)

Period: 05-19

WBAN: 53935

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -9.8	(c) -7.2	(d) -15.0	(e) 1.1	(f) -7.3	(g) -12.3	(h) 1.4	(i) -4.8	(j) 14.6	(k) 4.2	(l) 12.7	(m) 3.4	(n) 3.9	(o) 0	(p) 0.519

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.6	38.0	24.0	37.3	24.3	35.9	24.4	27.2	33.1	26.2	33.0	25.5	32.8	4.8	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 26.0	(b) 22.3	(c) 30.7	(d) 24.1	(e) 19.9	(f) 29.3	(g) 23.1	(h) 18.6	(i) 28.2	(j) 88.7	(k) 32.7	(l) 82.7	(m) 32.9	(n) 79.9	(o) 32.9	(p) 30.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.0	10.6	9.1	-13.7	40.6	3.2	2.1	-16.0	42.1	-17.8	43.3	-19.6	44.5	-21.9	46.0
			-14.2	27.8	3.0	1.4	-16.4	28.8	-18.2	29.7	-19.8	30.4	-22.0	31.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	4.4	6.3	11.7	15.8	20.9	26.5	28.6	28.1	23.5	16.8	10.7	4.8
	DBStd	9.82	5.40	6.10	5.67	4.87	4.50	2.83	2.74	3.17	3.78	5.26	5.03	5.30
	HDD10.0	610	185	132	48	9	1	0	0	0	0	9	51	175
	HDD18.3	1861	431	339	214	102	26	0	0	0	6	92	232	419
	CDD10.0	3006	12	28	100	184	339	494	578	560	405	219	72	13
	CDD18.3	1217	0	1	8	28	107	245	320	302	160	43	3	0
	CDH23.3	14048	2	13	73	283	1031	2784	4095	3707	1600	423	37	1
	CDH26.7	7166	0	2	10	72	381	1416	2362	2102	707	112	2	0
Wind	WSAvg	4.0	4.2	4.6	4.7	4.8	4.1	4.0	3.4	3.4	3.4	3.9	4.1	4.0
Precipitation	PrecAvg	883	35	41	64	89	112	115	77	82	85	76	49	46
	PrecMax	1436	110	108	170	174	240	359	194	203	233	247	155	135
	PrecMin	564	3	0	0	9	30	20	4	0	21	15	0	2
	PrecStd	190	26	30	45	42	61	73	50	51	48	57	47	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.8	25.2	27.8	32.3	35.2	37.8	41.3	42.2	36.2	32.3	27.1	22.4
		MCWB	12.7	16.0	17.6	20.5	24.3	24.6	23.7	24.7	23.2	21.7	18.0	14.6
	2%	DB	19.9	22.5	25.2	28.0	32.6	36.2	38.7	38.7	34.8	29.9	23.9	19.0
		MCWB	12.7	14.5	17.0	18.9	23.9	24.9	23.6	24.1	23.5	21.5	16.7	13.1
	5%	DB	16.4	19.7	22.9	26.3	31.4	35.0	37.3	37.4	32.6	27.4	22.1	16.1
		MCWB	9.4	14.1	16.2	18.5	22.7	24.4	24.2	24.2	23.3	19.5	15.4	10.6
	10%	DB	13.8	16.3	21.3	24.8	28.0	33.0	36.0	35.9	31.3	25.9	20.0	13.6
		MCWB	8.3	11.2	15.3	17.7	21.8	24.5	24.6	24.1	22.5	18.6	14.9	9.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.7	17.9	20.3	22.7	28.1	28.9	28.6	27.0	26.2	23.9	20.1	17.7
		MCDB	20.0	21.6	24.7	28.3	32.0	34.5	35.0	34.8	32.3	28.9	24.4	20.4
	2%	WB	12.9	16.2	19.2	21.5	25.1	27.2	27.0	26.0	24.9	22.9	18.3	14.2
		MCDB	17.6	21.0	23.4	26.0	30.5	32.0	33.8	34.5	31.3	27.2	21.9	16.9
	5%	WB	10.8	14.3	17.9	20.2	23.7	25.8	26.1	25.5	24.0	21.7	17.0	11.9
		MCDB	15.6	18.4	21.7	24.3	29.0	32.2	33.1	34.1	30.0	25.7	20.4	14.9
	10%	WB	8.7	11.9	16.1	19.1	22.7	25.1	25.3	24.9	23.3	20.2	15.3	9.7
		MCDB	13.4	16.2	20.4	23.1	27.3	31.9	32.6	33.4	29.1	23.9	19.2	13.9
Mean Daily Temperature Range	5% DB	MDBR	13.1	12.2	13.0	13.0	11.8	12.1	12.6	12.7	12.5	13.2	13.5	11.6
		MCDBR	17.7	16.8	15.0	15.1	14.1	13.6	14.4	14.7	14.1	14.3	15.7	16.1
		MCWBR	11.1	10.6	9.0	8.5	6.9	5.2	4.4	4.5	5.5	7.4	9.4	10.5
	5% WB	MCDBR	16.0	14.5	12.2	12.2	12.0	12.1	12.2	13.0	11.9	11.0	13.8	13.0
		MCWBR	11.0	10.3	8.1	8.1	6.7	5.9	5.2	4.8	5.2	6.6	10.1	10.2
Clear-Sky Solar Irradiance	taub	0.292	0.299	0.338	0.377	0.412	0.428	0.425	0.428	0.389	0.346	0.312	0.291	
	taud	2.508	2.503	2.414	2.326	2.299	2.298	2.298	2.336	2.272	2.356	2.467	2.496	2.510
	Ebn at Noon	921	952	934	907	875	857	857	849	868	884	886	899	
	Edh at Noon	82	92	110	126	132	132	126	132	115	95	82	77	
All-Sky Solar Radiation	RadAvg	2.86	3.45	4.56	5.61	6.05	6.81	6.87	6.25	5.19	3.96	3.01	2.42	
	RadStd	0.29	0.51	0.29	0.44	0.64	0.61	0.39	0.37	0.43	0.53	0.39	0.27	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (37 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page