

BEAUFORT MCAS, SC, USA

WMO: 722085

Lat: 32.483N

Lon: 80.717W

Elev: 11

StdP: 101.19

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 93831

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.2	-0.2	-11.9	1.3	2.4	-9.1	1.7	4.0	9.9	12.6	8.8	11.1	2.3	350	0.390

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	35.0	25.7	33.8	25.5	32.7	25.3	27.5	31.4	26.9	31.0	26.5	30.6	3.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.4	21.9	29.3	26.0	21.4	29.0	25.3	20.5	28.5	86.9	31.6	84.4	31.2	82.2	30.5	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.3	7.4	6.5	DB	-5.1	37.3	1.8	1.5	-6.3	38.4	-7.4	39.3	-8.3	40.1	-9.6	41.2	(4)
(5)			WB	-6.7	28.8	1.7	0.9	-7.8	29.4	-8.8	29.9	-9.8	30.4	-11.0	31.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.6	9.9	11.9	15.1	19.2	23.5	26.8	28.2	27.7	25.3	20.4	14.8	11.8	(6)	
	DBStd	7.44	5.16	4.69	4.49	3.69	3.06	2.28	1.65	1.74	2.53	3.82	4.45	4.98	(7)	
	HDD10.0	155	66	31	11	0	0	0	0	0	0	0	9	38	(8)	
	HDD18.3	957	262	186	117	33	3	0	0	0	1	24	122	209	(9)	
	CDD10.0	3657	64	83	169	278	418	503	564	548	459	323	154	94	(10)	
	CDD18.3	1417	2	4	18	61	162	253	306	289	209	89	17	6	(11)	
	CDH23.3	12946	6	24	111	391	1296	2471	3309	2967	1720	563	71	17	(12)	
	CDH26.7	4812	0	1	15	79	417	989	1426	1193	571	114	6	0	(13)	
(14) Wind	WSAvg	2.9	3.0	3.1	3.4	3.4	3.0	2.7	2.5	2.3	2.6	2.6	2.7	2.8	(14)	
(15) Precipitation	PrecAvg	1286	90	85	95	76	90	153	162	186	115	64	58	78	(15)	
	PrecMax	1718	224	199	226	181	267	372	486	458	312	245	197	160	(16)	
	PrecMin	848	6	6	16	2	5	23	37	32	15	2	0	2	(17)	
	PrecStd	232	52	45	55	46	59	85	91	98	79	58	47	39	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.1	26.2	28.6	31.2	34.6	36.3	36.6	36.2	33.9	31.2	27.5	25.4	(19)	
		MCWB	18.6	19.2	18.9	20.4	23.6	25.3	25.7	26.6	24.9	24.2	22.2	20.4	(20)	
	2%	DB	22.0	23.7	26.2	28.7	32.3	34.4	35.0	34.2	32.3	29.1	25.4	23.2	(21)	
		MCWB	17.6	17.8	18.5	20.7	23.0	25.2	26.0	26.0	24.8	23.1	20.2	19.3	(22)	
	5%	DB	19.8	21.4	24.1	27.2	30.6	32.9	33.8	32.9	31.2	27.8	23.7	21.2	(23)	
		MCWB	16.2	16.3	17.7	20.0	22.7	25.0	26.0	25.9	24.4	22.3	19.2	18.5	(24)	
	10%	DB	17.9	19.3	22.3	25.7	28.9	31.5	32.5	31.9	29.9	26.6	22.2	19.6	(25)	
		MCWB	15.0	15.3	16.8	19.4	22.2	24.6	25.8	25.6	23.9	21.6	18.8	17.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.3	20.8	21.3	23.8	25.7	27.8	28.3	28.3	27.2	26.3	23.4	21.7	(27)	
		MCDB	22.3	23.9	25.5	26.9	30.7	32.7	32.7	32.4	29.9	28.2	25.5	23.5	(28)	
	2%	WB	18.6	19.2	20.2	22.6	24.8	26.7	27.5	27.5	26.3	25.0	21.9	20.3	(29)	
		MCDB	20.8	22.2	23.9	26.3	29.1	31.6	31.7	31.2	29.4	27.6	23.7	22.0	(30)	
	5%	WB	17.3	17.8	19.1	21.6	24.1	26.0	26.9	26.9	25.7	24.0	20.7	19.0	(31)	
		MCDB	19.2	20.1	22.3	25.3	28.1	30.7	31.3	30.7	28.9	26.6	22.8	20.9	(32)	
	10%	WB	15.7	16.3	18.0	20.6	23.4	25.5	26.4	26.4	25.2	22.9	19.3	17.5	(33)	
		MCDB	17.6	18.6	21.0	24.1	27.3	29.9	30.9	30.2	28.5	25.3	21.5	19.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.7	11.0	11.1	11.0	10.2	9.2	9.0	8.5	8.5	10.0	11.1	10.4	(35)	
		MCDBR	11.9	12.7	12.7	11.9	11.6	10.8	10.2	9.7	9.7	10.2	11.5	10.9	(36)	
	5% WB	MCWBR	8.2	7.9	6.7	5.8	5.0	4.4	4.2	4.0	3.8	5.0	7.1	7.7	(37)	
		MCWBR	10.5	11.0	10.5	10.0	9.9	9.6	9.3	9.0	8.2	8.0	9.2	9.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.331	0.340	0.370	0.403	0.457	0.497	0.527	0.509	0.431	0.397	0.354	0.338	(40)	
		taud	2.526	2.495	2.430	2.330	2.219	2.154	2.088	2.138	2.354	2.417	2.494	2.534	(41)	
	Ebn at Noon		891	916	909	888	839	801	775	784	837	841	854	861	(42)	
		Edh at Noon	85	96	110	127	143	153	162	152	118	103	87	81	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.93	3.58	4.68	5.95	6.36	6.38	6.20	5.62	4.78	4.17	3.26	2.60	(44)	
	RadStd		0.15	0.36	0.42	0.38	0.42	0.46	0.39	0.37	0.39	0.44	0.22	0.21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		+0.64	N/A	N/A	+0.51	N/A	N/A	N/A	-88	+232	+155	(46)	
(47) Regional (37 neighbors)		+0.60	N/A	N/A	N/A	N/A	N/A	N/A	-100	+208	+145	(47)	

Nomenclature: See separate page