

WOLF CREEK PASS, CO, USA

WMO: 722101

Lat: 37.4628N

Lon: 106.8030W

Elev: 11791

StdP: 9.42

Time Zone: -7.00 (NAM)

Period: 04-19

WBAN: 03039

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.4	(c) -0.3	(d) -35.9	(e) 1.1	(f) 33.2	(g) -27.2	(h) 1.9	(i) 31.1	(j) 35.9	(k) 9.4	(l) 32.1	(m) 14.9	(n) 12.5	(o) 220	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 15.7	(c) 64.0	(d) 43.3	(e) 62.8	(f) 42.9	(g) 60.7	(h) 42.5	(i) 48.6	(j) 57.1	(k) 47.2	(l) 55.7	(m) 45.8	(n) 54.3	(o) 9.5	(p) 210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
45.4	70.4	50.2	43.5	65.3	48.8	42.7	63.4	48.3	23.9	56.8	22.8	55.3	22.0	55.5	54.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 33.8	(b) 29.0	(c) 26.3	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 33.8	(b) 29.0	(c) 26.3	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	33.2	16.3	17.7	23.1	28.9	36.0	49.0	53.2	50.1	44.4	34.4	26.8	17.1		
	DBStd	14.76	8.53	8.32	7.95	6.96	7.42	5.60	4.01	4.42	5.79	7.41	8.32	8.36		
	HDD50	6380	1044	903	834	634	436	82	16	54	179	482	696	1020		
	HDD65	11620	1509	1323	1299	1084	900	481	366	463	617	947	1146	1485		
	CDD50	236	0	0	0	0	2	52	115	56	11	0	0	0		
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	12.6	12.5	15.1	15.0	15.0	13.7	11.8	9.3	9.0	11.7	12.0	13.1	13.1		
	PrecAvg	19.9	1.5	1.6	1.9	1.6	1.3	0.9	2.1	2.6	1.9	1.7	1.5	1.6		
(15) Precipitation	PrecMax	25.0	3.3	4.1	4.1	3.5	2.8	2.0	3.6	5.5	3.4	4.4	2.6	3.4		
	PrecMin	14.4	0.6	0.7	0.6	0.6	0.1	0.1	0.6	1.0	0.4	0.0	0.1	0.3		
	PrecStd	2.4	0.7	0.6	0.7	0.9	0.7	0.5	0.8	1.0	0.7	0.9	0.6	0.7		
	PrecStd	2.4	0.7	0.6	0.7	0.9	0.7	0.5	0.8	1.0	0.7	0.9	0.6	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.4	37.3	45.5	49.5	57.1	65.7	70.0	65.8	61.2	54.4	48.0	37.4		
		MCWB	25.5	25.3	27.5	32.8	36.6	42.5	45.2	41.2	43.3	35.6	31.1	25.0		
	2%	DB	32.5	34.2	40.6	44.8	53.7	63.3	64.4	63.1	57.4	49.7	44.5	33.9		
		MCWB	22.9	24.4	27.4	29.8	35.7	41.4	44.4	43.1	39.8	32.8	29.2	23.3		
	5%	DB	30.1	31.7	36.5	42.4	49.9	61.1	63.1	60.8	55.0	46.1	39.3	30.7		
		MCWB	21.7	24.2	25.0	29.3	33.6	40.0	44.0	43.0	39.7	32.9	27.1	22.1		
	10%	DB	27.6	28.2	34.0	38.8	46.2	58.7	61.0	57.3	53.7	44.7	36.5	27.9		
		MCWB	20.6	22.2	24.6	27.6	32.5	39.3	43.7	42.6	39.4	32.2	25.5	21.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.6	28.9	31.2	34.3	39.7	46.5	50.9	50.1	46.0	42.6	33.5	27.6		
		MCDB	32.6	33.0	37.7	41.4	51.9	60.5	60.9	56.5	54.0	46.1	43.8	30.5		
	2%	WB	25.6	27.0	28.8	32.4	37.7	44.6	49.4	48.3	44.3	39.4	30.7	25.7		
		MCDB	30.5	29.8	36.1	40.0	49.3	58.5	59.0	54.9	52.5	44.0	40.0	31.1		
	5%	WB	23.3	25.1	27.0	30.8	35.5	43.0	47.9	46.8	43.0	36.2	28.4	23.7		
		MCDB	27.4	30.0	33.8	38.5	45.4	56.2	57.4	53.6	51.3	42.3	36.6	28.1		
	10%	WB	21.5	23.2	25.4	29.4	33.8	41.5	46.5	45.5	41.7	34.1	27.0	22.2		
		MCDB	25.8	28.0	31.9	37.3	43.7	53.8	55.7	52.7	49.4	40.2	34.1	27.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.7	11.8	13.2	14.4	13.6	15.5	15.7	14.4	13.8	12.6	11.6	11.4		
		MCDBR	14.2	13.8	13.9	15.8	15.5	16.2	16.8	16.0	15.4	14.5	13.1	13.2		
		MCWBR	9.7	9.6	8.4	9.1	8.1	8.8	8.1	8.4	7.9	8.9	7.5	8.7		
	5% WB	MCDBR	12.3	11.6	11.9	13.9	14.3	15.7	15.9	14.2	14.0	11.9	12.3	11.9		
		MCWBR	9.3	9.0	8.1	8.9	8.7	8.8	8.6	8.7	8.0	9.1	7.9	9.0		
(40) Clear-Sky Solar Irradiance	taub	0.188	0.192	0.211	0.233	0.245	0.243	0.281	0.266	0.238	0.218	0.203	0.191			
	taud	2.608	2.616	2.616	2.634	2.668	2.694	2.599	2.633	2.773	2.786	2.701	2.626			
	Ebn at Noon	335	344	341	334	329	327	314	319	327	329	327	327			
	Edh at Noon	22	25	28	29	29	28	30	29	23	21	20	20			
(44) All-Sky Solar Radiation	RadAvg	962	1260	1677	1997	2221	2427	2033	1859	1702	1351	1019	823			
	RadStd	59	80	113	112	181	148	125	95	97	102	69	49			

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page