

FORT MEYERS SW FLORIDA INTL, FL, USA

WMO: 722108

Lat: 26.536N

Lon: 81.755W

Elev: 31

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12894

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	41.6	45.6	27.6	21.6	52.7	32.2	26.7	54.1	24.1	71.7	20.6	70.4	5.9	0	0.364

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.5	93.4	76.6	92.2	76.6	91.0	76.5	80.2	87.3	79.4	86.6	78.7	86.1	7.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.8	149.7	82.6	77.4	142.8	82.2	76.9	140.2	81.9	43.5	86.7	42.8	86.2	42.2	86.5	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.2	17.9	16.0	DB	34.8	96.4	4.4	1.5	31.6	97.5	29.0	98.4	26.5	99.2	23.2	100.3
			WB	31.5	81.7	4.7	2.0	28.1	83.1	25.4	84.2	22.8	85.3	19.3	86.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	74.7	63.7	66.7	69.3	73.6	78.1	81.5	82.6	83.0	81.8	77.7	70.9	67.0
	DBStd	8.29	7.38	6.91	5.90	4.42	3.19	2.52	2.18	1.96	2.16	4.42	5.66	7.12
	HDD50	8	5	1	0	0	0	0	0	0	0	0	0	2
	HDD65	295	114	61	31	4	0	0	0	0	0	2	18	65
	CDD50	9024	430	468	599	709	871	945	1009	1023	955	858	627	530
	CDD65	3836	74	107	165	263	406	495	544	558	505	395	195	129
	CDH74	33660	425	694	1244	2209	3841	4681	5335	5482	4597	3219	1229	704
	CDH80	12453	43	112	272	696	1606	2024	2242	2250	1754	1086	258	110
Wind	WSAvg	7.0	7.6	7.6	8.1	7.8	7.2	6.2	5.4	5.6	6.4	7.6	7.5	7.3
Precipitation	PrecAvg	50.6	2.1	1.8	2.2	2.1	2.6	9.2	8.5	8.9	8.1	2.7	1.4	1.4
	PrecMax	68.3	11.2	3.5	7.2	5.2	8.0	18.0	13.3	13.9	15.5	7.5	4.7	3.9
	PrecMin	36.5	0.0	0.1	0.1	0.2	0.0	4.2	4.1	5.0	4.9	0.5	0.0	0.2
	PrecStd	7.8	2.4	1.1	1.9	1.4	1.8	3.7	2.6	2.2	2.6	1.9	1.3	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	83.5	85.5	88.0	90.6	93.2	95.2	94.9	95.0	93.1	91.1	87.8	85.2
		MCWB	70.3	70.3	71.5	72.1	73.3	76.5	77.0	77.7	76.8	76.5	74.6	73.2
	2%	DB	81.2	83.1	84.9	88.2	91.1	93.1	93.0	92.9	91.4	89.5	84.9	82.7
		MCWB	69.2	70.3	69.9	71.7	73.1	76.2	77.2	77.5	76.9	75.7	73.0	71.7
	5%	DB	79.0	81.3	83.0	86.2	89.8	91.2	91.3	91.3	90.3	87.9	82.8	81.0
		MCWB	68.0	69.4	69.2	70.9	73.1	76.3	77.3	77.4	76.9	75.0	71.3	70.7
	10%	DB	76.0	79.0	81.2	84.2	88.0	89.8	90.1	90.2	88.8	86.0	81.1	78.5
		MCWB	66.7	68.0	68.6	70.1	72.9	76.3	77.4	77.6	76.8	74.0	70.0	69.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.9	74.1	75.3	76.4	78.2	80.4	81.2	81.1	80.9	79.3	77.0	75.5
		MCDB	79.0	80.9	82.2	84.4	87.4	88.6	88.2	88.4	87.1	84.9	83.0	81.5
	2%	WB	71.8	72.4	73.7	75.0	77.0	79.1	79.9	80.1	79.5	78.1	75.3	74.0
		MCDB	77.1	79.1	80.0	82.7	85.8	87.3	87.1	87.4	86.1	84.4	81.8	79.3
	5%	WB	70.2	71.2	72.5	73.7	76.0	78.2	79.0	79.3	78.6	77.3	73.9	72.5
		MCDB	75.8	77.8	79.1	81.6	84.6	86.5	86.4	86.7	85.4	83.9	79.7	77.8
	10%	WB	68.6	69.9	70.9	72.6	75.1	77.5	78.3	78.5	78.1	76.4	72.4	70.8
		MCDB	74.4	76.4	77.8	80.5	83.3	85.8	85.9	85.9	85.0	82.5	78.0	76.2
Mean Daily Temperature Range	5% DB	MDBR	20.4	20.8	21.1	21.1	20.3	17.1	15.8	15.5	14.7	16.4	18.8	18.9
		MCDBR	20.8	21.1	21.5	22.3	22.1	19.3	17.4	17.0	16.2	16.6	18.2	18.8
		MCWBR	10.4	9.7	9.1	9.0	7.7	6.4	5.9	5.6	5.2	5.5	7.6	8.9
	5% WB	MCDBR	17.8	18.7	18.6	19.3	18.8	16.7	15.8	15.4	14.6	14.4	16.2	16.6
		MCWBR	10.7	9.5	9.8	9.1	7.5	6.7	6.2	5.9	5.7	5.5	7.8	9.4
Clear-Sky Solar Irradiance	taub	0.350	0.366	0.379	0.392	0.419	0.444	0.460	0.449	0.421	0.401	0.364	0.354	
	taud	2.514	2.480	2.429	2.374	2.350	2.355	2.302	2.360	2.425	2.449	2.496	2.529	
	Ebn at Noon	286	289	290	288	278	269	265	268	273	274	279	279	
	Edh at Noon	30	33	36	39	40	40	42	39	36	33	30	28	
All-Sky Solar Radiation	RadAvg	1177	1441	1745	2020	2066	1856	1825	1769	1599	1497	1268	1087	
	RadStd	81	83	107	85	141	164	124	86	99	85	67	75	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.70	+2.00	N/A	N/A	N/A	N/A	-4	-67	+299	+191
(47)	Regional (34 neighbors)	+0.74	+1.57	N/A	N/A	N/A	N/A	-2	-45	+263	+200

Nomenclature: See separate page