

FORT MEYERS SW FLORIDA INTL, FL, USA

WMO: 722108

Lat: 26.536N

Lon: 81.755W

Elev: 10

StdP: 101.21

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12894

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.4	7.5	-2.4	3.1	11.5	0.1	3.8	12.3	10.8	22.0	9.2	21.3	2.6	0	0.364

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.6	34.1	24.8	33.4	24.8	32.8	24.7	26.8	30.7	26.3	30.3	25.9	30.0	3.4	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.0	21.4	28.1	25.2	20.4	27.9	24.9	20.0	27.7	83.2	30.4	81.7	30.1	80.3	30.3	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.0	8.0	7.1	1.5	35.8	2.5	0.8	-0.2	36.4	-1.7	36.9	-3.1	37.4	-4.9	38.0		
			-0.3	27.6	2.6	1.1	-2.2	28.4	-3.7	29.0	-5.1	29.6	-7.0	30.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.7	17.6	19.3	20.7	23.1	25.6	27.5	28.1	28.3	27.7	25.4	21.6	19.5
	DBStd	4.60	4.10	3.84	3.28	2.46	1.77	1.40	1.21	1.09	1.20	2.45	3.14	3.95
	HDD10.0	4	3	1	0	0	0	0	0	0	0	0	0	1
	HDD18.3	164	63	34	17	2	0	0	0	0	0	1	10	36
	CDD10.0	5013	239	260	333	394	484	525	561	568	531	477	348	294
	CDD18.3	2131	41	59	92	146	226	275	302	310	281	219	108	72
	CDH23.3	18700	236	386	691	1227	2134	2601	2964	3046	2554	1788	683	391
	CDH26.7	6918	24	62	151	387	892	1124	1246	1250	974	603	143	61
Wind	WSAvg	3.1	3.4	3.4	3.6	3.5	3.2	2.8	2.4	2.5	2.9	3.4	3.4	3.2
Precipitation	PrecAvg	1286	54	45	55	53	66	233	217	225	207	68	36	35
	PrecMax	1735	284	89	184	131	204	458	339	354	393	190	120	100
	PrecMin	926	0	2	3	5	1	106	105	128	125	12	0	4
	PrecStd	198	62	27	48	35	46	95	67	55	66	49	32	29
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.6	29.7	31.1	32.6	34.0	35.1	35.0	35.0	33.9	32.8	31.0	29.6
		MCWB	21.3	21.3	22.0	22.3	22.9	24.7	25.0	25.4	24.9	24.7	23.7	22.9
	2%	DB	27.3	28.4	29.4	31.2	32.8	33.9	33.9	33.8	33.0	32.0	29.4	28.2
		MCWB	20.7	21.3	21.1	22.0	22.8	24.6	25.1	25.3	24.9	24.3	22.8	22.0
	5%	DB	26.1	27.4	28.4	30.1	32.1	32.9	32.9	32.9	32.4	31.1	28.2	27.2
		MCWB	20.0	20.8	20.7	21.6	22.8	24.6	25.2	25.2	24.9	23.9	21.8	21.5
	10%	DB	24.4	26.1	27.3	29.0	31.1	32.1	32.3	32.3	31.6	30.0	27.3	25.9
		MCWB	19.3	20.0	20.3	21.1	22.7	24.6	25.2	25.3	24.9	23.3	21.1	20.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.3	23.4	24.1	24.6	25.7	26.9	27.3	27.3	27.2	26.3	25.0	24.2
		MCDB	26.1	27.1	27.9	29.1	30.8	31.5	31.2	31.3	30.6	29.4	28.3	27.5
	2%	WB	22.1	22.5	23.1	23.9	25.0	26.2	26.6	26.7	26.4	25.6	24.1	23.3
		MCDB	25.1	26.2	26.7	28.2	29.9	30.7	30.6	30.8	30.0	29.1	27.7	26.3
	5%	WB	21.2	21.8	22.5	23.2	24.5	25.7	26.1	26.3	25.9	25.2	23.3	22.5
		MCDB	24.4	25.5	26.2	27.5	29.2	30.3	30.2	30.4	29.7	28.8	26.5	25.5
	10%	WB	20.4	21.1	21.6	22.6	23.9	25.3	25.7	25.8	25.6	24.7	22.5	21.6
		MCDB	23.5	24.7	25.5	26.9	28.5	29.9	30.0	29.9	29.5	28.1	25.5	24.5
Mean Daily Temperature Range	5% DB	MDBR	11.3	11.6	11.7	11.7	11.3	9.5	8.8	8.6	8.1	9.1	10.4	10.5
		MCDBR	11.5	11.7	12.0	12.4	12.3	10.7	9.7	9.4	9.0	9.2	10.1	10.4
		MCWBR	5.8	5.4	5.1	5.0	4.3	3.6	3.3	3.1	2.9	3.0	4.2	4.9
	5% WB	MCDBR	9.9	10.4	10.3	10.7	10.5	9.3	8.8	8.6	8.1	8.0	9.0	9.2
		MCWBR	6.0	5.3	5.4	5.1	4.2	3.7	3.4	3.3	3.1	3.1	4.4	5.2
Clear-Sky Solar Irradiance	taub	0.350	0.366	0.379	0.392	0.419	0.444	0.460	0.449	0.421	0.401	0.364	0.354	
	taud	2.514	2.480	2.429	2.374	2.350	2.355	2.302	2.360	2.425	2.449	2.496	2.529	
	Ebn at Noon	901	911	915	907	876	848	834	844	862	863	878	881	
	Edh at Noon	93	103	114	124	127	126	132	124	113	105	94	88	
All-Sky Solar Radiation	RadAvg	3.71	4.54	5.50	6.37	6.51	5.85	5.75	5.58	5.04	4.72	4.00	3.43	
	RadStd	0.26	0.26	0.34	0.27	0.45	0.52	0.39	0.27	0.31	0.27	0.21	0.24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.39	+1.11	N/A	N/A	N/A	N/A	-2	-37	+166	+106
(47)	Regional (34 neighbors)	+0.41	+0.87	N/A	N/A	N/A	N/A	-1	-25	+146	+111

Nomenclature: See separate page