

GILMER, TX, USA

WMO: 722112

Lat: 32.699N

Lon: 94.949W

Elev: 415

StdP: 14.48

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 53982

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.9	29.6	13.5	11.1	35.9	18.0	13.8	36.8	18.9	56.8	17.3	57.3	2.4	0	0.379

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.5	98.9	76.4	96.7	76.0	93.4	75.7	79.7	90.0	78.8	89.3	78.1	88.5	5.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.3	144.4	82.5	75.9	137.5	82.0	75.2	134.3	81.7	43.4	89.9	42.5	90.3	41.7	88.4	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.7	14.7	12.5	20.8	101.2	3.7	2.0	18.1	102.7	16.0	103.9	13.9	105.0	11.2	106.5		
			18.4	81.4	3.5	1.4	15.9	82.4	13.9	83.2	12.0	84.0	9.4	85.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.1	47.5	50.7	59.1	65.3	73.1	80.9	82.5	83.3	77.6	66.8	56.6	49.1
	DBStd	14.96	9.77	10.39	9.22	7.64	6.19	4.11	3.56	4.08	5.39	8.43	9.34	9.55
	HDD50	485	166	109	26	3	0	0	0	0	0	2	42	137
	HDD65	2155	548	410	230	88	13	0	0	0	1	83	282	500
	CDD50	6370	88	129	307	462	717	926	1008	1033	829	523	238	110
	CDD65	2566	6	10	45	97	265	476	543	568	380	139	29	8
	CDH74	26717	13	43	280	774	2338	5249	6219	6691	3788	1158	140	24
	CDH80	12134	0	3	31	155	803	2502	3057	3472	1738	357	15	1
(14) Wind	WSAvg	4.8	5.4	5.9	6.3	6.3	5.1	4.6	3.7	3.4	3.3	4.1	4.7	5.0
(15) Precipitation	PrecAvg	48.5	4.2	3.8	4.4	4.1	4.5	4.4	3.4	3.0	3.9	4.5	4.0	4.3
	PrecMax	67.7	10.0	8.6	8.3	9.3	7.6	8.7	9.7	8.9	10.4	15.8	10.3	8.3
	PrecMin	26.3	0.3	0.0	1.6	1.4	0.6	0.5	0.0	0.2	1.0	0.3	0.5	0.5
	PrecStd	11.1	2.4	2.2	1.9	2.4	2.2	2.6	2.5	1.8	2.7	3.6	2.4	2.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.4	79.2	82.4	88.3	91.7	99.4	100.0	100.3	99.0	90.5	82.1	77.0
		MCWB	63.1	63.1	66.4	71.3	73.7	76.0	76.4	76.7	73.8	71.2	69.6	66.3
	2%	DB	72.4	74.6	80.9	83.7	90.0	96.8	97.3	99.1	94.8	87.7	78.7	73.0
		MCWB	61.7	62.7	65.8	69.3	73.5	75.8	76.6	77.1	73.8	72.4	67.8	65.4
	5%	DB	69.0	71.9	77.3	81.4	87.7	93.1	94.3	97.0	91.5	84.0	74.2	70.0
		MCWB	61.2	62.7	64.2	67.9	73.0	75.5	76.6	76.5	74.0	70.6	66.5	63.8
	10%	DB	64.3	67.7	73.3	79.0	84.3	91.0	92.1	93.5	89.9	81.2	71.8	66.0
		MCWB	57.5	60.5	63.2	66.4	72.1	75.9	76.4	76.3	73.6	69.7	65.6	60.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.4	68.2	70.5	74.2	77.9	80.5	80.4	81.4	79.0	77.2	72.2	69.9
		MCDB	72.1	74.0	78.6	81.9	85.8	89.5	88.2	90.9	87.2	83.9	77.9	73.6
	2%	WB	65.5	66.5	68.6	72.5	76.1	79.0	79.3	79.9	77.8	75.3	70.5	67.4
		MCDB	69.6	71.6	76.0	79.8	84.6	89.3	89.3	91.0	86.7	81.9	75.6	71.6
	5%	WB	63.3	64.7	67.1	71.0	74.9	78.1	78.4	78.9	76.8	73.9	68.7	65.3
		MCDB	66.6	69.1	74.2	78.3	83.4	88.3	88.6	90.2	85.7	80.3	73.4	69.2
	10%	WB	58.5	62.1	65.6	69.4	73.8	77.2	77.8	78.1	75.8	72.3	66.1	62.0
		MCDB	63.4	66.3	72.2	76.0	82.0	87.1	88.2	89.0	84.4	78.2	70.6	64.9
(35) Mean Daily Temperature Range	5% DB	MDBR	18.9	18.6	20.4	21.0	19.2	18.6	18.3	19.5	20.6	20.9	20.1	19.2
		MCDBR	23.6	21.7	21.5	22.0	20.7	21.2	21.1	22.6	23.2	22.1	21.4	22.3
		MCWBR	14.8	13.4	10.2	10.5	7.4	5.9	5.4	5.5	7.2	9.1	12.6	15.8
	5% WB	MCDBR	19.2	18.7	17.9	17.9	17.8	17.8	17.7	19.3	18.3	17.7	18.2	19.2
		MCWBR	15.0	14.3	10.6	10.2	7.9	6.6	6.1	6.0	6.5	9.0	13.4	15.4
(40) Clear-Sky Solar Irradiance	taub		0.322	0.337	0.359	0.396	0.427	0.448	0.461	0.458	0.410	0.360	0.345	0.327
	taud		2.496	2.464	2.419	2.317	2.288	2.271	2.269	2.270	2.362	2.478	2.469	2.495
	Ebn at Noon		285	291	292	284	274	267	263	262	272	279	273	276
	Edh at Noon		28	31	35	41	43	43	43	42	37	30	28	26
(44) All-Sky Solar Radiation	RadAvg		866	976	1362	1691	1840	2007	2031	1898	1605	1282	931	757
	RadStd		79	157	122	107	144	177	146	148	144	176	115	98

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page