

WAYCROSS-WARE COUNTY AP, GA, USA

WMO: 722130

Lat: 31.250N

Lon: 82.400W

Elev: 43

StdP: 100.81

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 13861

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.2	0.0	-10.8	1.5	6.2	-7.4	2.0	5.4	9.9	16.1	8.6	14.2	1.2	290	0.363

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	36.3	25.7	35.1	25.3	34.0	25.1	27.9	32.9	27.4	32.2	26.9	31.5	2.9	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.9	22.6	29.9	26.3	21.8	29.5	25.9	21.4	29.2	89.1	33.2	86.9	31.9	84.7	31.7	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.0	7.0	5.8	DB	-4.6	37.2	1.9	1.4	-6.0	38.2	-7.1	39.1	-8.2	39.9	-9.6	40.9	
			WB	-5.9	28.5	1.8	0.9	-7.2	29.2	-8.2	29.7	-9.2	30.2	-10.5	30.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.6	11.4	13.4	16.6	20.2	24.2	27.5	28.5	28.2	26.1	21.3	15.9	13.2
	DBStd	7.17	5.39	4.93	4.65	3.71	2.97	2.18	1.61	1.57	2.32	3.96	4.54	5.27
	HDD10.0	107	49	19	6	1	0	0	0	0	0	0	6	26
	HDD18.3	777	222	150	87	23	2	0	0	0	0	19	100	174
	CDD10.0	3970	92	116	212	307	439	524	573	566	483	350	182	126
	CDD18.3	1597	6	12	35	80	182	274	314	307	233	111	26	16
	CDH23.3	15642	41	91	321	795	1832	2833	3371	3143	2072	866	201	78
CDH26.7	6801	2	10	72	252	803	1391	1652	1454	858	264	32	9	
Wind	WSAvg	2.3	2.5	2.5	2.7	2.6	2.4	2.1	1.9	1.8	2.1	2.0	2.1	2.3
Precipitation	PrecAvg	1290	114	96	118	76	88	149	162	159	105	67	63	86
	PrecMax	1871	375	215	297	266	305	312	344	284	463	227	193	176
	PrecMin	838	18	20	8	4	5	26	32	37	11	0	3	10
	PrecStd	233	71	48	70	59	66	66	64	66	80	58	48	42
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.0	27.9	30.9	32.9	36.0	37.6	37.7	36.9	35.3	32.9	29.2	28.0
		MCWB	20.5	19.6	21.3	22.9	22.3	25.6	26.4	26.6	23.1	23.7	22.8	22.6
	2%	DB	24.1	26.3	28.7	31.3	33.9	36.1	36.3	35.5	33.7	31.2	27.5	25.6
		MCWB	18.8	19.1	20.4	21.6	22.5	25.6	26.2	26.5	24.4	23.1	21.1	20.3
	5%	DB	22.3	23.9	27.1	29.4	32.6	34.5	34.9	34.1	32.6	29.2	26.0	23.6
		MCWB	17.9	18.1	19.4	20.6	22.5	25.0	26.0	26.0	24.7	22.2	20.1	20.3
	10%	DB	20.1	22.1	24.9	27.8	31.2	33.0	33.7	32.9	31.3	27.8	23.9	22.1
		MCWB	17.1	17.3	18.1	19.8	22.3	24.7	25.7	25.8	24.5	21.6	19.4	19.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.9	22.0	23.0	24.6	25.8	28.0	28.6	28.6	27.7	26.2	25.3	24.0
		MCDB	24.0	25.0	27.0	29.7	30.8	33.8	33.8	33.9	30.9	30.1	27.3	25.8
	2%	WB	20.4	20.6	21.9	23.4	25.0	27.3	27.9	27.9	26.9	25.2	23.5	22.5
		MCDB	23.2	24.2	26.3	28.4	30.0	33.1	33.1	32.8	30.5	28.6	25.5	24.2
	5%	WB	19.0	19.4	20.8	22.4	24.2	26.6	27.4	27.4	26.2	24.3	21.8	21.0
		MCDB	21.4	22.8	24.9	27.1	29.2	32.4	32.5	31.9	29.9	27.3	24.5	22.9
	10%	WB	17.4	18.1	19.8	21.4	23.5	25.9	26.8	26.9	25.7	23.4	20.2	19.3
		MCDB	19.2	21.0	23.4	25.8	28.4	31.2	31.7	31.0	29.2	26.0	23.2	21.5
Mean Daily Temperature Range	5% DB	MDBR	12.2	12.3	13.0	13.1	12.4	10.9	10.5	9.8	10.0	11.8	12.9	11.8
		MCDBR	13.4	13.7	14.2	14.3	13.8	12.6	12.0	11.0	11.2	12.1	13.3	12.2
		MCWBR	8.4	7.8	6.9	5.7	4.7	4.2	3.8	3.9	4.1	5.5	7.3	7.8
	5% WB	MCDBR	11.2	11.8	12.0	11.9	11.2	11.0	10.5	9.9	9.2	9.5	10.1	10.2
		MCWBR	8.3	7.7	6.8	5.8	4.6	4.4	4.1	4.1	4.0	4.8	6.6	7.4
Clear-Sky Solar Irradiance	taub		0.328	0.335	0.376	0.390	0.432	0.478	0.513	0.502	0.428	0.382	0.349	0.336
	taud		2.517	2.500	2.403	2.359	2.276	2.209	2.114	2.147	2.349	2.445	2.487	2.523
	Ebn at Noon		900	927	906	902	862	818	788	792	843	862	867	872
	Edh at Noon		87	97	114	124	136	145	158	152	119	101	89	83
All-Sky Solar Radiation	RadAvg		3.04	3.64	4.78	5.84	6.39	6.08	6.05	5.51	4.81	4.21	3.37	2.66
	RadStd		0.18	0.42	0.44	0.43	0.36	0.41	0.38	0.36	0.39	0.40	0.23	0.23

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (36 neighbors)	+0.49	N/A	N/A	N/A	N/A	N/A	N/A	-78	+168	+114

Nomenclature: See separate page