

VIDALIA, GA, USA

WMO: 722134

Lat: 32.193N

Lon: 82.372W

Elev: 274

StdP: 14.55

Time Zone: -5.00 (NAE)

Period: 01-19

WBAN: 63822

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.0	32.1	10.1	9.3	40.6	15.6	12.2	41.5	18.7	56.1	16.9	55.5	4.3	320	0.355

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.0	97.0	75.2	94.9	75.5	91.5	74.9	80.2	89.5	79.0	88.1	78.2	87.0	6.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.5	144.3	82.8	77.1	142.5	82.5	76.3	138.5	82.0	43.9	89.5	42.7	88.4	41.6	87.6	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.5	13.9	12.0	DB	24.2	99.3	3.5	3.6	21.7	101.9	19.7	104.0	17.8	106.0	15.3	108.6
			WB	21.5	81.4	3.3	2.1	19.1	82.9	17.1	84.1	15.2	85.3	12.8	86.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.6	50.6	53.9	59.5	67.2	74.5	80.4	82.6	82.1	77.9	68.7	58.9	53.8	(6)
	DBStd	13.26	9.47	8.81	8.26	6.59	5.55	3.49	3.05	3.08	4.50	7.22	7.69	8.89	(7)
	HDD50	257	110	54	19	1	0	0	0	0	0	0	14	59	(8)
	HDD65	1662	452	323	206	53	6	0	0	0	1	47	211	363	(9)
	CDD50	6679	130	163	315	516	761	913	1010	996	836	579	282	178	(10)
	CDD65	2608	7	12	37	119	302	463	545	531	386	160	29	17	(11)
	CDH74	24245	36	89	300	1103	2805	4463	5654	5113	3237	1197	185	63	(12)
	CDH80	10244	1	9	42	297	1136	2077	2710	2300	1323	329	18	2	(13)
(14) Wind	WSAvg	4.9	5.4	5.5	5.8	5.5	5.1	4.4	4.2	4.1	4.6	4.6	4.8	5.0	(14)
(15) Precipitation	PrecAvg	47.1	4.4	3.8	4.7	2.6	2.4	5.3	4.9	5.3	3.8	3.5	2.8	3.5	(15)
	PrecMax	59.6	9.7	7.8	9.3	6.0	5.6	8.1	9.3	10.2	11.7	10.6	6.6	7.8	(16)
	PrecMin	35.0	1.3	1.1	0.4	1.1	0.3	1.2	2.0	2.3	0.1	0.4	0.6	1.1	(17)
	PrecStd	7.4	2.0	1.8	2.8	1.4	1.2	2.1	1.9	2.2	2.7	2.7	1.7	1.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.8	81.4	83.7	90.3	95.3	99.1	99.5	98.9	95.3	90.2	82.0	79.2	(19)
		MCWB	67.6	67.2	66.9	69.6	69.6	74.7	76.6	77.7	73.8	72.8	69.0	68.0	(20)
	2%	DB	73.1	77.0	81.1	86.3	91.2	95.4	97.0	95.4	91.4	86.4	79.2	75.4	(21)
		MCWB	64.9	63.6	65.2	67.7	70.1	74.2	75.5	77.9	74.0	71.2	65.9	65.7	(22)
	5%	DB	69.9	72.5	77.3	82.4	89.8	93.0	94.8	93.0	90.2	83.6	75.4	72.0	(23)
		MCWB	62.7	60.9	62.1	65.7	69.8	74.5	76.2	77.3	73.7	70.4	64.8	66.2	(24)
	10%	DB	64.4	69.5	73.2	81.0	86.4	90.4	91.2	90.6	88.1	81.1	72.4	68.2	(25)
		MCWB	59.3	60.7	60.8	64.6	69.5	74.0	76.0	76.6	73.7	68.4	63.8	64.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.6	69.3	70.3	73.3	76.1	80.0	81.2	82.4	79.6	78.0	74.0	71.5	(27)
		MCDB	73.7	75.3	78.0	83.2	86.2	91.6	90.2	92.6	86.2	83.3	78.9	75.7	(28)
	2%	WB	66.8	66.8	67.9	71.7	74.3	78.3	79.6	80.8	78.3	75.7	71.2	69.3	(29)
		MCDB	72.3	74.1	75.8	80.1	83.7	89.1	90.0	89.9	85.0	80.6	75.2	71.6	(30)
	5%	WB	64.2	64.5	65.9	70.1	73.2	77.3	78.5	79.4	77.2	73.5	69.0	67.1	(31)
		MCDB	67.5	69.4	73.8	77.6	82.2	87.4	88.7	87.8	84.2	79.1	72.5	70.9	(32)
	10%	WB	61.7	62.2	64.1	68.4	72.1	76.2	77.8	78.3	75.9	72.1	65.8	64.1	(33)
		MCDB	64.8	66.5	70.3	76.4	80.8	85.7	87.7	86.4	83.6	78.0	71.2	67.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	19.8	20.7	21.5	22.3	21.1	19.0	19.0	17.9	18.5	20.8	21.7	19.4	(35)
		MCDBR	21.6	24.7	24.5	25.0	24.3	22.7	22.0	20.4	21.2	21.7	23.7	20.7	(36)
	5% WB	MCWBR	13.9	14.0	11.1	9.6	7.4	6.6	6.1	6.4	6.7	8.8	12.7	13.2	(37)
		MCWBR	18.7	20.4	20.2	20.1	19.1	18.9	18.8	18.0	16.6	16.1	17.2	18.2	(38)
(40) Clear-Sky Solar Irradiance	taub		0.324	0.331	0.362	0.388	0.431	0.480	0.512	0.509	0.421	0.380	0.349	0.326	(40)
		taud	2.508	2.484	2.427	2.347	2.261	2.188	2.107	2.111	2.349	2.431	2.467	2.531	(41)
	Ebn at Noon		285	294	291	286	273	259	250	249	269	273	273	279	(42)
		Edh at Noon	27	31	35	40	44	47	50	50	38	32	29	26	(43)
(44) All-Sky Solar Radiation	RadAvg		937	1129	1478	1840	2005	1984	1945	1768	1535	1320	1032	813	(44)
	RadStd		51	114	122	125	130	141	115	98	128	137	75	76	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (36 neighbors)	+0.99	N/A	N/A	N/A	N/A	N/A	N/A	-162	+338	+234

Nomenclature: See separate page