

TALLAHASSEE NWS, FL, USA

WMO: 722140

Lat: 30.4459N

Lon: 84.3007W

Elev: 173

StdP: 14.60

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 93805

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.5	30.0	12.0	10.2	40.5	17.0	13.0	42.1	21.5	57.8	19.4	57.6	2.0	340	0.374

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.3	96.2	76.2	94.3	75.8	92.5	75.5	80.0	88.8	79.1	87.7	78.3	86.7	7.6	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.9	146.0	82.9	77.0	141.6	82.3	76.2	137.6	81.7	43.5	89.0	42.6	87.7	41.8	86.7	86.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.3	16.2	13.7	DB	20.7	99.4	3.5	2.6	18.2	101.2	16.1	102.8	14.2	104.2	11.7	106.1	(4)
(5)			WB	19.1	81.9	3.4	1.5	16.6	83.0	14.6	83.9	12.7	84.8	10.2	85.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.6	52.1	55.9	61.4	67.6	75.3	80.8	82.4	82.4	79.1	70.5	60.4	54.9	(6)	
	DBStd	12.81	9.37	8.76	7.99	6.31	4.96	3.36	2.66	2.68	3.98	7.27	8.12	9.41	(7)	
	HDD50	208	90	38	12	0	0	0	0	0	0	0	11	57	(8)	
	HDD65	1441	408	271	161	47	3	0	0	0	0	36	183	332	(9)	
	CDD50	7014	155	203	366	528	786	925	1005	1004	873	635	324	210	(10)	
	CDD65	2768	8	15	50	124	323	475	540	539	423	205	46	20	(11)	
	CDH74	26655	27	101	479	1243	3375	4635	5399	5362	3875	1759	322	78	(12)	
	CDH80	11081	0	5	78	320	1452	2167	2476	2388	1615	536	43	1	(13)	
(14) Wind	WSAvg	5.5	5.9	6.0	6.4	6.2	5.7	5.1	4.5	4.6	5.4	5.4	5.2	5.5	(14)	
(15) Precipitation	PrecAvg	63.8	4.8	5.1	6.1	3.5	4.4	7.4	8.4	7.5	5.7	3.2	3.6	4.4	(15)	
	PrecMax	104.2	18.9	11.5	13.6	13.1	11.7	17.4	20.1	15.7	15.9	11.8	10.4	12.6	(16)	
	PrecMin	44.5	0.4	0.6	0.2	0.3	0.0	2.0	2.4	2.4	0.1	0.0	0.6	0.8	(17)	
	PrecStd	12.2	3.4	2.8	3.5	2.9	3.0	3.9	4.3	3.1	3.7	2.9	2.3	2.4	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.0	80.7	85.6	89.1	95.4	98.7	98.5	97.8	95.4	90.3	84.3	79.2	(19)	
		MCWB	66.3	66.8	65.5	69.3	72.2	75.6	77.3	77.2	75.2	73.1	70.2	68.4	(20)	
	2%	DB	74.1	77.2	82.2	86.1	92.4	95.8	95.6	95.1	92.7	87.8	80.8	76.3	(21)	
		MCWB	65.1	64.8	65.7	68.4	71.9	75.4	76.8	77.1	74.8	71.9	69.1	67.7	(22)	
	5%	DB	71.2	74.1	79.4	83.8	90.0	93.3	93.5	93.1	90.8	85.6	77.7	73.3	(23)	
		MCWB	63.6	63.9	64.9	67.3	71.3	74.9	76.7	76.8	74.4	70.9	67.0	67.1	(24)	
	10%	DB	68.0	70.8	76.3	81.4	87.8	90.7	91.3	91.0	88.7	83.1	74.9	70.4	(25)	
		MCWB	62.0	62.2	63.4	65.8	70.5	74.7	76.4	76.7	74.1	70.2	65.4	65.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.0	70.8	72.0	74.4	77.4	80.0	81.2	81.4	79.4	78.4	75.5	72.9	(27)	
		MCDB	73.1	75.2	77.8	80.9	87.2	89.0	90.0	90.4	86.9	83.6	79.4	75.3	(28)	
	2%	WB	67.8	68.8	70.1	72.6	75.9	78.5	80.0	80.2	78.2	76.4	72.9	70.6	(29)	
		MCDB	71.3	73.4	75.8	79.5	84.9	87.7	89.0	88.9	85.9	82.3	76.6	73.5	(30)	
	5%	WB	65.7	66.7	68.4	71.2	74.9	77.7	79.0	79.3	77.3	75.0	70.5	68.6	(31)	
		MCDB	69.5	71.5	74.5	78.3	83.5	87.1	87.9	87.7	85.1	80.9	74.5	71.9	(32)	
	10%	WB	63.4	64.6	66.5	69.7	73.6	76.9	78.1	78.3	76.5	73.3	68.0	66.1	(33)	
		MCDB	67.0	68.9	73.0	77.0	81.9	85.8	86.9	86.4	83.8	79.0	73.1	69.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	23.3	23.8	24.9	24.9	23.7	19.3	18.3	17.6	18.3	22.2	24.0	22.2	(35)	
		MCDBR	23.8	25.2	26.9	26.5	26.0	23.3	21.5	20.7	21.2	22.6	24.3	21.3	(36)	
	5% WB	MCWBR	15.9	15.1	13.4	11.6	9.4	7.2	6.7	6.5	6.9	9.7	13.5	14.2	(37)	
		MCWBR	18.7	19.5	19.9	20.5	21.0	19.3	18.6	17.9	17.0	16.3	17.4	17.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.332	0.340	0.358	0.387	0.443	0.494	0.506	0.492	0.431	0.379	0.350	0.336	(40)	
		taud	2.522	2.502	2.462	2.372	2.244	2.157	2.141	2.185	2.341	2.465	2.484	2.532	(41)	
	Ebn at Noon		286	293	294	287	271	255	252	254	267	276	276	278	(42)	
		Edh at Noon	28	31	34	39	44	48	49	46	38	32	29	26	(43)	
(44) All-Sky Solar Radiation	RadAvg		995	1181	1567	1891	2058	1873	1831	1689	1564	1399	1115	878	(44)	
	RadStd		73	144	128	151	134	148	133	128	122	124	81	81	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.94	+1.48	N/A	N/A	N/A	N/A	-40	-148	+311	+220
(47) Regional (25 neighbors)		+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+288	+184

Nomenclature: See separate page