

TALLAHASSEE NWS, FL, USA

WMO: 722140

Lat: 30.4459N

Lon: 84.3007W

Elev: 53

StdP: 100.69

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 93805

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.1	-1.1	-11.1	1.5	4.7	-8.3	1.9	5.6	9.6	14.3	8.7	14.2	0.9	340	0.374

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	35.7	24.6	34.6	24.3	33.6	24.2	26.7	31.6	26.2	31.0	25.7	30.4	3.4	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.5	20.9	28.3	25.0	20.2	27.9	24.6	19.7	27.6	83.3	31.6	81.2	30.9	79.3	30.4	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.2	7.2	6.1	DB	-6.3	37.4	1.9	1.4	-7.7	38.5	-8.8	39.3	-9.9	40.1	-11.3	41.2	
			WB	-7.2	27.7	1.9	0.8	-8.6	28.3	-9.7	28.8	-10.7	29.3	-12.1	29.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.4	11.2	13.3	16.3	19.8	24.1	27.1	28.0	28.0	26.2	21.4	15.8	12.7
	DBStd	7.12	5.20	4.86	4.44	3.51	2.76	1.87	1.48	1.49	2.21	4.04	4.51	5.23
	HDD10.0	116	50	21	7	0	0	0	0	0	0	0	6	32
	HDD18.3	801	227	151	89	26	2	0	0	0	0	20	102	184
	CDD10.0	3897	86	113	203	293	437	514	558	485	353	180	117	117
	CDD18.3	1538	4	8	28	69	179	264	300	299	235	114	26	11
	CDH23.3	14808	15	56	266	691	1875	2575	2999	2979	2153	977	179	43
Wind	WSAvg	6156	0	3	43	178	807	1204	1376	1327	897	298	24	1
	WSAvg	2.5	2.6	2.7	2.9	2.8	2.6	2.3	2.0	2.0	2.4	2.4	2.3	2.4
	PrecAvg	1621	123	130	156	88	111	187	214	191	146	82	92	112
	PrecMax	2646	481	292	345	334	296	442	511	400	404	300	265	321
	PrecMin	1130	9	16	6	8	0	50	60	62	3	0	14	20
	PrecStd	311	86	70	88	74	77	99	109	79	95	73	59	60
	PrecStd	311	86	70	88	74	77	99	109	79	95	73	59	60
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.0	27.0	29.8	31.7	35.2	37.1	37.0	36.5	35.2	32.4	29.1	26.2
		MCWB	19.1	19.4	18.6	20.7	22.3	24.2	25.2	25.1	24.0	22.8	21.2	20.2
	2%	DB	23.4	25.1	27.9	30.0	33.6	35.5	35.3	35.1	33.7	31.0	27.1	24.6
		MCWB	18.4	18.2	18.7	20.2	22.1	24.1	24.9	25.0	23.8	22.2	20.6	19.8
	5%	DB	21.8	23.4	26.3	28.8	32.2	34.0	34.1	33.9	32.7	29.8	25.4	22.9
		MCWB	17.6	17.7	18.3	19.6	21.9	23.8	24.8	24.9	23.6	21.6	19.4	19.5
	10%	DB	20.0	21.6	24.6	27.4	31.0	32.6	32.9	32.8	31.5	28.4	23.8	21.3
		MCWB	16.7	16.8	17.5	18.8	21.4	23.7	24.7	24.8	23.4	21.2	18.5	18.4
	0.4%	WB	21.1	21.6	22.2	23.5	25.2	26.7	27.3	27.4	26.3	25.8	24.1	22.7
		MCDB	22.8	24.0	25.5	27.1	30.6	31.7	32.2	32.4	30.5	28.7	26.3	24.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	19.9	20.4	21.2	22.6	24.4	25.8	26.6	26.8	25.7	24.7	22.7	21.4
		MCDB	21.8	23.0	24.4	26.4	29.4	30.9	31.7	31.6	30.0	28.0	24.8	23.1
	5%	WB	18.7	19.3	20.2	21.8	23.8	25.4	26.1	26.3	25.2	23.9	21.4	20.3
		MCDB	20.8	21.9	23.6	25.7	28.6	30.6	31.1	31.0	29.5	27.2	23.6	22.2
	10%	WB	17.4	18.1	19.2	20.9	23.1	24.9	25.6	25.7	24.7	23.0	20.0	19.0
		MCDB	19.5	20.5	22.8	25.0	27.7	29.9	30.5	30.2	28.8	26.1	22.8	20.9
Mean Daily Temperature Range	5% DB	MDBR	13.0	13.2	13.8	13.8	13.1	10.7	10.2	9.8	10.2	12.3	13.3	12.3
		MCDBR	13.2	14.0	14.9	14.7	14.4	12.9	11.9	11.5	11.8	12.6	13.5	11.8
		MCWBR	8.8	8.4	7.5	6.4	5.2	4.0	3.7	3.6	3.8	5.4	7.5	7.9
	5% WB	MCDBR	10.4	10.8	11.1	11.4	11.7	10.7	10.3	9.9	9.4	9.0	9.7	9.6
		MCWBR	7.9	7.7	6.7	6.2	4.8	4.0	3.8	3.6	3.5	4.6	6.4	7.4
Clear-Sky Solar Irradiance	taub		0.332	0.340	0.358	0.387	0.443	0.494	0.506	0.492	0.431	0.379	0.350	0.336
	taud		2.522	2.502	2.462	2.372	2.244	2.157	2.141	2.185	2.341	2.465	2.484	2.532
	Ebn at Noon		901	925	928	906	853	805	794	802	842	870	871	877
	Edh at Noon		88	97	108	123	140	152	154	146	121	100	90	83
	RadAvg		3.14	3.72	4.94	5.96	6.49	5.90	5.77	5.33	4.93	4.41	3.52	2.77
All-Sky Solar Radiation	RadStd		0.23	0.46	0.40	0.47	0.42	0.47	0.42	0.40	0.39	0.39	0.26	0.25

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.52	+0.82	N/A	N/A	N/A	N/A	-22	-82	+173	+122
Regional (25 neighbors)		+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+160	+102

Nomenclature: See separate page