

SOUTHWEST GEORGIA, GA, USA

WMO: 722160

Lat: 31.536N

Lon: 84.194W

Elev: 190

StdP: 14.60

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 13869

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.5	29.5	10.4	9.4	37.0	15.6	12.2	39.2	21.6	57.0	19.2	56.2	3.4	310	0.385

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.0	96.7	76.0	94.8	75.8	92.9	75.6	79.8	90.4	78.7	89.0	78.0	88.0	7.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.2	142.6	83.2	76.2	137.7	82.4	75.3	133.4	81.7	43.3	90.1	42.2	89.2	41.4	88.1	89.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.3	16.3	14.0	DB	19.8	99.5	3.6	2.8	17.2	101.5	15.1	103.2	13.0	104.7	10.4	106.7
			WB	17.8	82.2	3.6	2.4	15.2	84.0	13.1	85.4	11.1	86.8	8.5	88.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.5	50.2	54.0	60.1	66.8	75.0	80.6	82.5	82.1	78.1	68.8	58.7	52.8
	DBStd	13.50	9.78	8.98	8.23	6.49	5.43	3.74	2.68	2.93	4.56	7.31	8.17	9.41
	HDD50	293	122	56	17	1	0	0	0	0	1	18	78	78
	HDD65	1701	467	321	193	57	4	0	0	0	1	47	222	389
	CDD50	6694	127	166	329	505	775	918	1008	994	843	584	279	166
	CDD65	2630	7	12	40	111	315	468	543	529	394	166	33	12
	CDH74	25436	28	81	383	1109	3190	4680	5561	5238	3502	1374	229	61
	CDH80	11148	1	6	61	298	1385	2279	2707	2440	1529	408	31	3
(14) Wind	WSAvg	5.8	6.4	6.4	6.7	6.4	5.9	5.5	5.0	4.9	5.7	5.5	5.5	5.8
(15) Precipitation	PrecAvg	46.9	4.9	4.4	5.0	3.4	3.4	4.8	5.4	4.3	3.5	2.0	3.0	3.5
	PrecMax	64.4	11.3	8.7	10.4	8.3	10.4	11.3	9.4	11.1	12.4	7.8	8.4	8.6
	PrecMin	31.1	1.0	0.9	0.3	0.3	0.1	0.9	0.9	0.8	0.7	0.0	0.2	0.8
	PrecStd	8.2	2.4	2.0	2.6	2.2	2.1	2.3	2.2	2.5	2.4	1.9	2.1	1.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.2	80.6	84.9	89.1	95.8	99.3	98.5	98.5	96.4	90.9	83.7	79.1
		MCWB	65.4	66.9	65.7	69.2	72.9	75.7	77.0	77.1	74.5	74.2	69.8	67.3
	2%	DB	73.4	76.5	81.6	86.3	92.4	96.6	95.8	95.3	93.0	87.3	79.8	75.3
		MCWB	63.9	64.2	65.8	68.1	72.0	75.2	76.6	77.3	74.2	70.7	66.7	65.9
	5%	DB	69.8	72.8	78.7	83.6	90.3	93.8	93.9	93.2	90.8	84.3	76.3	71.8
		MCWB	62.4	62.3	63.9	67.0	71.0	74.9	76.8	76.9	74.0	69.6	64.7	65.0
	10%	DB	66.1	69.3	75.0	81.0	87.8	91.0	91.7	91.0	88.6	81.7	73.0	68.1
		MCWB	60.6	60.5	62.1	65.6	70.3	74.7	76.5	76.4	73.5	68.7	64.0	63.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.8	69.4	70.5	73.2	77.0	80.2	81.3	81.4	78.8	77.2	73.2	70.9
		MCDB	72.9	76.1	77.4	82.5	88.3	92.2	91.2	91.1	88.0	84.0	77.8	74.9
	2%	WB	66.4	67.4	68.7	71.4	75.2	78.4	79.7	80.0	77.5	75.2	70.8	68.7
		MCDB	70.6	73.1	75.6	80.4	85.2	89.6	90.7	90.0	86.7	81.8	75.3	72.4
	5%	WB	64.2	65.1	66.8	69.9	74.0	77.5	78.6	78.8	76.6	73.5	68.6	66.4
		MCDB	68.0	70.5	74.6	78.5	83.9	88.3	89.3	88.6	85.4	80.1	73.6	70.3
	10%	WB	61.7	62.8	64.9	68.4	72.7	76.5	77.9	78.0	75.6	71.9	66.1	63.9
		MCDB	66.2	67.4	72.5	76.5	82.7	86.3	88.2	87.3	83.8	78.4	71.3	67.5
(35) Mean Daily Temperature Range	5% DB	MDBR	22.1	22.4	23.4	23.8	22.8	19.7	19.0	18.3	19.2	22.2	23.4	21.2
		MCDBR	23.7	24.7	26.0	26.2	24.9	23.6	21.5	21.0	22.2	23.4	24.8	22.4
	5% WB	MCWBR	15.2	14.5	12.5	10.7	8.1	6.8	6.5	6.4	7.2	9.8	13.4	14.3
		MCWBR	19.9	20.4	21.1	20.7	20.4	19.5	19.1	18.6	17.8	17.5	18.4	18.6
(40) Clear-Sky Solar Irradiance	taub		0.326	0.331	0.354	0.385	0.431	0.477	0.511	0.502	0.425	0.375	0.351	0.331
		taud	2.506	2.485	2.439	2.351	2.258	2.192	2.107	2.130	2.331	2.443	2.455	2.509
	Ebn at Noon		286	295	294	287	273	259	250	251	268	276	273	277
		Edh at Noon	28	31	35	40	44	47	50	49	38	32	29	26
(44) All-Sky Solar Radiation	RadAvg		954	1135	1506	1859	2047	1952	1941	1769	1577	1357	1066	828
	RadStd		57	129	127	145	141	137	109	114	132	135	84	80

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.97	N/A	N/A	N/A	N/A	N/A	N/A	+293	+221
(47) Regional (31 neighbors)		+0.83	N/A	N/A	N/A	N/A	N/A	N/A	+288	+184

Nomenclature: See separate page