

SOUTHWEST GEORGIA, GA, USA

WMO: 722160

Lat: 31.536N

Lon: 84.194W

Elev: 58

StdP: 100.63

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 13869

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.0	(c) -1.4	(d) -12.0	(e) 1.3	(f) 2.8	(g) -9.1	(h) 1.7	(i) 4.0	(j) 9.6	(k) 13.9	(l) 8.6	(m) 13.5	(n) 1.5	(o) 310	(p) 0.385

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	36.0	24.4	34.9	24.4	33.8	24.2	26.6	32.4	26.0	31.7	25.6	31.1	3.4	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.1	20.4	28.4	24.5	19.7	28.0	24.0	19.1	27.6	82.9	32.3	80.4	31.8	78.5	31.2	32.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.2	(b) 7.3	(c) 6.2	(e) -6.8	(f) 37.5	(g) 2.0	(h) 1.5	(i) -8.2	(j) 38.6	(k) -9.4	(l) 39.5	(m) -10.5	(n) 40.4	(o) -12.0	(p) 41.5		
(a) 8.2	(b) 7.3	(c) 6.2	(e) -7.9	(f) 27.9	(g) 2.0	(h) 1.4	(i) -9.3	(j) 28.9	(k) -10.5	(l) 29.7	(m) -11.6	(n) 30.4	(o) -13.1	(p) 31.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.7	10.1	12.2	15.6	19.3	23.9	27.0	28.1	27.8	25.6	20.5	14.8	11.6		
	DBStd	7.50	5.44	4.99	4.57	3.61	3.01	2.08	1.49	1.63	2.53	4.06	4.54	5.23		
	HDD10.0	163	68	31	9	1	0	0	0	0	0	1	10	43		
	HDD18.3	945	259	178	107	32	2	0	0	0	1	26	123	216		
	CDD10.0	3719	71	92	183	281	431	510	560	552	468	324	155	92		
	CDD18.3	1461	4	7	22	62	175	260	302	294	219	92	18	7		
	CDH23.3	14131	16	45	213	616	1772	2600	3089	2910	1946	763	127	34		
	CDH26.7	6193	1	3	34	166	769	1266	1504	1356	849	227	17	2		
(14) Wind	WSAvg	2.6	2.8	2.9	3.0	2.9	2.6	2.5	2.2	2.2	2.5	2.5	2.4	2.6		
(15) Precipitation	PrecAvg	1191	125	111	126	86	87	121	136	108	90	52	76	89		
	PrecMax	1635	288	222	264	212	265	287	239	283	315	199	213	219		
	PrecMin	790	25	23	7	7	2	24	23	20	17	0	6	20		
	PrecStd	209	62	50	67	56	53	58	55	63	61	48	53	46		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.1	27.0	29.4	31.7	35.4	37.4	37.0	36.9	35.8	32.7	28.7	26.2		
		MCWB	18.6	19.4	18.7	20.7	22.7	24.3	25.0	25.1	23.6	23.5	21.0	19.6		
	2%	DB	23.0	24.7	27.5	30.1	33.6	35.9	35.5	35.2	33.9	30.7	26.5	24.1		
		MCWB	17.7	17.9	18.8	20.1	22.2	24.0	24.8	25.1	23.5	21.5	19.3	18.9		
	5%	DB	21.0	22.7	25.9	28.7	32.4	34.3	34.4	34.0	32.7	29.1	24.6	22.1		
		MCWB	16.9	16.8	17.7	19.4	21.7	23.8	24.9	24.9	23.4	20.9	18.2	18.4		
	10%	DB	18.9	20.7	23.9	27.2	31.0	32.8	33.2	32.8	31.4	27.6	22.8	20.1		
		MCWB	15.9	15.8	16.7	18.6	21.3	23.7	24.7	24.7	23.1	20.4	17.8	17.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.5	20.8	21.4	22.9	25.0	26.8	27.4	27.4	26.0	25.1	22.9	21.6		
		MCDB	22.7	24.5	25.2	28.0	31.3	33.5	32.9	32.8	31.1	28.9	25.4	23.9		
	2%	WB	19.1	19.7	20.4	21.9	24.0	25.8	26.5	26.7	25.3	24.0	21.5	20.4		
		MCDB	21.5	22.8	24.2	26.9	29.6	32.0	32.6	32.2	30.4	27.7	24.0	22.4		
	5%	WB	17.9	18.4	19.3	21.1	23.3	25.3	25.9	26.0	24.8	23.0	20.3	19.1		
		MCDB	20.0	21.4	23.7	25.9	28.8	31.3	31.8	31.4	29.6	26.7	23.1	21.3		
	10%	WB	16.5	17.1	18.3	20.2	22.6	24.7	25.5	25.6	24.2	22.2	18.9	17.7		
		MCDB	19.0	19.7	22.5	24.7	28.2	30.2	31.2	30.7	28.8	25.8	21.8	19.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.3	12.4	13.0	13.2	12.7	10.9	10.5	10.2	10.7	12.3	13.0	11.8		
		MCDBR	13.2	13.7	14.4	14.6	13.8	13.1	11.9	11.7	12.3	13.0	13.8	12.4		
		MCWBR	8.5	8.1	7.0	5.9	4.5	3.8	3.6	3.6	4.0	5.4	7.4	7.9		
		MCDBR	11.0	11.3	11.7	11.5	11.3	10.8	10.6	10.3	9.9	9.7	10.2	10.4		
	5% WB	MCWBR	8.2	7.9	6.8	6.0	4.5	3.9	3.8	3.7	3.7	4.8	6.6	7.8		
(40) Clear-Sky Solar Irradiance	taub		0.326	0.331	0.354	0.385	0.431	0.477	0.511	0.502	0.425	0.375	0.351	0.331		
	taud		2.506	2.485	2.439	2.351	2.258	2.192	2.107	2.130	2.331	2.443	2.455	2.509		
	Ebn at Noon		901	930	928	906	862	818	789	791	845	869	862	874		
	Edh at Noon		87	98	110	125	138	147	159	154	121	101	91	83		
(44) All-Sky Solar Radiation	RadAvg		3.01	3.58	4.75	5.86	6.45	6.16	6.12	5.58	4.97	4.28	3.36	2.61		
	RadStd		0.18	0.41	0.40	0.46	0.45	0.43	0.34	0.36	0.42	0.43	0.27	0.25		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+163	+123
(47) Regional (31 neighbors)		+0.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+160	+102

Nomenclature: See separate page