

VALDOSTA, GA, USA

WMO: 722166

Lat: 30.783N

Lon: 83.277W

Elev: 60

StdP: 100.60

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 93845

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.4	-0.8	-10.8	1.5	3.2	-7.9	1.9	4.8	8.3	14.8	7.5	13.1	1.0	0	0.347

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	35.8	24.8	34.7	24.6	33.7	24.4	26.8	32.1	26.3	31.5	25.8	30.8	2.3	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.6	21.0	28.4	25.0	20.3	28.0	24.5	19.6	27.7	83.9	32.0	81.6	31.3	79.6	31.1	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
7.1	5.8	5.2	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-5.7	37.3	1.8	1.5	-6.9	38.3	-8.0	39.2	-9.0	40.1	-10.2	41.1
			-6.7	27.9	1.9	0.9	-8.1	28.5	-9.2	29.1	-10.3	29.6	-11.6	30.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.2	11.1	13.3	16.3	19.6	23.8	26.9	27.9	27.8	25.7	20.9	15.6	12.8
	DBStd	7.04	5.27	4.97	4.51	3.53	2.75	1.88	1.46	1.52	2.19	3.86	4.46	5.26
	HDD10.0	120	52	22	7	1	0	0	0	0	0	0	7	32
	HDD18.3	809	229	151	92	27	2	0	0	0	0	21	105	182
	CDD10.0	3831	86	114	202	289	428	506	554	551	469	339	174	119
	CDD18.3	1479	4	10	28	66	172	256	296	293	220	102	23	11
	CDH23.3	13902	26	73	265	683	1737	2461	2970	2828	1859	787	158	56
Wind	WSAvg	5991	1	6	46	198	749	1192	1447	1321	784	224	19	3
	WSAvg	2.0	2.2	2.3	2.3	2.2	2.1	1.8	1.6	1.7	2.1	2.0	2.1	2.1
	PrecAvg	1228	105	101	110	101	78	143	143	130	105	70	57	82
	PrecMax	1838	515	214	292	244	166	317	227	215	356	297	152	143
	PrecMin	907	21	18	2	16	12	33	71	33	31	0	0	36
	PrecStd	240	95	44	73	57	37	79	45	43	83	66	41	28
	PrecStd	240	95	44	73	57	37	79	45	43	83	66	41	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.0	27.6	29.8	32.2	35.3	37.4	37.2	37.3	35.1	32.1	28.8	27.1
		MCWB	19.3	19.2	19.2	21.1	22.9	24.6	25.6	25.6	23.6	23.1	21.6	20.4
	2%	DB	23.8	25.8	27.9	30.4	33.4	35.5	35.4	35.2	33.5	30.5	27.1	24.9
		MCWB	18.2	18.7	18.8	20.2	22.3	24.4	25.1	25.4	23.7	22.2	20.4	19.4
	5%	DB	22.1	23.7	26.3	29.0	32.3	34.0	34.3	33.9	32.4	29.1	25.2	23.0
		MCWB	17.2	17.6	18.0	19.6	21.7	24.0	25.1	25.2	23.6	21.7	18.9	18.9
	10%	DB	19.8	21.8	24.6	27.5	31.0	32.6	33.1	32.7	31.2	27.7	23.4	21.3
		MCWB	16.4	16.4	17.4	19.0	21.5	24.0	24.9	25.0	23.5	21.0	18.6	18.2
	0.4%	WB	20.8	21.2	22.0	23.1	25.1	26.9	27.7	27.5	26.3	25.2	23.8	22.5
		MCDB	23.3	24.7	25.7	27.8	30.9	32.6	32.9	32.8	29.8	28.7	26.4	24.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	19.6	20.1	20.9	22.2	24.2	26.1	26.9	26.8	25.6	24.3	22.5	21.2
		MCDB	22.3	23.4	24.7	27.0	29.1	31.7	32.2	32.1	29.7	27.9	24.7	23.2
	5%	WB	18.4	19.1	19.9	21.4	23.5	25.5	26.3	26.2	25.1	23.5	21.1	19.9
		MCDB	20.9	22.3	23.8	26.0	28.6	31.0	31.6	31.4	29.4	26.8	23.5	22.3
	10%	WB	17.1	17.9	18.9	20.6	22.9	25.0	25.7	25.7	24.6	22.7	19.7	18.6
		MCDB	19.2	20.6	22.8	25.1	28.0	30.2	30.9	30.6	28.7	25.8	22.6	21.0
Mean Daily Temperature Range	5% DB	MDBR	12.5	12.8	13.5	13.8	13.2	11.4	10.9	10.4	10.5	12.2	13.1	12.1
		MCDBR	13.7	13.8	14.9	15.1	14.6	13.5	12.3	11.9	12.4	12.5	13.5	12.6
		MCWBR	8.5	7.7	7.0	6.2	5.1	4.4	4.1	3.9	4.4	5.6	7.2	7.7
	5% WB	MCDBR	11.4	11.2	11.7	12.0	11.9	11.1	11.0	10.7	9.7	9.5	10.0	10.3
		MCWBR	8.2	7.2	6.6	6.2	4.8	4.3	4.2	4.0	3.9	4.7	6.4	7.2
Clear-Sky Solar Irradiance	taub		0.327	0.335	0.359	0.387	0.425	0.471	0.508	0.492	0.432	0.378	0.348	0.332
	taud		2.519	2.495	2.449	2.357	2.291	2.226	2.126	2.172	2.330	2.455	2.483	2.532
	Ebn at Noon		905	929	925	906	868	824	792	801	841	869	872	880
	Edh at Noon		87	98	109	124	134	142	157	148	122	101	90	83
All-Sky Solar Radiation	RadAvg		3.11	3.70	4.87	5.91	6.46	5.97	5.98	5.42	4.90	4.32	3.46	2.73
	RadStd		0.21	0.44	0.41	0.45	0.40	0.40	0.36	0.36	0.40	0.38	0.24	0.24

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+64
(47)	Regional (30 neighbors)	+0.51	+0.80	N/A	N/A	N/A	N/A	N/A	-22	-81	+170	+118

Nomenclature: See separate page