

PECOS, TX, USA

WMO: 722169

Lat: 31.383N

Lon: 103.511W

Elev: 2613

StdP: 13.36

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 03058

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.5	25.4	0.3	6.1	43.1	3.6	7.3	44.7	31.7	62.7	27.5	63.1	4.4	270	0.494

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.4	105.8	66.2	103.4	66.8	100.8	66.6	73.0	87.6	71.9	87.6	71.1	87.4	9.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.1	122.0	76.6	68.3	114.6	76.1	66.8	108.6	76.1	38.3	86.7	37.4	86.9	36.6	86.8	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
26.3	22.6	19.0	14.2	109.3	4.9	2.1	10.7	110.8	7.9	112.1	5.1	113.2	1.6	114.8		
			12.3	74.0	4.7	1.6	8.9	75.1	6.2	76.1	3.5	77.0	0.1	78.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.4	46.5	51.3	59.2	67.2	74.8	83.9	84.6	83.7	76.7	66.6	54.6	47.0
	DBStd	15.59	8.19	9.10	8.26	7.27	7.15	4.55	4.36	4.61	5.72	7.96	7.95	8.27
	HDD50	478	165	83	23	2	0	0	0	0	0	3	46	156
	HDD65	2201	574	386	211	60	15	0	0	0	3	76	318	558
	CDD50	6471	56	121	306	518	768	1018	1071	1044	802	519	184	64
	CDD65	2718	0	3	30	126	318	568	607	579	354	126	6	1
	CDH74	38236	74	282	1060	2436	4673	8059	8127	7377	3956	1744	360	88
	CDH80	21981	6	71	407	1220	2741	5141	4977	4447	2090	775	97	9
Wind	WSAvg	7.5	6.8	7.7	8.1	9.4	8.9	8.9	8.2	6.9	6.7	6.3	6.1	6.6
Precipitation	PrecAvg	11.3	0.4	0.4	0.4	0.4	1.1	1.2	1.3	1.6	2.1	1.1	0.5	0.6
	PrecMax	22.6	1.7	2.0	2.0	3.6	7.4	4.1	4.1	7.4	7.8	4.8	2.7	3.8
	PrecMin	4.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.0	0.0
	PrecStd	4.4	0.4	0.6	0.5	0.6	1.3	1.1	1.2	1.5	2.0	1.2	0.6	0.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.8	87.3	92.6	98.5	106.0	109.7	106.7	106.7	101.7	96.1	88.2	81.4
		MCWB	52.1	55.6	57.4	58.7	62.7	65.0	67.5	68.7	65.8	64.4	58.3	53.6
	2%	DB	75.4	81.7	88.7	94.7	101.5	106.4	104.1	103.8	97.5	92.1	82.4	76.4
		MCWB	50.4	52.8	55.7	57.9	61.6	65.1	68.2	68.4	66.2	63.7	56.3	52.1
	5%	DB	71.3	77.3	84.4	91.4	98.6	103.8	101.7	101.2	94.9	88.6	78.2	70.5
		MCWB	49.6	52.1	55.0	57.2	61.2	65.6	68.4	68.6	66.6	62.5	54.9	50.3
	10%	DB	64.5	72.0	80.8	88.0	94.6	100.3	99.2	98.2	91.4	84.2	73.1	64.2
		MCWB	46.3	49.5	53.7	56.7	60.5	65.5	68.4	68.7	66.5	61.3	53.3	47.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.8	58.1	62.7	65.8	70.7	73.0	74.9	74.1	73.1	71.2	62.4	56.9
		MCDB	71.6	78.5	78.0	78.6	86.6	91.5	86.9	87.6	86.1	84.6	72.9	71.4
	2%	WB	52.6	55.1	60.0	63.2	68.7	71.5	73.0	72.8	71.5	68.9	59.4	53.5
		MCDB	70.4	75.2	75.8	77.7	83.4	89.1	86.6	87.9	85.3	82.2	74.6	72.5
	5%	WB	50.3	53.1	57.7	61.2	67.1	70.5	71.7	71.8	70.5	67.1	57.3	51.0
		MCDB	67.5	73.1	75.9	78.3	82.1	88.5	87.7	87.8	83.9	80.0	74.0	68.8
	10%	WB	47.8	50.7	55.5	59.3	65.5	69.4	70.8	70.9	69.3	65.0	55.0	48.5
		MCDB	64.0	70.1	75.8	79.0	81.2	87.7	88.0	87.6	82.4	77.4	70.5	63.5
Mean Daily Temperature Range	5% DB	MDBR	30.6	32.1	34.0	34.6	31.9	30.5	26.4	26.5	25.9	29.3	31.6	28.7
		MCDBR	41.1	42.3	42.8	41.2	39.8	36.3	30.8	30.5	32.1	35.7	40.6	39.4
		MCWBR	21.3	20.8	19.2	17.4	14.9	10.1	8.0	7.4	9.4	13.2	19.3	20.2
	5% WB	MCDBR	36.6	37.9	35.8	32.8	30.3	28.5	24.6	25.1	23.7	26.3	34.4	35.7
		MCWBR	19.8	19.2	16.5	13.7	13.1	8.1	6.6	6.5	7.3	10.1	17.1	19.0
Clear-Sky Solar Irradiance	taub	0.262	0.270	0.289	0.323	0.344	0.373	0.394	0.370	0.353	0.304	0.283	0.265	
	taud	2.599	2.571	2.516	2.401	2.399	2.376	2.359	2.421	2.434	2.568	2.555	2.582	
	Ebn at Noon	312	318	317	306	298	288	282	288	291	301	301	305	
	Edh at Noon	25	28	32	38	38	39	39	36	35	28	26	24	
All-Sky Solar Radiation	RadAvg	1129	1415	1818	2201	2341	2390	2265	2104	1793	1495	1194	1022	
	RadStd	104	136	121	131	139	114	102	102	116	143	109	87	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page