

PECOS, TX, USA

WMO: 722169

Lat: 31.383N

Lon: 103.511W

Elev: 796

StdP: 92.12

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 03058

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.9	-3.7	-17.6	0.9	6.1	-15.8	1.0	7.1	14.2	17.1	12.3	17.3	2.0	270	0.494

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.6	41.0	19.0	39.7	19.3	38.2	19.2	22.8	30.9	22.2	30.9	21.7	30.8	4.2	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.1	17.4	24.8	20.2	16.4	24.5	19.3	15.5	24.5	71.2	30.4	69.1	30.5	67.2	30.4	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.8	10.1	8.5	-9.9	43.0	2.7	1.2	-11.8	43.8	-13.4	44.5	-14.9	45.1	-16.9	46.0		
			-10.9	23.3	2.6	0.9	-12.8	24.0	-14.3	24.5	-15.8	25.0	-17.7	25.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	19.1	8.1	10.7	15.1	19.6	23.8	28.8	29.2	28.7	24.8	19.2	12.6	8.3	(6)
(7)		DBStd	8.66	4.55	5.06	4.59	4.04	3.97	2.53	2.42	2.56	3.18	4.42	4.42	4.59	(7)
(8)		HDD10.0	266	92	46	13	1	0	0	0	0	2	26	87		(8)
(9)		HDD18.3	1223	319	214	117	33	8	0	0	2	42	177	310		(9)
(10)		CDD10.0	3595	31	67	170	288	427	566	595	580	446	288	102	36	(10)
(11)		CDD18.3	1510	0	2	17	70	177	316	337	322	197	70	3	1	(11)
(12)		CDH23.3	21242	41	157	589	1353	2596	4477	4515	4098	2198	969	200	49	(12)
(13)		CDH26.7	12212	3	39	226	678	1523	2856	2765	2471	1161	431	54	5	(13)
(14)	Wind	WSAvg	3.4	3.0	3.4	3.6	4.2	4.0	3.7	3.1	3.0	2.8	2.7	2.9	(14)	
(15)	Precipitation	PrecAvg	286	10	11	9	11	27	31	34	40	54	28	12	15	(15)
(16)		PrecMax	573	42	52	52	92	189	104	103	188	197	121	68	96	(16)
(17)		PrecMin	125	0	0	0	0	0	1	0	0	6	0	0	0	(17)
(18)		PrecStd	113	10	15	13	16	32	27	30	39	50	31	15	20	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.1	30.7	33.7	37.0	41.1	43.2	41.5	41.5	38.7	35.6	31.2	27.5	(19)
(20)		MCWB	11.2	13.1	14.1	14.8	17.1	18.3	19.7	20.4	18.8	18.0	14.6	12.0		(20)
(21)		2%	DB	24.1	27.6	31.5	34.8	38.6	41.3	40.1	39.9	36.4	33.4	28.0	24.7	(21)
(22)		MCWB	10.2	11.5	13.1	14.4	16.4	18.4	20.1	20.2	19.0	17.6	13.5	11.1		(22)
(23)		5%	DB	21.8	25.1	29.1	33.0	37.0	39.9	38.7	38.4	34.9	31.4	25.7	21.4	(23)
(24)		MCWB	9.8	11.2	12.8	14.0	16.2	18.7	20.2	20.4	19.2	16.9	12.7	10.2		(24)
(25)		10%	DB	18.0	22.2	27.1	31.1	34.8	38.0	37.3	36.8	33.0	29.0	22.8	17.9	(25)
(26)		MCWB	7.9	9.7	12.1	13.7	15.9	18.6	20.2	20.4	19.2	16.3	11.8	8.6		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.2	14.5	17.0	18.8	21.5	22.8	23.9	23.4	22.8	21.8	16.9	13.8	(27)
(28)		MADB	22.0	25.9	25.6	25.9	30.3	33.0	30.5	30.9	30.1	29.2	22.7	21.9		(28)
(29)		2%	WB	11.4	12.8	15.5	17.3	20.4	21.9	22.8	22.7	21.9	20.5	15.2	11.9	(29)
(30)		MADB	21.3	24.0	24.3	25.4	28.5	31.7	30.3	31.1	29.6	27.9	23.7	22.5		(30)
(31)		5%	WB	10.2	11.7	14.3	16.2	19.5	21.4	22.0	22.1	21.4	19.5	14.0	10.6	(31)
(32)		MADB	19.7	22.8	24.4	25.7	27.9	31.4	30.9	31.0	28.8	26.7	23.3	20.4		(32)
(33)		10%	WB	8.8	10.4	13.1	15.2	18.6	20.8	21.5	21.6	20.7	18.3	12.8	9.1	(33)
(34)		MADB	17.8	21.2	24.3	26.1	27.3	30.9	31.1	30.9	28.0	25.2	21.4	17.5		(34)
(35)	Mean Daily Temperature Range	MDBR	17.0	17.9	18.9	19.2	17.7	17.0	14.6	14.7	14.4	16.3	17.6	15.9	(35)	
(36)		5% DB	MADB	22.8	23.5	23.8	22.9	22.1	20.2	17.1	16.9	17.8	19.8	22.6	21.9	(36)
(37)		MCWBR	11.8	11.5	10.7	9.7	8.3	5.6	4.5	4.1	5.2	7.3	10.7	11.2	(37)	
(38)		5% WB	MADB	20.3	21.0	19.9	18.2	16.8	15.9	13.7	13.9	13.2	14.6	19.1	19.8	(38)
(39)	MCWBR	11.0	10.7	9.2	7.6	7.3	4.5	3.7	3.6	4.0	5.6	9.5	10.6	(39)		
(40)	Clear-Sky Solar Irradiance	taub	0.262	0.270	0.289	0.323	0.344	0.373	0.394	0.370	0.353	0.304	0.283	0.265	(40)	
(41)		taud	2.599	2.571	2.516	2.401	2.399	2.376	2.359	2.421	2.434	2.568	2.555	2.582	(41)	
(42)		Ebn at Noon	985	1003	999	966	941	909	888	909	916	949	948	962	(42)	
(43)		Edh at Noon	78	89	101	119	120	122	124	115	109	88	81	76	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.56	4.46	5.73	6.94	7.38	7.54	7.14	6.63	5.65	4.71	3.76	3.22	(44)	
(45)		RadStd	0.33	0.43	0.38	0.41	0.44	0.36	0.32	0.32	0.36	0.45	0.34	0.27	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page