

MIDDLE GEORGIA, GA, USA

WMO: 722170

Lat: 32.685N

Lon: 83.653W

Elev: 343

StdP: 14.51

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 03813

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.7	27.2	7.9	8.3	35.5	12.6	10.6	36.5	21.0	51.2	19.6	50.1	4.7	300	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.3	96.7	75.1	94.5	75.0	92.5	74.8	78.9	89.8	78.0	88.6	77.2	87.3	7.6	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.1	138.2	82.7	75.2	134.0	81.8	74.4	130.1	81.0	42.5	90.1	41.5	89.0	40.6	87.3	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.4	16.2	13.6	17.4	99.6	3.2	3.3	15.1	101.9	13.2	103.9	11.3	105.7	9.0	108.1
			15.6	81.0	3.5	1.6	13.1	82.1	11.1	83.0	9.2	83.9	6.7	85.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.9	46.9	50.8	57.2	64.1	72.3	78.9	81.6	80.8	75.6	65.5	55.3	49.3	(6)
	DBStd	14.13	9.54	8.82	8.23	6.70	5.77	3.92	3.04	3.38	5.11	7.47	8.08	8.89	(7)
	HDD50	463	178	91	30	2	0	0	0	0	0	2	36	124	(8)
	HDD65	2223	564	403	262	96	13	0	0	0	3	86	307	489	(9)
	CDD50	5909	80	112	252	426	691	868	979	955	767	481	194	104	(10)
	CDD65	2196	2	4	20	70	240	418	514	490	319	100	15	4	(11)
	CDH74	21473	5	25	221	792	2504	4079	5257	4765	2787	895	127	16	(12)
	CDH80	9557	0	0	29	187	1017	1963	2619	2286	1203	239	14	0	(13)
(14) Wind	WSAvg	5.6	6.5	6.6	6.8	6.2	5.6	5.1	4.7	4.4	5.1	5.2	5.3	5.8	(14)
(15) Precipitation	PrecAvg	45.4	4.4	4.5	4.6	3.4	3.1	4.0	4.6	3.9	3.3	2.3	3.0	4.3	(15)
	PrecMax	73.0	11.3	12.9	11.9	8.4	8.3	12.2	18.1	10.2	12.7	7.2	10.3	12.6	(16)
	PrecMin	32.4	1.0	0.4	0.4	0.1	0.0	0.9	0.4	1.1	0.4	0.0	0.5	0.6	(17)
	PrecStd	8.1	2.2	2.4	2.7	2.1	1.8	2.1	3.0	2.1	2.6	2.0	1.9	2.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.3	77.4	83.5	87.5	94.9	98.3	98.6	99.1	96.3	89.4	82.2	76.2	(19)
		MCWB	63.6	64.1	64.3	68.2	71.6	74.5	75.5	76.5	73.3	71.8	67.4	65.3	(20)
	2%	DB	70.5	73.5	79.5	84.7	91.2	95.3	96.3	96.0	92.8	85.4	77.6	72.4	(21)
		MCWB	61.4	61.5	63.5	66.5	70.9	74.2	75.7	76.0	73.0	69.5	64.2	63.7	(22)
	5%	DB	67.1	70.0	76.2	82.1	88.6	92.8	94.1	93.3	89.9	82.5	74.2	68.7	(23)
		MCWB	59.8	59.8	61.7	65.8	70.2	74.1	75.8	76.0	72.8	68.1	63.0	62.1	(24)
	10%	DB	63.3	66.4	72.6	79.0	86.0	90.2	91.9	90.8	87.2	79.3	70.4	65.0	(25)
		MCWB	57.7	57.7	59.9	64.2	69.3	73.8	75.8	75.6	72.6	66.7	61.6	59.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.7	67.5	68.9	72.3	76.2	79.0	80.3	80.3	77.6	76.1	71.4	68.7	(27)
		MCDB	70.7	72.5	76.6	81.6	86.5	89.9	91.6	92.0	86.4	82.2	75.9	72.0	(28)
	2%	WB	64.2	64.9	66.5	70.3	74.3	77.7	78.9	78.9	76.5	73.7	68.7	66.1	(29)
		MCDB	68.2	70.6	73.9	79.3	84.4	89.2	90.1	89.7	85.3	80.6	73.3	69.9	(30)
	5%	WB	61.8	62.5	64.7	68.7	72.9	76.7	78.0	78.0	75.6	71.9	66.1	63.7	(31)
		MCDB	66.0	67.7	72.3	77.0	83.1	87.6	88.9	88.2	84.1	77.8	71.4	67.7	(32)
	10%	WB	58.6	59.9	62.7	66.9	71.5	75.6	77.1	77.1	74.6	70.0	63.5	60.4	(33)
		MCDB	62.6	64.9	69.9	75.0	81.3	85.5	87.5	86.8	82.5	75.8	69.0	64.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	22.0	22.5	23.9	24.9	24.1	21.1	20.3	19.9	21.1	23.9	24.8	21.8	(35)
		MCDBR	24.6	25.2	27.5	28.1	26.9	25.0	23.5	23.4	25.2	26.4	27.6	24.1	(36)
	5% WB	MCWBR	16.5	15.2	13.8	12.3	9.6	7.8	6.9	7.1	8.8	12.0	15.2	16.1	(37)
		MCWBR	19.9	20.3	21.9	21.6	21.6	20.5	20.1	19.6	19.7	19.0	20.4	19.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.325	0.327	0.355	0.388	0.438	0.479	0.522	0.521	0.426	0.379	0.349	0.325	(40)
		taud	2.509	2.495	2.441	2.339	2.238	2.182	2.070	2.064	2.318	2.426	2.460	2.524	(41)
	Ebn at Noon		284	295	293	286	271	259	247	245	267	272	272	277	(42)
		Edh at Noon	27	30	35	40	45	47	52	52	39	32	29	26	(43)
(44) All-Sky Solar Radiation	RadAvg		907	1094	1437	1794	1981	1965	1919	1737	1527	1310	1004	779	(44)
	RadStd		46	122	115	124	151	146	106	89	143	149	84	78	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	+0.86	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+277	+182
(47)	Regional (40 neighbors)	+0.94	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+322	+223

Nomenclature: See separate page