

NEWMAN COWETA COUNTY AP, GA, USA

WMO: 722176

Lat: 33.312N

Lon: 84.770W

Elev: 970

StdP: 14.19

Time Zone: -5.00 (NAE)

Period: 99-19

WBAN: 53884

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.1	21.3	7.1	8.2	29.8	11.6	10.3	32.3	18.0	43.5	16.2	44.8	1.8	0	0.350

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.1	93.0	75.7	91.0	75.6	89.7	75.4	79.7	87.2	78.5	86.0	77.7	85.2	4.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.5	148.2	83.0	76.6	144.0	82.3	75.3	137.6	81.1	43.9	86.7	42.7	86.4	41.8	85.2	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.6	12.0	10.5	10.0	95.5	10.8	3.0	2.3	97.6	-4.0	99.4	-10.1	101.0	-17.9	103.2
			11.4	81.1	3.7	1.2	8.7	82.0	6.5	82.7	4.4	83.3	1.7	84.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.4	42.0	46.8	53.3	61.1	68.4	75.4	77.7	77.6	72.9	62.1	52.3	46.0
	DBStd	14.63	9.83	9.62	9.40	7.37	6.36	4.33	3.77	3.86	5.94	8.43	8.11	9.67
	HDD50	811	287	166	74	8	0	0	0	0	0	12	66	198
	HDD65	2937	713	514	372	158	41	1	0	0	9	152	385	592
	CDD50	4957	39	75	176	341	570	762	858	855	687	386	135	73
	CDD65	1609	0	3	9	41	146	313	393	390	246	61	5	2
	CDH74	14219	0	14	103	462	1421	2774	3531	3385	2018	480	30	1
	CDH80	5467	0	1	11	74	416	1131	1497	1457	773	105	2	0
Wind	WSAvg	3.2	4.1	4.2	4.4	3.8	2.8	2.3	2.1	2.0	2.3	2.8	3.5	4.0
Precipitation	PrecAvg	49.7	4.7	4.9	5.5	3.9	3.5	3.9	4.8	3.8	3.6	3.0	4.0	4.5
	PrecMax	69.1	8.8	9.0	10.9	7.6	9.8	8.9	13.8	7.4	9.7	8.9	11.5	13.4
	PrecMin	34.0	2.7	1.7	1.1	1.6	0.9	1.1	2.1	1.1	0.4	0.3	1.0	1.2
	PrecStd	9.5	1.4	1.7	2.2	1.6	1.9	1.9	3.0	1.4	2.0	2.2	2.4	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.7	76.0	81.3	84.4	90.6	93.3	94.2	96.0	95.3	87.8	77.9	73.1
		MCWB	62.5	64.0	64.4	67.8	71.4	75.6	76.9	76.5	73.6	71.7	65.5	66.5
	2%	DB	66.1	70.6	76.8	82.0	87.5	91.1	92.0	92.7	91.1	82.4	73.1	70.1
		MCWB	59.9	61.0	62.4	65.9	71.5	74.8	76.9	76.3	73.3	69.6	63.3	64.9
	5%	DB	62.9	66.9	73.1	79.5	84.3	89.7	90.3	90.4	88.0	79.2	70.4	66.0
		MCWB	58.6	59.7	60.6	64.9	70.3	74.7	76.8	76.1	73.5	67.2	62.1	62.0
	10%	DB	58.8	63.6	69.8	76.1	81.9	87.1	88.2	88.2	84.2	75.5	67.6	62.6
		MCWB	53.8	56.6	59.2	63.5	69.5	74.6	76.4	76.1	73.2	67.3	60.4	58.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.1	66.5	68.0	72.4	75.6	79.8	80.9	81.2	78.3	75.8	71.1	69.9
		MCDB	68.6	71.3	75.8	79.3	83.9	87.0	87.7	88.2	84.7	82.2	72.8	71.3
	2%	WB	62.7	64.1	66.1	70.0	74.2	78.1	79.6	79.8	77.0	73.5	67.9	66.3
		MCDB	64.4	68.3	72.7	76.9	82.5	86.2	87.3	87.3	84.2	77.8	70.3	68.4
	5%	WB	59.5	62.1	63.9	68.2	73.0	77.0	78.5	78.5	75.7	71.3	64.8	63.2
		MCDB	62.3	65.4	68.7	74.9	81.0	85.2	86.1	86.0	82.9	77.0	68.1	64.7
	10%	WB	55.2	59.1	61.6	66.4	71.6	75.9	77.7	77.7	74.5	69.4	62.3	59.2
		MCDB	57.5	63.1	67.2	72.7	79.0	83.5	85.2	85.0	81.4	73.5	65.7	61.4
Mean Daily Temperature Range	5% DB	MDBR	21.4	22.8	24.3	24.6	23.5	21.0	20.1	19.8	20.5	23.3	23.9	21.2
		MCDBR	24.7	24.2	27.1	27.8	24.8	24.1	21.8	23.1	23.6	25.1	26.1	21.8
		MCWBR	18.5	15.7	14.7	13.4	11.0	9.7	8.7	9.1	9.0	13.3	16.5	16.2
	5% WB	MCDBR	20.9	18.5	22.4	21.4	21.0	20.5	19.3	19.4	19.1	18.0	20.3	18.7
		MCWBR	17.8	14.1	14.7	12.5	11.0	10.2	9.8	9.9	9.7	11.2	15.5	16.4
Clear-Sky Solar Irradiance	taub	0.315	0.318	0.351	0.384	0.440	0.472	0.514	0.516	0.417	0.365	0.338	0.316	
	taud	2.525	2.510	2.441	2.329	2.217	2.180	2.071	2.054	2.321	2.456	2.472	2.537	
	Ebn at Noon	287	297	294	287	271	260	249	246	268	276	275	279	
	Edh at Noon	26	30	34	40	45	47	52	52	38	31	28	25	
All-Sky Solar Radiation	RadAvg	866	1044	1392	1757	1937	1947	1884	1725	1505	1280	964	737	
	RadStd	50	128	120	117	162	160	130	102	146	164	96	77	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (42 neighbors)	+0.83	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+279	+194

Nomenclature: See separate page