

POTEAU, OK, USA

WMO: 722178

Lat: 35.021N

Lon: 94.621W

Elev: 451

StdP: 14.46

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 53953

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.8	21.9	4.9	7.2	25.5	10.1	9.4	29.0	22.6	59.2	20.1	54.3	4.1	0	0.397

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.0	100.2	77.8	98.8	77.4	95.2	76.4	82.1	93.3	80.6	91.6	79.3	90.0	5.5	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.4	154.9	87.1	78.6	151.1	86.1	76.7	141.5	84.4	46.3	93.9	44.6	92.8	43.0	90.7	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	16.5	13.6	8.0	104.2	15.5	3.3	-3.2	106.6	-12.2	108.5	-20.9	110.4	-32.2	112.8
			8.4	82.7	14.7	2.1	-2.2	84.2	-10.8	85.4	-19.0	86.6	-29.7	88.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	63.0	41.2	46.5	55.1	62.3	70.3	79.9	82.5	82.2	75.3	63.3	52.3	43.7
	DBStd	16.75	11.18	10.42	9.64	8.47	7.14	4.87	4.93	5.61	6.59	8.90	9.29	9.26
	HDD50	883	311	173	58	10	1	0	0	0	0	8	81	241
	HDD65	2976	741	524	330	144	35	0	0	0	6	142	392	662
	CDD50	5617	37	74	216	380	631	897	1008	998	760	420	150	46
	CDD65	2233	2	4	23	64	200	447	543	533	315	89	11	2
	CDH74	24826	6	35	196	637	1875	5056	6464	6271	3274	915	89	8
	CDH80	11845	0	3	22	129	582	2484	3454	3380	1518	265	8	0
Wind	WSAvg	4.3	5.0	5.3	5.8	5.8	4.5	3.9	3.0	2.9	3.0	3.7	4.4	4.2
Precipitation	PrecAvg	46.9	2.4	2.8	4.0	4.4	6.2	4.0	3.5	2.8	4.5	4.1	4.3	3.7
	PrecMax	72.7	9.3	8.4	9.1	12.3	15.7	10.7	10.7	8.7	11.9	16.5	9.9	10.7
	PrecMin	21.8	0.3	0.2	1.3	1.1	1.3	0.5	0.0	0.0	0.9	0.0	0.8	0.2
	PrecStd	11.1	1.8	1.8	2.0	2.4	3.7	2.7	2.4	1.8	2.5	3.4	2.8	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.4	79.0	82.3	88.2	92.6	100.2	102.3	106.0	99.8	90.3	81.0	74.6
		MCWB	60.5	64.5	65.3	72.5	76.2	77.5	76.2	77.4	76.3	71.8	66.9	66.3
	2%	DB	70.1	73.2	79.3	83.6	89.9	97.4	99.9	101.6	95.4	86.2	76.9	70.3
		MCWB	60.8	62.1	64.4	66.8	74.5	78.4	77.4	79.6	73.8	70.8	64.5	61.4
	5%	DB	64.4	69.9	75.2	81.0	86.1	94.6	98.7	98.7	91.4	82.2	72.5	64.3
		MCWB	55.4	59.9	63.4	66.8	71.5	76.8	77.3	77.8	73.8	68.9	63.2	56.4
	10%	DB	60.9	64.4	72.4	77.9	82.3	91.3	94.7	95.0	89.8	79.3	69.7	60.9
		MCWB	51.5	56.0	60.9	65.3	71.1	76.6	77.1	76.9	73.0	67.8	60.7	53.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.8	68.7	69.5	74.5	79.3	82.8	84.1	83.9	81.5	76.1	70.1	67.6
		MCDB	71.8	75.8	78.2	83.0	88.2	94.7	95.4	95.4	91.7	84.6	76.9	73.9
	2%	WB	62.9	64.7	67.3	72.0	76.7	81.0	81.8	82.0	78.4	74.1	67.3	63.7
		MCDB	67.6	71.1	76.1	80.1	85.2	92.5	92.0	93.9	88.7	82.1	74.2	67.7
	5%	WB	57.2	61.7	65.6	69.8	75.1	79.4	80.2	80.5	76.9	72.2	64.7	58.5
		MCDB	63.6	68.3	73.6	77.4	82.7	90.3	90.6	91.8	87.0	79.7	71.0	63.6
	10%	WB	51.9	57.4	63.0	67.5	73.2	77.9	78.8	79.0	75.3	70.2	61.5	54.0
		MCDB	59.0	63.5	70.0	75.3	80.6	88.1	89.5	89.7	84.3	76.5	67.3	59.1
Mean Daily Temperature Range	5% DB	MDBR	23.0	21.6	22.4	22.4	20.1	20.7	21.0	21.5	23.2	23.5	23.1	20.8
		MCDBR	30.2	29.0	26.0	25.5	22.8	23.9	24.9	25.4	26.3	25.9	26.2	28.0
		MCWBR	19.9	19.3	15.0	12.6	10.5	8.6	7.5	7.9	9.5	12.2	16.7	19.4
	5% WB	MCDBR	23.3	24.9	21.5	19.3	19.5	20.5	20.3	21.8	21.9	20.5	21.8	23.7
		MCWBR	18.7	18.9	14.0	12.4	11.0	9.2	8.5	8.6	9.3	11.3	16.7	19.3
Clear-Sky Solar Irradiance	taub	0.316	0.321	0.358	0.393	0.427	0.441	0.462	0.461	0.403	0.356	0.330	0.309	
	taud	2.487	2.483	2.406	2.311	2.280	2.272	2.253	2.235	2.363	2.476	2.500	2.522	
	Ebn at Noon	282	294	290	283	273	268	262	260	271	277	274	278	
	Edh at Noon	27	30	35	41	43	43	43	43	36	30	26	24	
All-Sky Solar Radiation	RadAvg	808	948	1296	1607	1767	2005	2003	1841	1564	1190	860	695	
	RadStd	77	135	85	97	164	215	124	124	123	165	104	91	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page