

AUGUSTA, GA, USA

WMO: 722180

Lat: 33.364N

Lon: 81.963W

Elev: 40

StdP: 100.84

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 03820

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.2	-3.3	-13.7	1.2	1.4	-11.2	1.4	2.6	10.3	10.9	9.2	10.3	1.0	290	0.390

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	36.2	24.4	34.9	24.2	33.8	24.0	26.3	32.5	25.7	31.8	25.3	31.1	3.7	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.7	19.8	28.6	24.2	19.2	28.1	23.7	18.6	27.6	81.5	32.4	79.2	31.9	77.2	31.1	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.4	6.2	-8.6	38.0	2.0	1.8	-10.1	39.3	-11.3	40.4	-12.4	41.4	-13.9	42.7		
(5)			-9.5	27.6	1.9	0.7	-10.8	28.1	-12.0	28.5	-13.0	28.9	-14.4	29.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.1	8.0	10.0	13.7	17.7	22.1	25.9	27.5	27.0	24.0	18.4	12.6	9.4		
	DBStd	7.95	5.38	4.93	4.64	3.86	3.31	2.30	1.80	2.02	2.85	4.14	4.42	5.03		
	HDD10.0	282	106	57	19	1	0	0	0	0	0	1	23	74		
	HDD18.3	1292	323	237	155	57	8	0	0	0	2	51	179	280		
	CDD10.0	3221	43	56	133	232	375	477	541	528	421	261	99	55		
	CDD18.3	1190	2	3	11	38	125	227	283	269	173	52	6	2		
	CDH23.3	11993	9	30	153	507	1362	2291	2953	2618	1495	494	63	17		
	CDH26.7	5430	0	2	26	143	568	1118	1507	1278	646	135	6	1		
(14) Wind	WSAvg	2.3	2.7	2.8	2.9	2.8	2.4	2.2	2.1	1.8	2.0	2.0	2.1	2.3		
(15) Precipitation	PrecAvg	1124	100	101	112	78	85	111	113	111	83	68	64	90		
	PrecMax	1677	257	239	303	214	244	275	290	312	242	376	197	228		
	PrecMin	769	15	18	22	15	9	17	26	16	6	0	2	24		
	PrecStd	175	55	49	58	46	51	58	63	62	57	64	46	51		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.7	26.5	29.4	31.7	35.2	37.0	37.5	38.1	35.4	32.0	27.6	25.5		
		MCWB	18.1	18.2	18.5	20.3	22.7	24.1	24.7	24.5	23.0	22.7	19.6	18.7		
	2%	DB	22.0	23.9	26.9	30.0	33.3	35.4	36.1	35.8	33.7	29.8	25.2	22.9		
		MCWB	16.5	16.5	17.7	19.6	22.1	23.9	24.6	25.0	23.1	21.3	18.2	17.8		
	5%	DB	19.6	21.5	25.0	28.5	31.7	34.0	34.8	34.1	32.2	28.1	23.2	20.6		
		MCWB	15.3	14.9	16.4	19.1	21.6	23.8	24.6	24.6	23.0	20.4	16.6	16.5		
	10%	DB	17.4	19.1	22.8	26.6	30.0	32.4	33.4	32.7	30.6	26.2	21.1	18.3		
		MCWB	13.9	13.7	15.4	17.8	21.0	23.5	24.5	24.4	22.6	19.5	16.6	15.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.6	19.9	20.5	22.6	24.7	26.3	27.1	27.1	25.7	25.1	21.8	20.9		
		MCDB	22.3	24.1	25.8	27.8	31.1	32.7	33.4	33.2	31.4	28.7	24.0	22.8		
	2%	WB	18.0	18.2	19.2	21.5	23.7	25.6	26.3	26.3	25.0	23.6	20.2	19.0		
		MCDB	20.8	22.3	24.2	26.8	30.1	32.0	32.7	32.3	30.2	27.2	22.6	21.5		
	5%	WB	16.5	16.7	18.1	20.5	22.9	25.0	25.7	25.7	24.4	22.4	19.1	17.5		
		MCDB	19.0	20.0	22.8	25.8	28.9	31.3	31.9	31.5	29.2	25.7	21.6	19.9		
	10%	WB	14.5	15.0	16.9	19.5	22.1	24.5	25.3	25.2	23.8	21.2	17.6	15.6		
		MCDB	16.9	17.9	21.0	24.5	27.6	30.3	31.3	30.7	28.1	24.5	20.7	18.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.0	13.4	14.2	14.6	13.9	12.2	11.8	11.4	12.0	13.7	14.3	12.8		
		MCDBR	15.3	16.0	16.9	16.8	15.6	14.5	13.6	13.4	14.2	15.1	16.5	14.5		
		MCWBR	10.1	9.6	8.5	7.5	6.2	4.9	4.3	4.2	5.1	7.3	9.5	9.6		
	5% WB	MCDBR	12.5	13.2	13.4	13.2	12.9	12.1	11.7	11.6	11.3	11.0	11.7	12.3		
		MCWBR	9.5	9.1	7.9	6.9	5.5	4.7	4.4	4.2	4.6	6.0	8.3	9.1		
(40) Clear-Sky Solar Irradiance	taub		0.326	0.333	0.369	0.405	0.468	0.504	0.548	0.535	0.440	0.401	0.354	0.323		
	taud		2.490	2.466	2.396	2.285	2.156	2.102	1.997	2.025	2.277	2.351	2.441	2.532		
	Ebn at Noon		889	919	907	884	829	795	757	761	825	831	846	873		
	Edh at Noon		87	98	113	132	152	160	177	170	127	109	90	79		
(44) All-Sky Solar Radiation	RadAvg		2.83	3.44	4.53	5.69	6.19	6.33	6.07	5.54	4.81	4.05	3.10	2.45		
	RadStd		0.15	0.36	0.33	0.39	0.47	0.45	0.42	0.27	0.41	0.47	0.24	0.23		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.65	N/A	N/A	N/A	N/A	N/A	N/A	-105	+210	+153
(47) Regional (51 neighbors)		+0.55	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+179	+125

Nomenclature: See separate page