

DANIEL FIELD, GA, USA

WMO: 722181

Lat: 33.467N

Lon: 82.039W

Elev: 423

StdP: 14.47

Time Zone: -5.00 (NAE)

Period: 97-19

WBAN: 13837

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.5	30.3	5.8	7.5	34.5	9.5	9.1	36.7	19.1	53.3	17.0	51.5	6.1	290	0.382

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.0	97.0	74.7	94.7	74.2	92.6	73.8	77.8	89.5	77.1	88.4	76.4	87.1	7.0	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.9	133.1	81.2	73.9	128.6	80.6	73.2	125.4	80.2	41.4	90.2	40.6	88.3	39.9	87.0	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.6	14.4	12.4	DB	21.3	100.2	4.2	3.1	18.4	102.4	15.9	104.3	13.6	106.0	10.6	108.2	
			WB	17.9	79.4	3.5	1.1	15.4	80.2	13.4	80.8	11.4	81.4	8.9	82.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.3	47.9	51.6	58.2	65.9	74.0	80.2	82.6	81.8	76.9	67.1	57.1	51.0
	DBStd	14.19	9.79	8.79	8.69	7.02	5.82	4.54	3.55	3.81	5.27	7.39	7.81	9.12
	HDD50	396	162	79	28	2	0	0	0	0	0	1	24	100
	HDD65	2002	533	381	241	73	8	1	0	0	2	64	257	442
	CDD50	6331	96	125	284	478	744	907	1010	984	806	532	235	130
	CDD65	2463	3	6	31	99	287	458	545	519	358	131	19	7
	CDH74	23931	6	32	231	862	2621	4744	5954	5367	3113	895	85	21
	CDH80	10339	0	2	31	217	1007	2246	2908	2462	1239	220	7	0
(14) Wind	WSAvg	5.9	6.2	6.5	6.9	6.8	6.1	5.7	5.2	5.1	5.9	5.6	5.6	5.8
(15) Precipitation	PrecAvg	42.3	3.0	3.6	4.1	3.1	3.1	4.4	4.4	4.3	3.5	2.2	2.6	3.9
	PrecMax	60.1	6.1	8.7	8.2	6.5	6.1	12.0	8.1	12.2	7.8	5.8	7.4	8.8
	PrecMin	32.4	1.5	1.1	1.1	1.1	0.8	0.4	2.1	1.6	1.0	0.1	0.4	1.2
	PrecStd	7.4	1.3	1.7	1.9	1.5	1.5	2.8	1.7	2.3	1.9	1.5	1.8	2.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.6	78.4	83.5	88.5	95.0	98.9	99.2	99.9	95.3	89.3	81.0	76.8
		MCWB	63.2	64.6	63.8	67.4	70.8	74.7	75.1	74.9	72.8	72.4	67.2	65.5
	2%	DB	70.4	73.3	79.8	85.1	91.1	95.5	96.8	96.1	92.3	85.0	76.3	72.6
		MCWB	60.9	59.8	62.9	65.8	70.0	73.7	75.3	75.2	72.4	69.2	63.7	63.7
	5%	DB	66.4	70.0	76.3	82.3	88.5	93.1	94.4	93.1	90.0	82.0	73.0	69.0
		MCWB	59.1	58.6	60.9	64.8	69.3	73.3	74.9	74.8	71.9	68.0	62.2	62.3
	10%	DB	63.3	65.9	72.6	79.4	85.8	90.8	92.0	90.7	87.6	79.2	70.1	65.3
		MCWB	56.6	56.5	59.1	63.3	68.5	72.8	74.6	74.6	71.4	66.4	61.4	59.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.5	67.0	67.9	71.2	75.1	78.1	78.9	78.7	77.2	75.9	71.4	69.1
		MCDB	70.7	73.3	77.6	81.5	84.2	90.2	91.8	89.3	86.7	82.3	75.0	73.3
	2%	WB	63.6	64.2	65.7	69.5	73.4	76.7	77.8	77.9	76.0	73.3	67.9	66.2
		MCDB	67.5	70.4	73.9	78.9	83.8	88.8	90.2	88.8	84.7	80.5	72.2	69.9
	5%	WB	61.2	61.6	64.0	68.0	72.2	75.7	77.1	77.1	75.0	71.6	65.8	63.5
		MCDB	65.7	67.3	72.0	76.7	82.7	87.7	89.1	87.9	83.2	78.4	70.4	67.7
	10%	WB	58.0	58.6	62.2	66.2	70.9	74.9	76.3	76.3	74.0	69.8	63.3	60.5
		MCDB	62.2	64.2	69.7	75.2	81.2	86.2	87.6	86.4	81.8	76.1	68.1	65.1
(35) Mean Daily Temperature Range	5% DB	MDBR	17.6	18.4	19.7	20.3	19.3	18.4	18.0	17.3	17.3	18.4	18.5	16.9
		MCDBR	19.8	21.3	22.7	23.1	21.7	21.2	20.4	20.1	20.4	19.9	20.8	18.8
		MCWBR	12.7	12.5	10.2	8.6	7.0	6.0	5.5	5.3	5.8	7.9	10.9	12.0
	5% WB	MCDBR	16.7	18.1	18.9	19.1	18.0	18.2	18.0	17.5	16.1	15.6	15.8	16.3
		MCWBR	13.1	12.9	10.5	9.4	6.9	6.2	5.9	5.4	5.5	7.9	10.9	12.7
(40) Clear-Sky Solar Irradiance	taub		0.321	0.328	0.364	0.398	0.460	0.495	0.539	0.526	0.433	0.394	0.348	0.318
	taud		2.501	2.477	2.408	2.298	2.171	2.119	2.016	2.040	2.288	2.364	2.453	2.541
	Ebn at Noon		284	293	289	282	265	254	242	243	264	266	270	279
	Edh at Noon		27	31	36	42	48	50	55	53	40	34	28	25
(44) All-Sky Solar Radiation	RadAvg		893	1087	1432	1798	1960	2012	1923	1756	1526	1284	978	772
	RadStd		48	115	104	124	152	143	136	85	133	151	78	75

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.93	+2.27	N/A	N/A	N/A	N/A	-164	-394	+668	+457
(47) Regional (49 neighbors)		+0.99	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+322	+225

Nomenclature: See separate page