

DANIEL FIELD, GA, USA

WMO: 722181

Lat: 33.467N

Lon: 82.039W

Elev: 129

StdP: 99.79

Time Zone: -5.00 (NAE)

Period: 97-19

WBAN: 13837

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.5	-1.0	-14.6	1.1	1.4	-12.5	1.3	2.6	8.5	11.8	7.6	10.8	2.7	290	0.382

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	36.1	23.7	34.8	23.5	33.7	23.2	25.5	31.9	25.1	31.3	24.6	30.6	3.1	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.9	19.0	27.3	23.3	18.4	27.0	22.9	17.9	26.8	78.4	32.4	76.6	31.3	75.0	30.6	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.4	6.4	5.6		-5.9	37.9	2.3	1.7	-7.6	39.1	-8.9	40.1	-10.2	41.1	-11.9	42.4	
			DB	-7.8	26.3	1.9	0.6	-9.2	26.8	-10.3	27.1	-11.4	27.4	-12.8	27.9	
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.0	8.8	10.9	14.6	18.8	23.3	26.8	28.1	27.6	24.9	19.5	13.9	10.5	(6)
	DBStd	7.88	5.44	4.89	4.83	3.90	3.23	2.52	1.97	2.11	2.93	4.11	4.34	5.07	(7)
	HDD10.0	220	90	44	16	1	0	0	0	0	0	1	13	56	(8)
	HDD18.3	1112	296	212	134	41	4	1	0	0	1	36	143	246	(9)
	CDD10.0	3517	53	69	158	266	413	504	561	547	448	296	131	72	(10)
	CDD18.3	1368	2	3	17	55	159	254	303	288	199	73	11	4	(11)
	CDH23.3	13295	3	18	128	479	1456	2636	3308	2982	1729	497	47	12	(12)
	CDH26.7	5744	0	1	17	121	559	1248	1616	1368	688	122	4	0	(13)
(14) Wind	WSAvg	2.7	2.8	2.9	3.1	3.0	2.7	2.5	2.3	2.3	2.6	2.5	2.5	2.6	(14)
(15) Precipitation	PrecAvg	1075	76	92	104	78	79	113	112	110	90	56	67	100	(15)
	PrecMax	1527	154	222	208	164	155	306	206	310	197	147	189	224	(16)
	PrecMin	823	39	28	28	29	20	11	53	40	26	2	11	30	(17)
	PrecStd	189	33	42	48	39	39	72	42	59	47	37	46	57	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.7	25.8	28.6	31.4	35.0	37.1	37.3	37.7	35.2	31.8	27.2	24.9	(19)
		MCWB	17.3	18.1	17.7	19.6	21.6	23.7	24.0	23.8	22.7	22.4	19.6	18.6	(20)
	2%	DB	21.3	23.0	26.6	29.5	32.8	35.3	36.0	35.6	33.5	29.5	24.6	22.5	(21)
		MCWB	16.0	15.4	17.2	18.8	21.1	23.2	24.0	24.0	22.4	20.7	17.6	17.6	(22)
	5%	DB	19.1	21.1	24.6	28.0	31.4	33.9	34.7	33.9	32.2	27.8	22.8	20.6	(23)
		MCWB	15.0	14.8	16.0	18.2	20.7	23.0	23.8	23.8	22.1	20.0	16.8	16.8	(24)
	10%	DB	17.4	18.8	22.6	26.4	29.9	32.7	33.3	32.6	30.9	26.2	21.1	18.5	(25)
		MCWB	13.7	13.6	15.0	17.4	20.3	22.7	23.7	23.7	21.9	19.1	16.3	15.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.1	19.4	19.9	21.8	23.9	25.6	26.0	26.0	25.1	24.4	21.9	20.6	(27)
		MCDB	21.5	23.0	25.3	27.5	29.0	32.4	33.2	31.8	30.4	28.0	23.9	22.9	(28)
	2%	WB	17.5	17.9	18.7	20.8	23.0	24.8	25.4	25.5	24.4	22.9	20.0	19.0	(29)
		MCDB	19.7	21.3	23.3	26.0	28.8	31.5	32.4	31.6	29.3	26.9	22.4	21.1	(30)
	5%	WB	16.2	16.5	17.8	20.0	22.3	24.3	25.0	25.1	23.9	22.0	18.8	17.5	(31)
		MCDB	18.7	19.6	22.2	24.9	28.2	31.0	31.7	31.0	28.5	25.8	21.3	19.8	(32)
	10%	WB	14.4	14.8	16.8	19.0	21.6	23.8	24.6	24.6	23.4	21.0	17.4	15.8	(33)
		MCDB	16.8	17.9	20.9	24.0	27.4	30.1	30.9	30.2	27.6	24.5	20.1	18.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.8	10.2	11.0	11.3	10.7	10.2	10.0	9.6	9.6	10.2	10.3	9.4	(35)
		MCDBR	11.0	11.8	12.6	12.8	12.1	11.8	11.4	11.2	11.3	11.1	11.6	10.5	(36)
	5% WB	MCWBR	7.1	6.9	5.7	4.8	3.9	3.4	3.1	3.0	3.2	4.4	6.1	6.7	(37)
		MCWBR	9.3	10.0	10.5	10.6	10.0	10.1	10.0	9.7	8.9	8.7	8.8	9.0	(38)
(40) Clear-Sky Solar Irradiance	taub		0.321	0.328	0.364	0.398	0.460	0.495	0.539	0.526	0.433	0.394	0.348	0.318	(40)
		taud	2.501	2.477	2.408	2.298	2.171	2.119	2.016	2.040	2.288	2.364	2.453	2.541	(41)
	Ebn at Noon		895	925	912	890	835	802	764	767	831	837	852	878	(42)
		Edh at Noon	85	97	112	131	150	158	174	167	125	107	89	78	(43)
(44) All-Sky Solar Radiation	RadAvg		2.81	3.43	4.51	5.67	6.18	6.34	6.06	5.54	4.81	4.05	3.08	2.43	(44)
	RadStd		0.15	0.36	0.33	0.39	0.48	0.45	0.43	0.27	0.42	0.47	0.24	0.24	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+1.07	+1.26	N/A	N/A	N/A	N/A	-91	-219	+371	+254	(46)
(47)	Regional (49 neighbors)	+0.55	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+179	+125	(47)

Nomenclature: See separate page