

PEACHTREE CITY, GA, USA

WMO: 722197

Lat: 33.355N

Lon: 84.567W

Elev: 243

StdP: 98.44

Time Zone: -5.00 (NAE)

Period: 96-19

WBAN: 53819

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.7	-4.4	-14.6	1.1	-1.0	-12.4	1.3	0.7	9.2	3.4	8.4	4.9	2.0	320	0.364

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	34.3	23.4	33.2	23.3	32.3	23.2	25.5	30.7	24.9	30.2	24.4	29.5	2.7	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.0	19.5	27.4	23.4	18.8	26.8	22.9	18.2	26.3	79.0	30.8	76.7	30.2	74.8	29.5	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
7.7	6.7	5.5	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-10.0	35.8	2.3	1.9	-11.7	37.2	-13.0	38.2	-14.4	39.3	-16.1	40.6
			-10.9	26.5	2.4	0.9	-12.6	27.2	-14.0	27.7	-15.4	28.2	-17.1	28.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.5	6.3	8.3	12.0	16.1	20.6	24.4	26.1	25.7	22.6	16.8	10.9	7.8
	DBStd	8.03	5.36	4.91	4.72	3.80	3.32	2.39	1.68	1.96	3.03	4.28	4.29	4.87
	HDD10.0	410	141	83	35	3	0	0	0	0	4	39	104	
	HDD18.3	1596	373	281	201	87	18	1	0	0	5	79	224	327
	CDD10.0	2788	27	37	97	186	329	433	498	487	379	214	67	36
	CDD18.3	933	0	1	4	19	89	184	239	229	134	32	2	1
	CDH23.3	8556	0	6	66	261	894	1698	2213	2021	1099	281	16	1
	CDH26.7	3468	0	0	7	44	289	742	1002	905	422	57	1	0
(14) Wind	WSAvg	1.8	2.4	2.3	2.4	2.2	1.7	1.4	1.4	1.2	1.3	1.5	1.8	2.1
(15) Precipitation	PrecAvg	1218	106	111	132	94	93	107	115	90	91	70	95	113
	PrecMax	1742	154	206	262	190	227	243	365	160	277	219	253	325
	PrecMin	842	73	46	26	37	32	52	57	29	8	2	24	31
	PrecStd	257	25	40	60	39	46	55	73	34	64	51	54	70
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.2	24.2	27.6	29.8	33.0	35.1	35.6	36.1	34.8	30.6	25.9	22.8
		MCWB	15.8	16.9	17.1	18.7	21.7	23.1	23.7	23.5	22.7	22.2	18.2	17.4
	2%	DB	19.7	21.3	25.2	27.9	31.2	33.7	33.9	34.1	32.6	27.9	22.9	21.1
		MCWB	15.4	15.2	16.4	18.3	21.2	22.9	23.7	23.8	22.2	19.9	16.1	17.0
	5%	DB	17.7	19.3	23.0	26.5	29.6	32.5	32.8	32.7	31.0	26.4	21.4	18.7
		MCWB	14.3	14.1	15.1	17.4	20.4	22.7	23.9	23.6	22.3	18.6	15.8	15.7
	10%	DB	15.9	17.5	21.1	24.6	28.1	31.1	31.8	31.4	29.1	24.5	19.4	16.7
		MCWB	12.8	13.1	14.3	16.5	20.1	22.5	23.8	23.4	21.7	18.2	14.6	13.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.1	18.6	19.1	21.4	23.8	25.6	26.2	26.1	24.7	23.8	20.8	19.7
		MCDB	19.4	21.4	23.4	25.9	28.5	30.8	31.1	31.2	29.7	27.7	22.3	20.9
	2%	WB	16.7	17.3	18.0	20.2	22.8	24.7	25.5	25.4	24.0	22.3	18.9	17.9
		MCDB	18.6	19.8	22.2	24.7	28.0	30.3	30.8	30.6	28.9	25.6	21.1	19.5
	5%	WB	15.3	15.9	17.0	19.3	22.1	24.1	25.0	24.8	23.4	21.1	17.4	16.4
		MCDB	17.4	18.4	21.1	23.8	27.3	29.7	30.4	29.9	28.1	24.1	19.3	18.2
	10%	WB	13.2	14.2	15.7	18.3	21.4	23.5	24.5	24.3	22.8	19.9	15.8	14.2
		MCDB	14.9	16.7	19.5	22.4	26.3	28.7	29.6	29.1	27.1	23.0	18.7	16.0
(35) Mean Daily Temperature Range	5% DB	MDBR	12.1	12.7	13.5	14.0	13.2	11.7	11.1	11.0	11.8	13.4	13.7	12.0
		MCDBR	14.2	14.9	16.3	16.4	14.8	14.0	12.7	13.1	14.3	15.1	15.8	13.5
		MCWBR	9.9	9.4	8.3	7.5	6.3	5.0	4.5	4.5	5.5	7.5	9.6	9.6
	5% WB	MCDBR	11.2	11.9	12.7	12.3	12.2	11.5	10.9	10.9	11.2	10.8	11.4	11.3
		MCWBR	9.2	8.8	7.6	6.8	5.7	4.8	4.5	4.3	4.9	6.2	8.5	9.1
(40) Clear-Sky Solar Irradiance	taub		0.316	0.320	0.352	0.387	0.442	0.476	0.518	0.520	0.421	0.368	0.340	0.317
	taud		2.524	2.508	2.441	2.323	2.216	2.172	2.065	2.047	2.313	2.450	2.471	2.538
	Ebn at Noon		903	935	925	901	851	818	781	773	843	868	864	880
	Edh at Noon		84	94	108	127	144	150	166	166	122	98	88	78
(44) All-Sky Solar Radiation	RadAvg		2.73	3.30	4.40	5.54	6.11	6.14	5.94	5.43	4.73	4.03	3.04	2.32
	RadStd		0.16	0.40	0.38	0.37	0.51	0.51	0.41	0.32	0.47	0.51	0.30	0.24

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.01	N/A	N/A	N/A	N/A	N/A	-113	-232	+353	+210
(47) Regional (39 neighbors)		+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+145	+105

Nomenclature: See separate page