

APALACHICOLA REGIONAL, FL, USA

WMO: 722200

Lat: 29.733N

Lon: 85.033W

Elev: 19

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 98-19

WBAN: 12832

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.6	35.3	16.3	12.6	39.1	21.0	15.7	42.4	22.2	57.3	20.1	57.0	5.8	50	0.401

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.6	92.2	78.9	90.8	78.6	89.7	78.4	81.8	88.1	80.9	87.4	80.2	86.6	10.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.1	156.1	84.7	79.2	151.6	84.3	78.5	147.9	84.0	45.3	88.7	44.4	87.6	43.6	86.4	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.3	17.2	15.8	DB	26.1	96.7	3.0	4.4	23.9	99.9	22.1	102.4	20.5	104.9	18.3	108.1	
			WB	23.0	83.2	3.0	1.4	20.9	84.2	19.1	85.0	17.5	85.8	15.3	86.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	69.2	53.8	56.9	61.7	67.6	75.0	80.7	82.1	82.3	79.3	71.7	62.0	56.9
	DBStd	11.93	8.85	7.77	6.96	5.71	4.47	2.85	2.39	2.44	3.45	6.67	7.42	8.80
	HDD50	134	65	24	5	0	0	0	0	0	0	0	6	34
	HDD65	1218	355	240	144	38	1	0	0	0	0	24	140	276
	CDD50	7153	183	217	369	527	775	922	995	1000	878	673	366	248
	CDD65	2763	8	13	43	115	312	472	530	535	428	231	51	25
	CDH74	26608	3	20	101	581	2792	5075	5966	5943	4070	1797	218	42
	CDH80	9293	0	0	5	45	727	1945	2418	2361	1390	383	12	7
Wind	WSAvg	7.3	7.7	7.5	8.1	8.1	7.8	7.1	6.1	6.2	6.8	7.1	7.2	7.6
Precipitation	PrecAvg	54.7	4.2	3.9	4.6	2.6	2.5	5.0	6.9	7.5	7.1	3.9	3.2	3.5
	PrecMax	88.3	20.8	9.9	13.0	12.1	12.1	16.4	18.1	18.9	18.8	20.5	7.5	9.7
	PrecMin	32.4	0.7	0.4	0.0	0.0	0.0	0.2	0.7	2.3	0.6	0.0	0.2	0.8
	PrecStd	13.2	3.3	2.3	3.0	2.8	2.3	3.9	4.3	3.9	4.7	3.9	2.0	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.7	76.7	80.0	83.4	90.6	94.5	94.4	94.0	91.4	88.0	81.5	77.4
		MCWB	68.5	67.9	67.5	70.8	74.7	79.0	79.4	79.4	77.6	76.7	73.0	70.6
	2%	DB	71.7	73.3	76.7	81.2	88.0	91.4	91.7	91.7	89.7	86.0	79.0	74.6
		MCWB	66.5	66.9	67.8	70.9	74.7	78.4	79.1	79.2	77.1	75.7	71.5	69.6
	5%	DB	69.7	71.0	74.4	79.3	85.9	90.0	90.4	90.4	88.3	83.9	76.6	72.6
		MCWB	65.0	65.7	66.9	69.6	74.1	78.1	79.0	79.2	76.9	74.7	69.4	68.7
	10%	DB	67.0	68.7	72.5	77.4	83.9	88.2	89.0	89.1	86.8	82.0	74.4	70.6
		MCWB	63.2	64.3	66.1	69.3	73.6	77.4	78.7	79.0	76.7	73.8	68.3	67.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.6	71.3	72.8	76.5	78.9	82.2	82.9	82.8	82.0	80.9	76.4	73.3
		MCDB	72.4	73.6	75.9	80.1	83.9	87.8	88.5	89.3	87.2	83.8	79.5	74.8
	2%	WB	68.2	69.3	70.9	74.8	77.6	80.7	81.5	81.8	80.3	78.5	74.0	71.5
		MCDB	70.4	71.5	73.9	78.5	83.6	87.3	88.7	88.4	85.8	82.7	77.0	73.5
	5%	WB	66.2	67.3	69.3	73.0	76.6	79.9	80.6	80.8	79.2	77.2	72.0	70.0
		MCDB	68.3	69.9	72.6	77.3	82.6	86.7	87.5	87.4	85.0	81.8	75.1	71.9
	10%	WB	64.3	65.4	67.5	71.3	75.6	78.8	79.9	80.1	78.2	75.8	69.9	67.6
		MCDB	66.2	67.5	71.0	75.2	81.6	85.7	86.6	86.5	84.0	80.7	73.4	70.1
Mean Daily Temperature Range	5% DB	MDBR	17.9	17.4	17.3	17.2	16.6	14.2	13.6	13.2	14.2	17.5	19.3	17.4
		MCDBR	15.9	16.3	16.6	17.0	18.0	16.4	15.5	14.9	15.7	16.4	17.8	15.2
		MCWBR	11.9	12.0	10.3	9.4	8.1	6.9	6.4	6.2	6.7	8.4	11.6	11.5
	5% WB	MCDBR	12.9	14.2	13.3	12.9	14.0	14.1	13.8	13.0	12.7	13.2	13.8	13.0
		MCWBR	10.9	11.9	9.6	9.1	7.4	6.7	6.5	6.3	6.3	7.7	10.6	11.2
Clear-Sky Solar Irradiance	taub		0.347	0.356	0.367	0.394	0.436	0.469	0.491	0.482	0.435	0.387	0.356	0.346
	taud		2.507	2.495	2.465	2.381	2.297	2.267	2.221	2.251	2.362	2.474	2.494	2.532
	Ebn at Noon		281	289	292	286	272	262	256	257	267	274	275	276
	Edh at Noon		29	31	34	39	42	43	45	43	38	32	29	27
All-Sky Solar Radiation	RadAvg		1009	1220	1629	1950	2162	1985	1861	1738	1607	1446	1134	903
	RadStd		81	145	137	160	131	136	132	124	115	106	82	84

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+1.08	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (26 neighbors)	+0.83	N/A	N/A	N/A	N/A	N/A	N/A	-175	+292	+180

Nomenclature: See separate page