

MOORE COUNTY AP, TX, USA

WMO: 722214

Lat: 35.858N

Lon: 102.013W

Elev: 3705

StdP: 12.83

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 03070

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	9.5	14.1	-1.3	5.9	20.9	2.5	7.2	29.3	37.4	34.5	33.0	38.5	9.8	10	0.636

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.4	99.1	64.4	96.6	65.1	93.8	65.4	70.7	86.0	69.5	85.3	68.6	84.5	13.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.7	113.0	74.8	65.4	107.9	74.2	64.2	103.2	73.1	37.0	85.3	36.0	85.4	35.1	84.2	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
32.0	27.1	24.2	1.5	103.3	4.0	2.6	-1.5	105.2	-3.8	106.7	-6.1	108.2	-9.0	110.1	
			0.4	72.5	3.9	1.7	-2.4	73.7	-4.6	74.7	-6.8	75.7	-9.6	76.9	
			DB												
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.3	37.0	39.4	48.5	55.6	64.5	75.8	78.6	76.7	69.9	57.5	46.4	36.8	(6)
	DBStd	17.31	9.68	10.82	9.69	8.99	8.67	6.00	4.90	5.15	6.58	9.16	9.47	9.79	(7)
	HDD50	1549	410	321	140	47	7	0	0	0	0	36	173	415	(8)
	HDD65	4236	867	718	513	298	115	2	0	1	29	261	558	874	(9)
	CDD50	4227	7	22	95	215	458	775	888	829	598	269	65	6	(10)
	CDD65	1440	0	0	3	16	100	327	423	365	177	29	0	0	(11)
	CDH74	17740	0	19	159	496	1526	4019	5059	3961	1949	499	53	0	(12)
	CDH80	8843	0	3	33	154	668	2142	2786	2058	839	156	4	0	(13)
	WSAvg	11.6	11.6	12.0	12.6	13.9	11.9	12.2	10.4	9.6	10.8	11.4	11.9	11.4	(14)
	PrecAvg	18.3	0.5	0.4	1.3	1.3	1.9	2.5	2.8	3.1	1.6	1.5	0.7	0.8	(15)
(16) Precipitation	PrecMax	25.5	1.3	1.4	4.0	4.7	4.9	5.1	6.0	5.9	5.3	5.8	3.1	3.7	(16)
	PrecMin	12.0	0.0	0.0	0.0	0.0	0.3	0.2	0.4	0.6	0.1	0.1	0.0	0.0	(17)
	PrecStd	3.0	0.5	0.4	1.0	1.3	1.2	1.2	1.4	1.3	1.3	1.7	0.7	0.9	(18)
	PrecStd	3.0	0.5	0.4	1.0	1.3	1.2	1.2	1.4	1.3	1.3	1.7	0.7	0.9	(18)
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.7	76.8	84.4	89.2	95.4	102.4	102.5	99.7	95.5	89.8	79.3	68.3	(19)
		MCWB	47.1	49.7	53.4	54.0	58.0	61.7	66.3	65.5	63.4	59.3	52.7	47.6	(20)
	2%	DB	64.2	70.1	78.8	84.4	91.1	99.0	99.1	97.2	92.0	84.3	74.5	63.0	(21)
		MCWB	45.2	47.4	51.7	53.7	58.7	62.3	65.8	66.3	63.9	58.7	51.0	45.2	(22)
	5%	DB	59.2	64.8	72.9	80.5	87.9	95.3	96.3	94.7	89.2	80.3	68.6	58.5	(23)
		MCWB	42.6	45.3	49.7	53.3	58.4	64.1	66.2	66.7	63.8	57.5	49.0	43.4	(24)
	10%	DB	54.1	58.8	67.7	74.7	83.0	91.4	93.1	90.8	85.4	74.6	63.3	52.9	(25)
		MCWB	40.4	42.5	48.5	52.7	58.9	64.7	66.8	66.6	63.4	55.5	47.2	40.8	(26)
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.7	51.9	58.3	62.3	67.6	71.2	72.5	72.1	69.9	66.0	55.7	50.2	(27)
		MCDB	66.6	69.9	71.3	72.6	80.3	87.7	88.1	86.1	84.9	76.4	69.1	62.3	(28)
	2%	WB	46.3	48.6	55.1	58.9	65.2	69.4	70.7	70.6	68.1	63.2	53.0	46.8	(29)
		MCDB	61.9	67.1	67.9	70.8	79.7	86.0	86.6	85.0	81.4	73.0	67.9	61.3	(30)
	5%	WB	43.6	46.1	52.3	56.7	63.4	68.4	69.4	69.4	66.6	60.7	50.7	44.0	(31)
		MCDB	58.1	63.8	68.4	70.3	76.6	84.7	85.5	84.8	79.6	71.5	65.6	56.1	(32)
	10%	WB	40.9	43.4	49.8	54.4	61.3	67.2	68.5	68.4	65.5	58.4	48.2	41.3	(33)
		MCDB	53.2	57.8	66.4	70.7	75.0	83.3	84.9	84.0	79.1	70.8	62.3	52.2	(34)
(36) Mean Daily Temperature Range	5% DB	MDBR	26.1	27.3	29.3	29.3	27.7	27.9	26.4	25.6	26.0	27.3	27.6	24.4	(35)
		MCDBR	33.3	36.9	37.2	37.6	34.2	32.3	30.3	30.2	31.0	33.4	34.8	31.8	(36)
		MCWBR	18.4	19.2	16.8	15.7	13.2	10.0	8.1	7.9	9.9	13.6	16.7	17.8	(37)
	5% WB	MCDBR	32.3	35.3	32.5	29.8	28.6	27.8	25.9	25.8	24.7	25.5	30.7	30.0	(38)
		MCWBR	18.2	18.9	16.1	14.5	12.9	9.8	8.2	8.4	9.0	13.0	15.9	17.5	(39)
(40) Clear-Sky Solar Irradiance	taub		0.250	0.258	0.287	0.319	0.333	0.370	0.376	0.363	0.334	0.294	0.266	0.253	(40)
	taud		2.605	2.590	2.508	2.424	2.443	2.384	2.407	2.414	2.474	2.569	2.574	2.591	(41)
	Ebn at Noon		310	317	314	306	301	288	285	288	293	299	299	301	(42)
	Edh at Noon		23	26	31	36	36	38	37	36	32	27	23	22	(43)
(44) All-Sky Solar Radiation	RadAvg		969	1234	1638	2027	2277	2421	2340	2079	1779	1350	1040	840	(44)
	RadStd		80	108	123	113	149	129	100	102	87	138	95	52	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (17 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+160	N/A

Nomenclature: See separate page