

MOORE COUNTY AP, TX, USA

WMO: 722214

Lat: 35.858N

Lon: 102.013W

Elev: 1129

StdP: 88.47

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 03070

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-12.5	-9.9	-18.5	0.8	-6.2	-16.4	1.0	-1.5	16.7	1.4	14.7	3.6	4.4	10	0.636

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.7	37.3	18.0	35.9	18.4	34.3	18.5	21.5	30.0	20.8	29.6	20.3	29.1	6.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.3	16.1	23.8	18.6	15.4	23.4	17.9	14.7	22.9	68.3	29.6	65.9	29.7	63.8	29.0	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 14.3	12.1	10.8		-17.0	39.6	2.2	1.4	-18.6	40.7	-19.9	41.5	-21.2	42.3	-22.8		
(5)				-17.5	22.5	2.1	0.9	-19.1	23.2	-20.3	23.7	-21.5	24.3	-23.1	24.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.1	2.8	4.1	9.2	13.1	18.1	24.4	25.9	24.9	21.1	14.2	8.0	2.7
	DBStd	9.62	5.38	6.01	5.38	4.99	4.81	3.33	2.72	2.86	3.65	5.09	5.26	5.44
	HDD10.0	861	228	178	78	26	4	0	0	0	0	20	96	231
	HDD18.3	2353	482	399	285	166	64	1	0	1	16	145	310	486
	CDD10.0	2348	4	12	53	119	254	431	493	461	332	149	36	3
	CDD18.3	800	0	0	2	9	56	182	235	203	98	16	0	0
	CDH23.3	9856	0	11	88	276	848	2233	2811	2201	1083	277	29	0
	CDH26.7	4913	0	2	18	86	371	1190	1548	1143	466	87	2	0
(14) Wind	WSAvg	5.2	5.2	5.4	5.6	6.2	5.3	5.5	4.6	4.3	4.8	5.1	5.3	5.1
(15) Precipitation	PrecAvg	466	13	10	32	33	49	64	70	78	40	39	17	20
	PrecMax	648	34	36	102	120	124	129	152	151	135	148	80	94
	PrecMin	305	0	0	0	0	8	4	10	15	2	2	0	0
	PrecStd	77	12	10	26	32	31	31	36	32	34	42	18	22
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.0	24.9	29.1	31.8	35.2	39.1	39.2	37.6	35.3	32.1	26.3	20.2
		MCWB	8.4	9.8	11.9	12.2	14.4	16.5	19.0	18.6	17.4	15.2	11.5	8.7
	2%	DB	17.9	21.2	26.0	29.1	32.9	37.2	37.3	36.2	33.3	29.1	23.6	17.2
		MCWB	7.3	8.5	10.9	12.1	14.8	16.8	18.8	19.0	17.7	14.8	10.6	7.4
	5%	DB	15.1	18.2	22.7	27.0	31.0	35.2	35.7	34.8	31.8	26.8	20.3	14.7
		MCWB	5.9	7.4	9.8	11.9	14.7	17.8	19.0	19.3	17.7	14.2	9.4	6.3
	10%	DB	12.3	14.9	19.8	23.7	28.3	33.0	34.0	32.7	29.7	23.7	17.4	11.6
		MCWB	4.7	5.8	9.2	11.5	14.9	18.2	19.3	19.2	17.4	13.1	8.4	4.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.9	11.0	14.6	16.8	19.8	21.8	22.5	22.3	21.1	18.9	13.2	10.1
		MCDB	19.2	21.0	21.8	22.6	26.8	30.9	31.2	30.1	29.4	24.7	20.6	16.9
	2%	WB	7.9	9.2	12.8	14.9	18.4	20.8	21.5	21.5	20.1	17.3	11.7	8.2
		MCDB	16.6	19.5	19.9	21.6	26.5	30.0	30.3	29.5	27.4	22.8	19.9	16.3
	5%	WB	6.4	7.8	11.3	13.7	17.4	20.2	20.8	20.8	19.2	15.9	10.4	6.7
		MCDB	14.5	17.7	20.2	21.3	24.8	29.3	29.7	29.3	26.4	22.0	18.7	13.4
	10%	WB	4.9	6.3	9.9	12.4	16.3	19.6	20.3	20.2	18.6	14.7	9.0	5.2
		MCDB	11.8	14.3	19.1	21.5	23.9	28.5	29.4	28.9	26.2	21.5	16.8	11.2
(35) Mean Daily Temperature Range	5% DB	MDBR	14.5	15.1	16.3	16.3	15.4	15.5	14.7	14.2	14.5	15.2	15.3	13.5
		MCDBR	18.5	20.5	20.7	20.9	19.0	17.9	16.8	16.8	17.2	18.6	19.4	17.7
		MCWBR	10.2	10.6	9.3	8.7	7.3	5.5	4.5	4.4	5.5	7.5	9.3	9.9
	5% WB	MCDBR	17.9	19.6	18.0	16.5	15.9	15.4	14.4	14.3	13.7	14.2	17.0	16.7
		MCWBR	10.1	10.5	8.9	8.0	7.2	5.4	4.6	4.6	5.0	7.2	8.9	9.7
(40) Clear-Sky Solar Irradiance	taub		0.250	0.258	0.287	0.319	0.333	0.370	0.376	0.363	0.334	0.294	0.266	0.253
	taud		2.605	2.590	2.508	2.424	2.443	2.384	2.407	2.414	2.474	2.569	2.574	2.591
	Ebn at Noon		976	1000	989	964	948	909	900	908	923	943	944	949
	Edh at Noon		72	83	99	114	114	120	117	114	102	84	74	69
(44) All-Sky Solar Radiation	RadAvg		3.06	3.89	5.16	6.39	7.18	7.63	7.38	6.55	5.61	4.26	3.28	2.65
	RadStd		0.25	0.34	0.39	0.36	0.47	0.41	0.31	0.32	0.28	0.43	0.30	0.16

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+89	N/A

Nomenclature: See separate page