

CRESTVIEW, FL, USA

WMO: 722215

Lat: 30.780N

Lon: 86.523W

Elev: 190

StdP: 14.60

Time Zone: -6.00 (NAC)

Period: 97-19

WBAN: 13884

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.7	27.8	12.1	10.3	35.3	16.9	13.0	38.8	20.1	58.4	18.1	56.1	1.8	340	0.358

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.0	96.0	76.1	93.9	76.0	92.1	75.7	80.1	89.1	79.1	88.1	78.2	87.1	6.3	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.8	145.5	83.5	76.7	140.3	82.7	75.8	135.8	81.9	43.6	89.0	42.6	88.1	41.7	87.6	84.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.9	14.8	12.5	DB	18.7	99.0	3.6	2.5	16.1	100.8	14.0	102.3	12.0	103.6	9.4	105.5
			WB	17.3	81.7	3.6	1.1	14.7	82.5	12.6	83.1	10.6	83.7	7.9	84.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.8	50.1	53.6	59.3	66.0	73.4	79.9	81.2	81.0	77.4	68.0	57.8	52.6
	DBStd	13.29	10.20	8.90	8.23	6.50	5.15	3.28	2.62	2.80	4.55	7.61	8.41	9.54
	HDD50	314	128	58	18	1	0	0	0	0	0	1	23	85
	HDD65	1791	470	330	212	66	7	0	0	0	2	59	246	399
	CDD50	6435	133	160	306	479	725	898	969	962	823	559	257	164
	CDD65	2439	9	11	35	95	268	448	504	497	375	153	30	14
	CDH74	23601	16	56	328	996	2922	4586	4948	4730	3307	1431	229	52
	CDH80	10129	0	2	44	217	1205	2226	2330	2190	1449	443	23	0
Wind	WSAvg	4.6	5.3	5.5	5.8	5.6	4.7	4.1	3.7	3.4	4.0	4.1	4.3	4.9
Precipitation	PrecAvg	58.5	3.8	4.6	5.4	5.3	3.3	5.2	7.2	5.9	5.1	3.2	3.9	5.1
	PrecMax	77.8	15.1	8.5	13.8	15.0	12.2	11.7	17.1	9.6	26.0	10.4	10.9	10.7
	PrecMin	37.7	0.0	1.5	0.4	1.3	0.0	1.3	2.5	1.1	1.1	0.0	0.2	2.1
	PrecStd	12.2	3.0	2.0	3.6	2.8	3.0	2.7	3.7	2.2	4.8	3.1	3.1	2.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.0	79.3	84.3	87.8	95.3	98.9	97.6	97.5	96.2	90.5	83.0	78.5
		MCWB	66.3	65.6	66.0	70.1	72.2	75.8	77.9	76.9	75.0	72.5	69.4	68.8
	2%	DB	73.3	75.3	80.8	84.9	91.6	95.5	95.0	94.6	92.9	87.8	79.3	75.2
		MCWB	65.9	64.1	65.3	67.8	71.7	75.3	77.2	77.2	74.8	71.8	68.1	68.0
	5%	DB	71.0	72.4	77.8	82.5	89.2	93.2	92.9	92.6	90.6	84.8	76.6	72.4
		MCWB	65.0	63.8	64.3	66.6	71.0	75.0	77.1	77.1	74.5	70.9	66.5	67.1
	10%	DB	67.9	69.7	74.7	80.1	86.7	90.7	90.8	90.5	88.3	82.1	73.8	69.6
		MCWB	63.0	62.6	62.8	65.9	70.5	74.8	76.8	76.9	74.3	69.0	65.4	65.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.4	70.2	71.7	74.3	76.6	80.0	81.4	81.4	79.1	77.4	74.6	72.9
		MCDB	72.9	73.9	76.7	80.4	84.9	89.8	90.5	90.1	86.9	83.6	77.9	75.7
	2%	WB	68.6	68.5	69.7	72.7	75.4	78.5	80.1	80.2	78.0	75.8	72.5	70.2
		MCDB	71.5	72.4	74.4	78.7	83.4	88.3	89.7	88.7	86.4	81.7	75.7	72.8
	5%	WB	66.4	66.6	68.2	71.2	74.5	77.7	79.0	79.2	77.2	74.4	69.7	68.3
		MCDB	69.7	70.5	73.3	77.4	82.8	87.5	88.5	87.7	85.6	80.5	74.1	71.2
	10%	WB	63.7	64.2	66.1	69.6	73.4	76.8	78.1	78.3	76.2	72.6	67.2	65.6
		MCDB	66.6	67.7	72.2	75.8	82.0	86.2	87.0	86.6	84.2	78.8	72.6	68.9
Mean Daily Temperature Range	5% DB	MDBR	24.0	24.7	26.2	26.0	25.7	21.9	20.0	19.4	21.0	25.1	26.4	23.1
		MCDBR	23.1	24.8	27.5	27.8	29.0	25.7	23.0	22.5	24.2	25.8	26.3	22.2
		MCWBR	16.0	15.2	14.2	12.9	11.5	8.7	8.3	8.1	9.2	12.0	15.7	15.7
	5% WB	MCDBR	18.0	19.1	19.8	20.2	22.1	21.3	20.0	19.1	19.1	19.0	19.9	18.4
		MCWBR	14.6	14.6	12.5	11.0	9.6	8.1	8.3	7.9	8.2	10.1	14.1	15.3
Clear-Sky Solar Irradiance	taub		0.327	0.341	0.364	0.392	0.434	0.466	0.511	0.499	0.436	0.379	0.351	0.335
	taud		2.541	2.504	2.435	2.364	2.279	2.243	2.134	2.163	2.316	2.453	2.473	2.527
	Ebn at Noon		287	292	292	286	273	263	250	252	266	276	275	278
	Edh at Noon		27	31	35	39	43	44	49	47	39	32	29	26
All-Sky Solar Radiation	RadAvg		972	1159	1571	1899	2096	1987	1887	1752	1623	1429	1100	850
	RadStd		69	149	126	153	125	163	116	126	104	145	96	87

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+1.01	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+392	+218
Regional (42 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+277	+175

Nomenclature: See separate page