

DUBLIN, GA, USA

WMO: 722217

Lat: 32.564N

Lon: 82.985W

Elev: 94

StdP: 100.20

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 63881

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.7	(c) -2.3	(d) -13.7	(e) 1.2	(f) 0.7	(g) -10.9	(h) 1.5	(i) 3.8	(j) 9.4	(k) 13.5	(l) 8.3	(m) 11.3	(n) 0.8	(o) 320	(p) 0.363

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 11.5	(c) 36.3	(d) 24.3	(e) 35.0	(f) 24.1	(g) 33.7	(h) 24.1	(i) 27.5	(j) 31.5	(k) 26.6	(l) 30.7	(m) 25.9	(n) 30.4	(o) 2.7	(p) 320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.4	22.1	29.0	25.9	21.5	28.7	24.8	20.1	27.9	87.7	31.9	83.6	31.0	80.4	30.3	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 7.3	(b) 6.0	(c) 5.2	(e) -7.1	(f) 37.9	(g) 1.9	(h) 2.1	(i) -8.4	(j) 39.4	(k) -9.5	(l) 40.6	(m) -10.5	(n) 41.8	(o) -11.9	(p) 43.3		
			DB													
			WB													
				-7.9	27.5	1.8	1.2	-9.2	28.4	-10.3	29.1	-11.3	29.8	-12.7	30.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.5	8.5	10.8	13.7	17.9	22.6	26.5	27.5	27.0	24.5	18.8	12.7	10.6		
	DBStd	7.77	5.22	4.91	4.60	3.78	3.22	2.24	1.77	2.41	2.58	4.25	4.20	4.78		
	HDD10.0	231	93	46	18	2	0	0	0	1	0	1	19	52		
	HDD18.3	1199	305	214	154	53	7	0	0	2	1	48	174	242		
	CDD10.0	3323	47	68	133	239	390	494	544	527	436	273	100	72		
	CDD18.3	1248	1	3	11	40	138	244	286	270	186	62	6	3		
	CDH23.3	12544	7	28	135	492	1427	2558	2959	2618	1661	579	63	16		
	CDH26.7	5665	0	1	18	121	596	1283	1483	1253	738	164	7	0		
(14) Wind	WSAvg	1.8	2.1	2.2	2.3	2.2	1.9	1.6	1.5	1.4	1.5	1.7	1.7	1.8		
(15) Precipitation	PrecAvg	1206	105	107	124	69	62	132	117	128	105	89	71	96		
	PrecMax	1576	236	209	240	167	154	230	223	241	327	271	185	227		
	PrecMin	912	27	32	6	16	6	29	44	59	3	7	12	40		
	PrecStd	198	46	45	74	41	34	60	52	50	83	72	42	45		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.1	26.4	28.1	31.3	35.9	37.7	37.5	37.4	36.2	32.2	27.6	25.2		
		MCWB	18.5	18.6	18.9	20.5	22.1	24.6	25.1	25.3	22.4	22.5	19.1	18.9		
	2%	DB	22.1	23.8	27.1	29.7	32.9	36.2	36.1	35.9	33.8	30.1	25.2	22.7		
		MCWB	17.3	16.9	18.3	19.6	21.9	24.3	24.7	24.9	22.7	21.1	17.4	18.0		
	5%	DB	19.1	22.1	24.9	27.8	32.1	34.1	34.7	33.9	32.4	28.0	22.8	21.1		
		MCWB	16.2	15.9	16.9	18.9	21.5	24.0	24.6	25.0	22.9	20.2	16.4	18.0		
	10%	DB	17.5	19.9	22.5	26.9	30.2	32.7	32.9	32.5	31.2	27.1	21.2	18.7		
		MCWB	14.9	15.0	15.7	18.3	21.0	23.6	24.6	24.8	22.8	19.6	16.3	16.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.2	19.7	20.8	22.7	24.7	27.7	28.5	28.9	26.0	25.0	21.7	21.2		
		MCDB	21.5	23.9	25.0	27.3	29.8	33.5	33.0	33.7	29.8	27.8	23.7	22.8		
	2%	WB	18.4	18.6	19.5	21.6	23.7	26.4	27.5	27.6	25.2	23.7	20.4	19.7		
		MCDB	20.6	22.7	24.2	26.4	29.1	32.5	31.4	31.0	29.7	26.7	22.6	21.2		
	5%	WB	17.3	17.4	18.6	20.7	23.0	25.6	26.6	26.7	24.6	22.7	18.8	18.2		
		MCDB	18.6	19.7	23.3	25.1	28.2	31.5	30.9	30.0	28.9	25.7	22.1	19.8		
	10%	WB	15.5	16.1	17.4	19.6	22.3	24.9	25.8	25.9	23.9	21.9	17.3	17.1		
		MCDB	17.7	18.7	20.4	24.4	27.6	30.5	30.5	29.9	28.1	25.0	19.2	18.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.1	13.0	13.8	14.3	13.5	12.4	11.5	11.2	12.2	13.8	14.0	11.8		
		MCDBR	13.6	15.5	16.0	16.1	15.6	14.2	13.3	13.2	14.6	14.9	16.3	13.4		
	5% WB	MCWBR	9.2	9.3	8.3	7.4	5.6	4.6	4.0	4.2	5.3	6.9	9.5	9.1		
		MCWBR	10.9	12.5	13.3	13.0	12.3	12.2	11.0	10.5	11.2	10.6	12.4	10.9		
(40) Clear-Sky Solar Irradiance	taub		0.323	0.329	0.356	0.386	0.434	0.478	0.517	0.516	0.423	0.380	0.348	0.324		
	taud		2.513	2.490	2.440	2.347	2.248	2.189	2.086	2.083	2.333	2.426	2.465	2.532		
	Ebn at Noon		899	929	923	904	858	817	783	778	844	858	859	878		
	Edh at Noon		86	96	109	125	139	147	163	161	120	102	89	80		
(44) All-Sky Solar Radiation	RadAvg		2.90	3.50	4.58	5.73	6.28	6.25	6.10	5.54	4.84	4.14	3.19	2.50		
	RadStd		0.15	0.36	0.36	0.39	0.46	0.45	0.34	0.28	0.43	0.45	0.25	0.24		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (37 neighbors)	+0.50	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+173	+120

Nomenclature: See separate page