

PERRY FOLEY, FL, USA

WMO: 722224

Lat: 30.072N

Lon: 83.574W

Elev: 45

StdP: 14.67

Time Zone: -5.00 (NAE)

Period: 01-19

WBAN: 53862

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.9	31.7	13.3	10.8	39.9	18.5	14.0	42.8	22.5	66.6	19.7	61.1	2.0	300	0.356

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.3	93.9	76.8	92.6	76.7	91.0	76.5	80.7	87.9	79.8	87.5	79.0	86.7	6.8	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.1	151.1	84.0	77.7	144.4	83.3	76.9	140.4	82.8	44.2	87.7	43.2	87.2	42.4	87.0	84.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.3	16.1	13.3	DB	23.0	97.6	4.4	1.7	19.8	98.8	17.2	99.8	14.7	100.7	11.5	101.9	(4)
(5)			WB	20.7	82.0	4.0	1.2	17.9	82.9	15.5	83.6	13.3	84.3	10.4	85.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	69.0	53.5	56.9	61.8	67.9	74.8	80.4	81.7	81.7	79.2	71.2	61.5	56.7	(6)	
	DBStd	12.12	9.70	8.74	7.40	5.68	4.74	2.73	2.18	2.49	3.70	7.23	8.06	9.55	(7)	
	HDD50	168	77	31	7	0	0	0	0	0	0	0	9	44	(8)	
	HDD65	1286	369	249	147	37	4	0	0	0	0	33	158	289	(9)	
	CDD50	7107	186	224	374	536	769	912	984	984	876	657	354	251	(10)	
	CDD65	2748	13	21	49	123	308	462	519	519	426	224	53	31	(11)	
	CDH74	25166	61	121	389	1102	2952	4388	5110	4960	3781	1782	384	136	(12)	
	CDH80	9804	1	11	44	222	1142	1916	2238	2057	1572	541	53	7	(13)	
(14) Wind	WSAvg	5.1	5.7	5.8	6.2	5.9	5.5	4.8	4.2	3.8	4.5	4.8	5.0	5.3	(14)	
(15) Precipitation	PrecAvg	52.2	4.4	3.5	4.6	2.8	2.7	6.6	7.5	7.5	4.5	2.9	2.1	2.7	(15)	
	PrecMax	68.5	14.2	11.2	15.7	7.9	7.6	17.0	14.1	22.1	13.7	10.3	5.0	6.2	(16)	
	PrecMin	33.4	0.9	0.6	0.2	0.4	0.2	2.8	3.4	3.1	0.6	0.2	0.0	0.9	(17)	
	PrecStd	10.6	3.0	2.5	3.3	2.0	1.9	3.4	2.7	4.1	2.8	2.7	1.3	1.4	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.0	81.9	83.9	87.9	94.0	96.4	95.5	95.5	94.0	90.5	84.5	81.0	(19)	
		MCWB	66.9	67.6	65.8	69.3	72.2	75.8	77.4	77.9	76.6	74.7	72.1	69.1	(20)	
	2%	DB	75.4	77.9	81.1	84.4	90.7	93.2	93.3	93.2	91.9	88.0	81.4	77.9	(21)	
		MCWB	66.0	66.3	66.5	68.4	71.8	75.9	77.4	78.2	75.9	73.4	69.8	67.9	(22)	
	5%	DB	72.6	74.5	78.8	82.4	88.5	91.2	91.5	91.3	90.4	85.6	78.8	74.9	(23)	
		MCWB	64.3	64.3	65.4	67.7	71.4	76.1	77.4	78.2	75.4	71.6	67.5	68.0	(24)	
	10%	DB	69.3	71.7	75.4	80.8	86.3	89.6	90.2	89.9	88.5	83.1	75.3	72.1	(25)	
		MCWB	63.0	63.2	63.5	66.9	71.1	76.0	77.5	78.0	75.1	71.4	65.9	66.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.6	71.4	72.4	74.7	77.5	81.6	82.3	82.0	80.3	78.5	76.2	73.4	(27)	
		MCDB	74.6	76.6	77.2	80.8	85.8	87.9	87.7	89.5	88.1	84.4	80.8	76.5	(28)	
	2%	WB	68.5	69.3	70.1	73.1	76.1	79.9	80.6	80.5	78.9	76.9	73.6	71.2	(29)	
		MCDB	72.7	74.8	75.4	79.8	84.4	87.6	87.3	88.3	86.8	83.3	78.2	74.9	(30)	
	5%	WB	66.2	67.5	68.5	71.5	75.1	78.5	79.6	79.7	78.0	75.5	71.0	69.4	(31)	
		MCDB	70.5	72.9	74.5	78.1	83.2	86.5	87.1	87.7	86.0	81.8	75.0	73.2	(32)	
	10%	WB	63.9	65.2	66.7	70.0	74.0	77.6	78.6	78.9	77.1	74.1	68.3	67.1	(33)	
		MCDB	67.6	69.6	73.0	76.5	81.8	85.5	86.3	86.6	84.8	80.0	73.9	71.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	22.7	23.3	24.0	23.6	22.2	18.1	17.3	16.3	18.4	21.7	24.0	22.2	(35)	
		MCDBR	22.9	23.3	24.9	24.9	24.8	21.4	19.3	18.8	20.4	21.5	23.7	20.5	(36)	
	5% WB	MCWBR	14.0	13.5	12.3	11.4	9.4	8.0	7.3	7.0	7.5	9.1	12.5	12.2	(37)	
		MCWBR	18.6	19.2	18.9	19.6	19.1	17.9	17.3	16.7	16.9	17.3	17.4	16.8	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.336	0.344	0.362	0.388	0.430	0.471	0.501	0.483	0.436	0.382	0.352	0.336	(40)	
		taud	2.517	2.498	2.460	2.367	2.293	2.247	2.170	2.225	2.341	2.470	2.486	2.542	(41)	
	Ebn at Noon	Ebn at Noon	285	292	293	287	274	262	253	257	266	276	276	279	(42)	
		Edh at Noon	28	31	35	39	43	44	48	45	38	32	29	26	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1021	1221	1617	1943	2130	1938	1891	1735	1589	1430	1142	911	(44)	
	RadStd	RadStd	72	138	140	147	122	126	121	124	130	113	78	79	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (30 neighbors)	+0.86	N/A	N/A	N/A	N/A	N/A	-40	-146	+297	+202

Nomenclature: See separate page