

PERRY FOLEY, FL, USA

WMO: 722224

Lat: 30.072N

Lon: 83.574W

Elev: 14

StdP: 101.16

Time Zone: -5.00 (NAE)

Period: 01-19

WBAN: 53862

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.3	(c) -0.1	(d) -10.4	(e) 1.5	(f) 4.4	(g) -7.5	(h) 2.0	(i) 6.0	(j) 10.1	(k) 19.2	(l) 8.8	(m) 16.2	(n) 0.9	(o) 300	(p) 0.356

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	34.4	24.9	33.6	24.8	32.8	24.7	27.1	31.1	26.6	30.8	26.1	30.4	3.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.1	21.6	28.9	25.4	20.6	28.5	24.9	20.1	28.2	85.0	30.9	82.6	30.7	80.7	30.6	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.2	7.2	5.9	-5.0	36.5	2.5	0.9	-6.8	37.1	-8.2	37.7	-9.6	38.2	-11.4	38.8		
			-6.3	27.8	2.2	0.7	-7.9	28.3	-9.1	28.7	-10.4	29.1	-12.0	29.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.6	12.0	13.8	16.6	19.9	23.8	26.9	27.6	27.6	26.2	21.8	16.4	13.7
	DBStd	6.73	5.39	4.85	4.11	3.16	2.63	1.51	1.21	1.38	2.06	4.02	4.48	5.31
	HDD10.0	93	43	17	4	0	0	0	0	0	0	0	5	24
	HDD18.3	714	205	138	82	21	2	0	0	0	0	18	88	161
	CDD10.0	3948	103	124	208	298	427	507	547	547	487	365	197	139
	CDD18.3	1527	7	12	27	68	171	257	288	288	237	124	29	17
	CDH23.3	13981	34	67	216	612	1640	2438	2839	2756	2101	990	213	76
	CDH26.7	5447	1	6	24	123	634	1064	1243	1143	873	301	29	4
Wind	WSAvg	2.3	2.6	2.6	2.8	2.7	2.4	2.1	1.9	1.7	2.0	2.1	2.2	2.4
Precipitation	PrecAvg	1326	112	90	118	72	69	168	190	191	115	73	54	68
	PrecMax	1740	360	285	400	200	193	433	359	562	347	261	126	158
	PrecMin	849	23	16	6	11	4	71	87	79	14	6	0	23
	PrecStd	270	77	63	84	51	49	86	69	105	72	69	34	36
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.1	27.7	28.9	31.1	34.4	35.8	35.3	35.3	34.5	32.5	29.2	27.2
		MCWB	19.4	19.8	18.8	20.7	22.4	24.3	25.2	25.5	24.8	23.7	22.3	20.6
	2%	DB	24.1	25.5	27.3	29.1	32.6	34.0	34.0	34.0	33.3	31.1	27.4	25.5
		MCWB	18.9	19.1	19.1	20.2	22.1	24.4	25.2	25.7	24.4	23.0	21.0	20.0
	5%	DB	22.5	23.6	26.0	28.0	31.4	32.9	33.0	32.9	32.4	29.8	26.0	23.8
		MCWB	17.9	17.9	18.6	19.9	21.9	24.5	25.2	25.7	24.1	22.0	19.7	20.0
	10%	DB	20.7	22.1	24.1	27.1	30.2	32.0	32.3	32.1	31.4	28.4	24.1	22.3
		MCWB	17.2	17.3	17.5	19.4	21.7	24.4	25.3	25.6	24.0	21.9	18.8	19.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.5	21.9	22.4	23.7	25.3	27.6	27.9	27.8	26.8	25.8	24.6	23.0
		MCDB	23.7	24.8	25.1	27.1	29.9	31.1	31.0	32.0	31.2	29.1	27.1	24.7
	2%	WB	20.3	20.7	21.2	22.8	24.5	26.6	27.0	26.9	26.0	24.9	23.1	21.8
		MCDB	22.6	23.8	24.1	26.5	29.1	30.9	30.7	31.3	30.5	28.5	25.7	23.8
	5%	WB	19.0	19.7	20.3	21.9	23.9	25.8	26.5	26.5	25.6	24.2	21.6	20.8
		MCDB	21.4	22.7	23.6	25.6	28.4	30.3	30.6	30.9	30.0	27.7	23.9	22.9
	10%	WB	17.7	18.4	19.3	21.1	23.3	25.3	25.9	26.0	25.1	23.4	20.2	19.5
		MCDB	19.8	20.9	22.8	24.7	27.7	29.7	30.2	30.3	29.4	26.7	23.3	21.6
Mean Daily Temperature Range	5% DB	MDBR	12.6	12.9	13.3	13.1	12.3	10.0	9.6	9.1	10.2	12.0	13.3	12.4
		MCDBR	12.7	13.0	13.8	13.9	13.8	11.9	10.7	10.5	11.4	11.9	13.2	11.4
		MCWBR	7.8	7.5	6.9	6.3	5.2	4.4	4.1	3.9	4.2	5.0	6.9	6.8
	5% WB	MCDBR	10.4	10.7	10.5	10.9	10.6	10.0	9.6	9.3	9.4	9.6	9.7	9.3
		MCWBR	7.3	7.4	6.5	6.4	4.7	4.3	4.2	4.0	3.9	4.8	6.5	6.6
Clear-Sky Solar Irradiance	taub		0.336	0.344	0.362	0.388	0.430	0.471	0.501	0.483	0.436	0.382	0.352	0.336
	taud		2.517	2.498	2.460	2.367	2.293	2.247	2.170	2.225	2.341	2.470	2.486	2.542
	Ebn at Noon		898	922	924	905	864	825	798	810	839	869	871	880
	Edh at Noon		89	98	109	123	134	139	150	141	121	100	91	83
All-Sky Solar Radiation	RadAvg		3.22	3.85	5.10	6.13	6.71	6.11	5.96	5.47	5.01	4.51	3.60	2.87
	RadStd		0.23	0.44	0.44	0.46	0.39	0.40	0.38	0.39	0.41	0.35	0.25	0.25

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)		+0.48	N/A	N/A	N/A	N/A	N/A	-22	-81	+165	+112

Nomenclature: See separate page