

WHITING FIELD NAS NORTH, FL, USA

WMO: 722226

Lat: 30.717N

Lon: 87.017W

Elev: 61

StdP: 100.60

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 93841

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.4	-0.6	-11.5	1.4	2.1	-8.7	1.8	4.0	10.8	14.0	9.3	14.8	2.5	0	0.378

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	35.0	24.9	33.9	24.8	32.9	24.6	26.9	31.5	26.5	31.1	26.0	30.4	3.0	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.8	21.3	29.0	25.2	20.5	28.6	24.8	19.9	28.2	84.9	31.6	82.5	31.0	80.6	30.6	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.8	7.8	6.9	-6.1	36.9	1.9	1.6	-7.5	38.0	-8.6	39.0	-9.7	39.9	-11.1	41.0
			-7.1	28.0	2.2	0.7	-8.7	28.5	-10.0	28.9	-11.3	29.3	-12.9	29.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.8	10.3	13.1	16.0	19.2	23.5	26.8	27.6	27.5	25.7	20.4	15.0	12.6
	DBStd	7.16	5.29	5.18	4.72	3.38	2.79	2.02	1.40	1.60	2.10	3.92	4.46	5.38
	HDD10.0	140	61	27	9	0	0	0	0	0	0	0	9	34
	HDD18.3	875	253	157	100	31	3	0	0	0	0	26	117	189
	CDD10.0	3733	71	113	195	276	419	503	545	543	471	322	159	116
	CDD18.3	1426	4	10	28	56	163	253	287	284	221	89	18	12
	CDH23.3	12781	6	34	167	414	1459	2464	2794	2736	1849	707	108	42
	CDH26.7	5145	0	1	21	67	538	1098	1228	1221	761	191	9	10
Wind	WSAvg	2.8	3.2	3.3	3.5	3.3	2.8	2.4	2.2	2.1	2.2	2.7	2.8	3.0
Precipitation	PrecAvg	1637	137	131	151	104	120	189	198	161	134	85	100	119
	PrecMax	2197	399	249	330	321	296	693	453	253	496	224	221	238
	PrecMin	926	21	36	23	9	1	41	50	70	14	0	10	27
	PrecStd	317	80	59	69	78	69	122	96	52	90	62	59	59
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.2	26.4	28.8	30.0	34.5	36.8	35.6	36.6	34.8	31.5	27.8	26.0
		MCWB	20.1	18.8	19.1	21.0	22.5	24.3	25.7	25.4	24.0	22.9	21.2	19.4
	2%	DB	22.6	24.2	27.0	28.4	32.4	34.7	34.3	34.6	33.3	30.1	26.0	24.1
		MCWB	18.7	18.8	19.0	20.0	22.3	24.6	25.4	25.4	23.9	21.9	20.0	20.2
	5%	DB	21.1	22.5	25.3	27.2	31.0	33.4	33.3	33.4	32.2	28.9	24.4	22.8
		MCWB	18.2	18.2	18.4	19.8	22.4	24.5	25.3	25.2	23.8	21.3	19.0	20.0
	10%	DB	19.1	21.1	23.5	25.9	29.7	32.1	32.3	32.3	31.1	27.5	22.9	21.1
		MCWB	16.2	17.8	17.9	19.4	22.0	24.4	25.2	25.0	23.7	20.9	18.4	18.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.2	21.9	22.6	24.0	25.5	27.3	27.5	28.0	26.8	25.6	23.6	23.3
		MCDB	22.7	23.3	24.7	27.4	29.3	31.6	32.5	32.5	30.8	28.9	25.4	24.7
	2%	WB	20.1	20.9	21.4	23.0	24.6	26.4	26.8	27.1	25.9	24.5	22.2	21.7
		MCDB	21.8	22.4	23.7	25.5	28.7	30.8	31.7	31.7	30.0	27.5	23.9	22.9
	5%	WB	18.8	19.9	20.5	22.1	24.0	25.8	26.4	26.5	25.3	23.7	20.8	20.4
		MCDB	20.5	21.6	23.0	24.7	28.1	30.4	31.1	31.1	29.3	26.6	23.2	21.9
	10%	WB	17.1	18.6	19.5	21.2	23.3	25.3	25.8	25.8	24.7	22.6	19.5	19.1
		MCDB	18.6	20.5	22.3	24.2	27.5	30.0	30.3	30.2	28.7	25.6	22.1	20.9
Mean Daily Temperature Range	5% DB	MDBR	11.7	11.9	12.3	12.0	11.8	10.3	9.8	9.8	10.5	12.1	12.8	11.1
		MCDBR	11.2	11.5	12.4	12.7	13.0	12.0	11.0	11.3	11.8	12.6	12.9	10.8
		MCWBR	8.0	7.1	6.2	6.0	5.1	4.2	4.1	4.3	4.5	6.0	7.8	7.7
	5% WB	MCDBR	9.8	9.2	9.8	9.6	10.4	10.3	9.9	9.9	9.6	9.5	11.0	9.4
		MCWBR	8.5	7.2	6.2	6.0	4.8	4.2	4.3	4.3	4.4	5.7	8.3	8.1
Clear-Sky Solar Irradiance	taub	0.328	0.344	0.368	0.397	0.435	0.466	0.513	0.499	0.440	0.380	0.352	0.336	
	taud	2.546	2.501	2.430	2.351	2.279	2.249	2.134	2.167	2.306	2.452	2.471	2.530	
	Ebn at Noon	906	919	916	896	859	829	788	796	833	868	866	875	
	Edh at Noon	85	97	112	125	135	139	155	149	125	101	91	83	
All-Sky Solar Radiation	RadAvg	3.05	3.63	4.93	5.96	6.59	6.25	5.92	5.51	5.14	4.52	3.46	2.67	
	RadStd	0.22	0.48	0.40	0.48	0.37	0.50	0.39	0.40	0.32	0.46	0.30	0.26	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (39 neighbors)	+0.44	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+154	+97

Nomenclature: See separate page