

MOBILE, AL, USA

WMO: 722230

Lat: 30.688N

Lon: 88.246W

Elev: 66

StdP: 100.54

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13894

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.5	(c) -0.6	(d) -11.1	(e) 1.5	(f) 1.4	(g) -8.5	(h) 1.8	(i) 4.0	(j) 10.5	(k) 15.1	(l) 9.2	(m) 13.0	(n) 3.1	(o) 0	(p) 0.394

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 9.2	(c) 34.6	(d) 25.1	(e) 33.5	(f) 24.9	(g) 32.6	(h) 24.7	(i) 26.8	(j) 31.5	(k) 26.3	(l) 30.8	(m) 25.8	(n) 30.1	(o) 3.0	(p) 300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.7	21.1	28.7	25.2	20.5	28.2	24.7	19.9	27.8	84.2	31.4	82.0	30.7	80.0	30.3	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.9	(b) 7.9	(c) 7.1	(e) -6.1	(f) 36.2	(g) 2.2	(h) 1.5	(i) -7.7	(j) 37.2	(k) -9.0	(l) 38.1	(m) -10.2	(n) 39.0	(o) -11.8	(p) 40.0		
(4) 8.9	(5) 7.9	(6) 7.1	(7) -6.1	(8) 36.2	(9) 2.2	(10) 1.5	(11) -7.7	(12) 37.2	(13) -9.0	(14) 38.1	(15) -10.2	(16) 39.0	(17) -11.8	(18) 40.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.8	10.6	12.8	16.0	19.5	23.6	26.7	27.6	27.6	25.6	20.5	15.2	11.9
	DBStd	7.25	5.61	5.22	4.60	3.47	2.72	1.76	1.41	1.54	2.36	4.03	4.62	5.37
	HDD10.0	151	63	28	8	0	0	0	0	0	0	0	9	42
	HDD18.3	889	246	165	98	28	3	0	0	0	1	26	115	208
	CDD10.0	3744	80	106	194	286	422	500	547	547	468	327	164	102
	CDD18.3	1439	5	9	26	63	166	250	289	289	219	94	21	9
	CDH23.3	12621	6	24	121	409	1414	2369	2812	2806	1857	693	95	17
	CDH26.7	4809	0	0	9	58	476	985	1191	1194	717	170	8	0
Wind	WSAvg	3.1	3.6	3.8	3.8	3.6	3.1	2.6	2.3	2.3	2.7	3.0	3.1	3.4
Precipitation	PrecAvg	1672	139	114	156	138	126	153	209	166	137	85	115	132
	PrecMax	2152	408	260	400	449	378	452	577	325	552	241	297	368
	PrecMin	1072	25	19	16	16	9	42	98	28	50	1	34	32
	PrecStd	295	91	62	87	105	82	89	93	77	107	65	73	70
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.1	25.7	27.9	29.7	33.6	35.7	35.7	35.9	34.7	31.7	27.8	25.1
		MCWB	19.4	19.5	18.9	21.0	22.9	24.5	25.7	25.6	24.6	23.2	20.5	20.9
	2%	DB	22.5	23.9	26.2	28.3	31.8	33.9	34.1	34.3	33.0	30.0	25.7	23.5
		MCWB	18.9	19.1	19.0	20.5	22.5	24.3	25.4	25.5	24.1	22.2	20.5	20.4
	5%	DB	21.1	22.2	24.7	27.1	30.6	32.6	33.1	33.2	31.9	28.6	24.3	22.2
		MCWB	18.1	18.5	18.3	19.9	22.3	24.3	25.2	25.3	23.9	21.7	19.7	19.6
	10%	DB	19.5	20.8	23.0	25.9	29.4	31.5	32.0	32.2	30.7	27.2	22.9	20.6
		MCWB	17.2	17.7	18.0	19.3	21.9	24.1	25.1	25.0	23.6	21.0	18.7	18.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.1	21.9	22.4	23.8	25.4	26.9	27.7	27.8	26.8	25.6	23.8	23.0
		MCDB	22.6	23.4	24.4	26.8	29.9	31.5	32.3	33.0	30.8	28.7	25.3	23.8
	2%	WB	20.0	20.8	21.2	22.9	24.6	26.2	26.8	26.9	25.8	24.7	22.2	21.3
		MCDB	21.5	22.3	23.4	25.6	28.6	30.7	31.4	31.6	29.8	27.7	23.9	22.6
	5%	WB	18.9	19.8	20.3	22.1	24.0	25.6	26.3	26.3	25.3	23.9	21.0	20.0
		MCDB	20.6	21.5	22.6	24.7	27.6	29.9	30.8	30.8	29.2	26.6	23.1	21.5
	10%	WB	17.6	18.5	19.4	21.3	23.5	25.2	25.8	25.8	24.8	22.9	19.8	18.7
		MCDB	19.2	20.2	21.8	24.0	27.1	29.3	30.1	30.0	28.5	25.4	22.1	20.4
Mean Daily Temperature Range	5% DB	MDBR	11.1	11.0	11.4	11.3	11.0	9.6	9.2	9.3	9.8	11.3	11.8	10.6
		MCDBR	10.3	10.3	11.3	11.4	11.8	11.0	10.5	10.6	10.9	11.4	11.3	9.9
		MCWBR	7.1	6.3	5.5	5.1	4.4	3.8	3.7	3.6	4.0	5.1	6.5	7.1
	5% WB	MCDBR	8.9	8.4	9.1	8.8	9.3	9.4	9.4	9.3	9.1	8.7	9.6	9.0
		MCWBR	7.6	6.5	5.9	4.9	4.0	3.8	3.8	3.7	3.8	4.8	7.0	7.6
Clear-Sky Solar Irradiance	taub	0.328	0.345	0.369	0.398	0.433	0.460	0.510	0.499	0.443	0.379	0.350	0.336	
	taud	2.552	2.507	2.433	2.355	2.287	2.263	2.145	2.170	2.295	2.460	2.483	2.538	
	Ebn at Noon	906	919	915	896	861	833	790	795	830	869	869	876	
	Edh at Noon	85	97	111	125	134	137	154	148	126	100	90	82	
All-Sky Solar Radiation	RadAvg	3.02	3.58	4.83	5.90	6.51	6.26	5.92	5.58	5.20	4.52	3.45	2.65	
	RadStd	0.24	0.49	0.39	0.47	0.36	0.47	0.40	0.39	0.33	0.47	0.30	0.24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+135	+77
(47) Regional (33 neighbors)		+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+140	+91

Nomenclature: See separate page