

SOUTHLAND FIELD, LA, USA

WMO: 722248

Lat: 30.131N

Lon: 93.376W

Elev: 3

StdP: 101.29

Time Zone: -6.00 (NAC)

Period: 07-19

WBAN: 00359

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.2	1.1	-7.1	2.1	3.3	-4.1	2.7	6.8	10.3	14.7	9.1	15.8	2.3	340	0.398

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.2	35.9	26.1	34.8	25.8	33.7	25.7	28.7	32.1	27.8	31.0	27.3	30.5	3.2	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.8	23.8	29.9	27.3	23.1	29.3	26.3	21.8	28.5	92.5	32.0	88.3	32.0	85.7	29.5	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.1	8.2	7.3	-3.3	37.2	2.4	1.5	-4.9	38.2	-6.3	39.1	-7.6	39.9	-9.4	41.0		
			-4.5	28.6	2.1	1.1	-6.0	29.4	-7.3	30.0	-8.5	30.6	-10.0	31.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.1	11.5	14.0	17.5	20.7	24.9	28.2	28.6	29.0	27.0	22.1	16.4	13.5
	DBStd	7.26	5.31	5.46	4.53	3.59	2.70	1.67	1.75	1.48	2.09	4.15	5.03	5.11
	HDD10.0	105	46	23	5	1	0	0	0	0	0	8	22	
	HDD18.3	728	219	138	72	19	2	0	0	0	0	14	95	168
	CDD10.0	4169	92	135	236	321	461	546	576	589	509	374	201	130
	CDD18.3	1751	8	17	44	89	204	296	317	331	259	129	38	17
	CDH23.3	17389	13	37	171	549	1785	3347	3696	3897	2510	1146	186	53
CDH26.7	7037	0	1	8	71	551	1494	1679	1839	1009	363	22	1	
Wind	WSAvg	2.9	3.2	3.7	3.6	3.9	3.3	2.7	2.1	2.0	2.1	2.7	2.9	3.2
Precipitation	PrecAvg	1517	154	99	100	108	116	155	164	125	134	129	117	126
	PrecMax	2109	363	212	220	214	324	318	318	251	311	487	314	275
	PrecMin	962	42	18	15	12	3	25	74	23	26	32	21	62
	PrecStd	304	82	59	51	59	80	81	60	59	75	120	67	51
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.9	26.2	27.7	30.0	33.0	37.2	36.2	37.4	35.2	32.8	28.9	26.3
		MCWB	19.9	21.0	20.4	21.0	23.3	25.1	25.7	27.1	24.5	24.0	23.1	22.0
	2%	DB	23.0	24.6	26.5	28.2	32.0	35.0	35.0	36.2	33.8	31.5	27.2	25.0
		MCWB	19.0	20.4	21.1	21.8	23.4	25.8	25.7	26.8	24.9	23.8	21.9	21.6
	5%	DB	21.8	22.9	25.3	27.4	30.8	33.4	33.9	35.0	32.7	30.4	25.7	23.2
		MCWB	18.8	20.1	20.2	21.7	23.8	25.5	25.9	26.3	24.9	23.3	20.7	20.9
	10%	DB	20.1	21.9	24.0	26.4	29.8	32.6	32.9	33.7	31.9	28.8	23.9	21.8
		MCWB	17.7	19.4	19.9	21.2	23.9	25.6	25.9	26.1	24.7	22.7	20.4	20.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.9	22.5	23.0	25.0	26.9	29.3	29.2	30.2	27.6	27.3	24.6	23.7
		MCDB	23.4	24.7	25.6	26.9	28.3	31.0	31.2	33.5	30.6	29.4	26.6	25.0
	2%	WB	21.1	21.9	22.4	24.0	25.8	27.8	28.0	29.0	26.8	26.2	23.5	22.7
		MCDB	22.2	23.6	24.7	26.6	28.3	30.6	30.7	33.1	30.2	28.7	25.4	24.1
	5%	WB	20.0	21.2	21.9	23.4	25.3	27.2	27.4	28.0	26.3	25.4	22.6	21.7
		MCDB	20.9	22.4	23.9	25.9	28.4	30.3	30.4	31.8	29.7	28.2	24.5	22.9
	10%	WB	18.1	20.2	21.2	22.8	24.9	26.7	26.9	27.4	25.8	24.6	21.3	20.6
		MCDB	19.3	21.1	23.0	25.3	28.1	30.1	30.2	30.8	29.1	27.4	23.3	21.5
Mean Daily Temperature Range	5% DB	MDBR	10.6	9.6	10.0	9.8	8.9	8.7	8.8	9.2	9.2	11.4	10.9	9.8
		MCDBR	11.0	9.5	9.1	9.8	9.8	10.0	10.0	11.2	10.0	10.6	10.5	10.2
		MCWBR	7.6	6.2	5.1	4.7	3.6	3.2	3.1	3.5	3.2	4.4	5.8	6.9
	5% WB	MCDBR	8.8	7.6	7.8	8.0	7.6	8.6	8.6	9.6	8.4	8.8	8.8	9.3
		MCWBR	7.3	5.7	5.5	4.9	3.7	3.7	3.5	4.2	3.3	4.8	6.1	7.3
Clear-Sky Solar Irradiance	taub	0.341	0.358	0.376	0.430	0.467	0.502	0.500	0.487	0.458	0.383	0.368	0.351	
	taud	2.515	2.478	2.421	2.267	2.198	2.136	2.183	2.223	2.270	2.463	2.447	2.487	
	Ebn at Noon	892	907	910	867	833	799	799	807	819	867	851	859	
	Edh at Noon	89	100	113	137	147	156	148	141	130	101	94	88	
All-Sky Solar Radiation	RadAvg	2.86	3.26	4.52	5.48	6.12	6.14	5.92	5.61	5.00	4.39	3.31	2.54	
	RadStd	0.28	0.54	0.41	0.41	0.41	0.47	0.46	0.51	0.50	0.56	0.32	0.28	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (31 neighbors)	+0.32	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+105	+80

Nomenclature: See separate page