

LAWSON AAF, GA, USA

WMO: 722250

Lat: 32.332N

Lon: 84.989W

Elev: 232

StdP: 14.57

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13829

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.2	25.6	9.9	9.2	32.9	14.3	11.5	35.3	20.5	45.7	18.7	46.9	4.1	320	0.366

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.4	96.8	75.9	94.8	75.9	92.7	75.8	80.5	88.6	79.4	88.5	78.4	87.4	6.5	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.0	151.5	83.2	77.3	143.0	82.2	76.1	137.7	81.5	44.2	88.7	42.9	88.6	41.9	87.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.3	14.9	12.4	DB	15.2	99.4	3.5	3.3	12.6	101.8	10.6	103.7	8.6	105.6	6.0	108.0
			WB	14.2	83.1	3.5	1.9	11.7	84.5	9.6	85.6	7.6	86.7	5.0	88.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	64.7	46.2	51.1	57.1	63.6	72.1	78.7	81.1	80.6	75.6	65.7	55.2	49.0
	DBStd	14.12	9.47	9.32	8.08	6.51	5.54	3.71	3.01	3.31	4.96	7.46	8.29	9.08
	HDD50	482	190	92	28	1	0	0	0	0	0	2	38	131
	HDD65	2253	583	396	263	104	13	0	0	0	2	84	309	499
	CDD50	5864	73	122	249	408	684	862	966	947	767	489	195	102
	CDD65	2161	1	6	19	61	232	412	501	482	320	106	17	4
	CDH74	21356	11	56	281	835	2476	3960	4994	4682	2872	1013	154	22
	CDH80	9650	0	4	40	209	1005	1938	2532	2338	1285	280	19	0
Wind	WSAvg	4.6	5.4	5.6	5.9	5.2	4.4	3.9	3.7	3.7	4.1	4.3	4.4	4.8
Precipitation	PrecAvg	49.5	4.4	4.9	5.7	4.1	3.2	4.1	5.2	4.5	3.3	2.7	3.8	4.3
	PrecMax	67.6	8.2	14.8	13.0	9.8	9.2	7.8	10.9	9.0	10.7	7.6	10.9	16.1
	PrecMin	35.2	2.0	1.2	0.6	0.7	0.5	0.9	2.6	2.0	0.6	0.5	1.0	1.8
	PrecStd	8.7	1.3	2.5	3.1	2.1	1.9	2.0	2.2	1.9	2.2	2.0	2.4	2.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.8	79.4	84.3	87.9	94.0	98.3	99.3	100.2	96.7	89.8	82.3	77.2
		MCWB	63.9	65.9	65.8	68.6	72.3	75.2	75.9	76.9	73.9	72.8	67.8	66.8
	2%	DB	71.4	75.2	80.6	85.0	90.8	95.3	96.3	96.4	93.4	86.0	78.6	72.8
		MCWB	62.4	63.9	64.2	67.9	72.2	75.5	76.7	76.7	73.2	70.3	65.6	65.4
	5%	DB	67.6	71.8	77.1	82.4	88.4	93.0	93.8	93.7	90.6	83.0	74.9	68.9
		MCWB	61.2	62.0	62.2	66.5	71.3	75.4	76.8	76.7	73.6	68.5	63.5	63.3
	10%	DB	63.5	68.0	73.3	79.3	86.1	90.4	91.5	91.1	87.9	80.2	71.6	65.3
		MCWB	58.1	59.9	60.1	64.9	70.3	75.3	76.9	76.6	73.4	67.4	63.2	60.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.9	70.0	69.7	73.9	76.8	80.7	84.0	84.3	79.4	77.2	72.5	70.7
		MCDB	70.9	75.0	76.2	81.0	84.6	89.2	89.0	89.6	85.4	81.8	76.3	73.4
	2%	WB	65.2	67.0	67.8	71.4	75.1	79.3	80.5	80.7	77.7	74.9	69.8	67.7
		MCDB	68.8	71.8	74.7	79.2	83.8	89.2	88.4	89.0	85.9	81.1	73.6	70.2
	5%	WB	62.5	64.7	65.9	69.7	73.9	78.1	79.3	79.4	76.5	72.8	67.1	64.8
		MCDB	66.0	69.4	73.5	77.3	83.3	87.8	88.4	88.6	84.8	78.5	72.1	67.7
	10%	WB	59.3	62.2	63.5	67.9	72.8	77.0	78.2	78.3	75.2	70.6	64.2	61.8
		MCDB	62.9	66.5	69.8	75.6	82.2	86.2	87.5	86.9	83.0	76.1	69.4	65.2
Mean Daily Temperature Range	5% DB	MDBR	24.7	25.5	26.6	27.7	25.8	22.3	21.4	21.4	22.5	25.5	26.8	23.4
		MCDBR	27.8	28.2	30.4	30.6	28.0	26.4	24.5	25.0	26.6	27.7	29.1	26.0
		MCWBR	19.0	17.0	15.3	14.7	11.4	9.5	8.3	8.6	9.8	13.1	16.7	17.8
	5% WB	MCDBR	22.7	22.9	24.5	24.2	23.4	21.7	21.5	21.1	20.9	20.2	21.9	20.9
		MCWBR	17.7	16.3	14.3	13.6	10.7	9.7	9.1	8.9	9.3	11.7	15.4	16.4
Clear-Sky Solar Irradiance	taub	0.327	0.329	0.357	0.389	0.440	0.485	0.521	0.523	0.428	0.376	0.352	0.330	
	taud	2.518	2.506	2.446	2.345	2.244	2.174	2.082	2.069	2.325	2.446	2.460	2.521	
	Ebn at Noon	284	295	293	286	271	257	247	245	266	274	272	277	
	Edh at Noon	27	30	35	40	44	48	52	52	38	32	29	26	
All-Sky Solar Radiation	RadAvg	906	1088	1445	1800	1990	1942	1913	1741	1540	1320	1015	778	
	RadStd	51	128	121	130	150	151	118	105	137	162	88	83	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (42 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.86	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+286	+193

Nomenclature: See separate page