

RUSTON, LA, USA

WMO: 722251

Lat: 32.514N

Lon: 92.588W

Elev: 95

StdP: 100.19

Time Zone: -6.00 (NAC)

Period: 06-19

WBAN: 53958

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.1	-2.4	-11.9	1.4	1.8	-8.7	1.8	4.1	8.3	16.4	7.6	14.3	1.1	20	0.369

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	37.2	23.9	35.7	23.9	34.1	24.0	26.7	31.5	26.2	31.1	25.7	30.5	2.5	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.6	21.1	28.1	25.1	20.4	27.8	24.6	19.8	27.6	83.7	31.7	81.6	31.0	79.5	30.7	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.5	6.4	5.4	-7.7	38.2	2.6	1.6	-9.5	39.4	-11.1	40.3	-12.6	41.2	-14.5	42.4		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			-8.0	27.7	2.5	1.0	-9.8	28.5	-11.3	29.1	-12.6	29.6	-14.4	30.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.4	8.0	10.3	14.2	17.7	22.4	26.5	27.7	25.0	18.7	12.6	9.6		
		DBStd	8.35	5.80	6.04	5.38	4.10	3.51	2.35	2.44	3.11	4.70	5.29	5.55		
		HDD10.0	311	109	64	22	3	0	0	0	0	2	32	78		
		HDD18.3	1287	322	232	147	59	11	0	0	1	54	182	278		
		CDD10.0	3386	48	74	154	234	383	496	550	449	273	112	64		
		CDD18.3	1321	3	8	20	41	136	246	292	291	199	67	6		
		CDH23.3	13088	8	38	143	352	1162	2543	3181	3101	1856	616	22		
		CDH26.7	5953	0	4	19	56	407	1199	1605	1591	856	206	9		
(14)	Wind	WSAvg	1.9	2.2	2.5	2.5	2.4	2.0	1.8	1.5	1.4	1.3	1.7	1.9	2.2	(14)
(15)	Precipitation	PrecAvg	1436	146	124	130	132	122	113	99	86	98	111	116	135	(15)
(16)		PrecMax	1881	379	211	240	462	261	306	239	195	247	551	306	248	(16)
(17)		PrecMin	951	15	17	28	58	23	25	27	23	13	9	30	13	(17)
(18)		PrecStd	254	83	63	56	89	66	66	52	45	58	119	65	57	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	24.6	27.2	29.1	29.9	32.7	37.5	37.9	40.0	36.5	33.0	28.0	25.9		
(20)		MCWB	17.5	18.4	19.4	20.4	22.5	22.8	24.3	25.2	23.1	21.3	20.9	21.2		
(21)		DB	22.3	24.1	26.8	28.0	31.5	36.0	37.1	37.2	34.8	31.1	25.2	23.3		
(22)		MCWB	17.5	18.3	18.3	19.2	22.3	23.3	24.2	24.4	23.1	21.4	19.0	19.7		
(23)		DB	20.0	22.2	25.0	27.2	30.6	33.8	35.4	35.1	33.0	29.1	23.0	21.3		
(24)		MCWB	16.2	17.1	17.4	18.8	21.9	24.2	24.6	24.1	23.6	21.1	18.5	18.6		
(25)		DB	17.7	20.1	22.8	25.7	29.2	32.4	33.8	33.5	31.9	27.1	21.4	19.5		
(26)		MCWB	14.4	16.4	16.8	18.2	21.4	23.8	24.5	24.1	23.4	20.0	17.8	17.2		
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	20.3	20.7	21.6	23.0	25.1	26.9	27.2	27.7	26.6	24.8	22.5	22.2		
(28)		MCDB	22.3	24.3	24.7	26.6	29.4	31.1	32.3	32.0	30.9	28.0	25.5	24.9		
(29)		WB	18.9	19.7	20.2	21.9	24.1	26.1	26.6	26.8	25.7	23.9	21.4	20.7		
(30)		MCDB	21.3	22.3	24.1	25.2	28.5	30.6	31.8	31.4	30.1	27.9	23.9	22.5		
(31)		WB	17.4	18.6	19.2	21.0	23.5	25.5	26.1	26.1	25.1	23.0	20.2	19.5		
(32)		MCDB	18.6	21.3	22.9	24.1	27.8	29.9	31.3	30.9	29.4	26.6	22.3	21.0		
(33)		WB	15.2	17.2	18.4	20.0	22.8	25.0	25.6	25.6	24.3	22.0	18.6	17.6		
(34)		MCDB	17.0	19.6	21.7	23.5	27.0	29.3	30.8	30.5	28.9	24.8	21.0	18.8		
(35)	Mean Daily Temperature Range	MDBR	11.1	11.3	12.4	12.6	11.5	11.1	11.0	11.3	11.9	13.2	12.7	10.9		
(36)		5% DB	13.0	12.8	13.4	13.6	12.3	12.9	12.8	13.1	13.4	14.2	13.2	12.2		
(37)		MCWBR	8.6	7.6	6.5	6.1	4.4	3.7	3.0	3.5	4.2	6.0	7.8	8.5		
(38)		5% WB	10.9	10.3	10.7	10.6	10.4	10.3	10.8	10.9	10.9	11.2	10.2	10.7		
(39)	Clear-Sky Solar Irradiance	taub	0.325	0.340	0.364	0.402	0.430	0.472	0.487	0.484	0.428	0.364	0.346	0.329		
(40)		taud	2.525	2.481	2.419	2.307	2.285	2.212	2.196	2.202	2.333	2.481	2.485	2.516		
(41)		Ebn at Noon	897	916	915	889	862	822	807	805	839	877	863	871		
(42)		Edh at Noon	85	97	112	130	134	144	146	143	120	96	88	82		
(44)	All-Sky Solar Radiation	RadAvg	2.67	3.04	4.29	5.36	5.95	6.31	6.22	5.82	5.01	4.09	2.98	2.33		
(45)		RadStd	0.26	0.52	0.35	0.38	0.40	0.45	0.41	0.49	0.47	0.57	0.32	0.30		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (25 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page