

COLUMBUS, GA, USA

WMO: 722255

Lat: 32.516N

Lon: 84.942W

Elev: 392

StdP: 14.49

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 93842

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.7	29.4	6.4	7.7	33.9	10.8	9.7	38.0	20.9	49.1	19.6	49.1	5.3	330	0.385

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.0	96.1	74.5	94.1	74.3	92.3	74.1	78.2	89.2	77.3	87.9	76.5	86.5	7.9	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.3	134.8	82.2	74.5	130.7	81.2	73.7	127.3	80.4	41.7	89.2	40.8	87.8	40.1	86.9	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
18.4	16.2	13.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			19.2	98.7	4.4	3.0	16.0	100.9	13.4	102.6	11.0	104.3	7.8	106.5
			16.4	79.7	4.2	1.1	13.4	80.5	11.0	81.2	8.7	81.8	5.6	82.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.2	47.8	52.0	58.5	65.7	73.7	79.8	82.3	81.8	77.1	67.2	57.0	50.5	(6)
	DBStd	14.02	9.53	9.01	8.25	6.42	5.48	3.77	3.12	3.34	4.98	7.13	7.86	8.75	(7)
	HDD50	389	159	77	23	1	0	0	0	0	0	1	24	104	(8)
	HDD65	1991	537	371	229	69	7	0	0	0	1	62	260	455	(9)
	CDD50	6295	90	132	286	471	735	893	1002	987	813	533	234	119	(10)
	CDD65	2421	2	7	28	89	276	443	537	522	364	129	20	4	(11)
	CDH74	23372	6	30	250	822	2598	4348	5664	5367	3225	942	110	10	(12)
	CDH80	9907	0	2	33	179	978	1981	2685	2482	1325	231	11	0	(13)
(14) Wind	WSAvg	5.7	6.3	6.4	6.7	6.4	5.8	5.3	5.1	4.9	5.5	5.3	5.3	5.8	(14)
(15) Precipitation	PrecAvg	49.5	4.5	4.5	5.8	4.1	3.7	4.0	5.2	3.9	3.1	2.2	3.7	4.5	(15)
	PrecMax	73.2	8.3	9.4	13.3	11.4	7.9	10.8	13.2	10.1	6.3	8.1	11.6	9.4	(16)
	PrecMin	26.4	0.7	1.2	0.6	0.1	0.2	0.5	2.0	0.8	0.2	0.0	0.8	1.6	(17)
	PrecStd	10.1	2.0	2.2	2.8	2.6	2.0	2.4	2.5	2.2	1.6	1.7	2.2	2.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.6	77.9	83.7	87.3	93.7	97.3	98.5	98.9	96.0	89.3	81.6	75.4	(19)
		MCWB	64.2	64.8	64.4	68.2	71.7	74.3	75.0	75.1	73.0	72.7	66.4	64.6	(20)
	2%	DB	70.2	73.6	79.9	84.5	90.6	94.4	95.9	95.6	93.0	85.3	77.1	71.7	(21)
		MCWB	61.5	61.8	63.2	66.6	71.1	73.8	74.9	75.0	72.5	68.9	64.7	63.3	(22)
	5%	DB	66.6	70.3	76.7	82.0	88.1	92.3	93.7	93.2	90.2	82.6	73.8	68.2	(23)
		MCWB	59.6	60.0	61.4	65.3	70.3	73.4	75.2	74.9	71.9	67.5	63.0	62.0	(24)
	10%	DB	63.1	66.7	73.1	79.2	85.6	89.9	91.6	90.9	87.5	79.6	70.7	64.7	(25)
		MCWB	57.5	58.0	59.6	63.7	69.0	73.0	75.0	74.6	71.7	66.2	61.7	59.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.5	67.8	68.9	72.1	76.0	78.6	79.8	79.3	77.0	75.3	71.8	68.4	(27)
		MCDB	70.7	73.7	75.8	81.1	87.2	90.4	91.0	90.7	86.9	83.2	75.1	71.6	(28)
	2%	WB	64.2	65.3	66.6	70.2	74.2	77.3	78.2	78.0	75.9	73.3	68.8	65.9	(29)
		MCDB	68.4	71.0	73.8	78.8	84.4	88.4	89.2	88.7	85.2	80.3	72.9	68.8	(30)
	5%	WB	61.7	63.2	64.7	68.6	72.9	76.2	77.4	77.2	75.0	71.5	66.3	63.2	(31)
		MCDB	65.4	68.1	72.3	76.7	82.6	86.6	88.2	87.4	83.8	77.6	71.5	67.1	(32)
	10%	WB	58.7	60.5	62.7	67.0	71.5	75.2	76.5	76.4	74.0	69.8	63.7	60.5	(33)
		MCDB	62.7	65.2	70.3	75.1	81.3	85.0	86.6	86.0	82.2	76.0	69.0	64.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	19.6	20.4	21.6	22.0	20.5	18.3	18.0	17.5	18.0	20.0	20.8	18.5	(35)
		MCDBR	21.8	22.4	25.1	24.6	22.6	21.6	20.5	20.5	21.7	22.3	22.7	20.0	(36)
	5% WB	MCWBR	14.3	13.2	11.4	9.9	7.3	6.2	5.5	5.6	6.4	8.9	12.4	13.1	(37)
		MCWBR	17.8	18.2	19.9	18.8	18.9	18.0	17.9	17.4	16.6	15.9	17.2	16.2	(38)
(40) Clear-Sky Solar Irradiance	taub		0.324	0.326	0.354	0.387	0.439	0.481	0.519	0.522	0.425	0.374	0.349	0.327	(40)
		taud	2.520	2.508	2.449	2.345	2.242	2.179	2.083	2.067	2.327	2.447	2.461	2.523	(41)
	Ebn at Noon		285	296	293	286	271	258	248	245	267	275	272	277	(42)
		Edh at Noon	27	30	34	40	44	47	52	52	38	32	29	26	(43)
(44) All-Sky Solar Radiation	RadAvg		898	1080	1432	1789	1980	1941	1912	1735	1530	1311	1005	770	(44)
	RadStd		49	126	120	126	152	153	117	103	140	165	88	83	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+241	N/A
(47) Regional (42 neighbors)	+0.86	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+286	+193

Nomenclature: See separate page