

OKEECHOBEE COUNTY AP, FL, USA

WMO: 722261

Lat: 27.267N

Lon: 80.850W

Elev: 33

StdP: 14.68

Time Zone: -5.00 (NAE)

Period: 07-19

WBAN: 00360

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	36.4	41.0	27.1	21.0	45.6	31.6	26.0	50.2	20.5	65.7	18.5	64.6	3.5	340	0.315

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.6	93.4	77.8	91.3	77.3	90.6	77.1	82.2	88.4	80.8	87.0	79.6	86.3	7.3	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.0	161.2	85.2	79.1	151.3	84.2	77.4	142.6	82.9	45.7	90.0	44.2	87.1	43.1	85.8	86.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.5	15.3	12.7	31.8	95.0	2.2	2.7	30.2	97.0	28.8	98.6	27.6	100.1	26.0	102.1		
(5)			29.1	81.3	2.5	2.1	27.3	82.9	25.9	84.1	24.5	85.3	22.7	86.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	72.8	60.7	64.8	66.6	72.4	76.1	80.0	81.1	81.4	80.0	75.7	68.8	65.6
	DBStd	8.83	7.89	7.59	6.52	4.47	3.73	2.49	2.53	3.42	3.21	5.40	6.16	7.48
	HDD50	22	14	4	0	0	0	0	0	0	0	0	0	4
	HDD65	456	173	89	61	5	0	0	0	0	0	8	34	86
	CDD50	8348	347	418	515	671	810	901	966	972	900	796	564	488
	CDD65	3306	41	83	111	226	345	451	501	507	450	339	148	104
	CDH74	28433	318	669	969	2067	3171	3963	4618	4702	3759	2598	984	615
	CDH80	10508	26	109	187	621	1243	1710	1978	2015	1510	849	184	76
Wind	WSAvg	5.0	5.6	5.5	5.9	5.9	5.3	4.4	3.7	4.0	4.1	5.2	5.0	5.2
Precipitation	PrecAvg	54.0	2.4	2.4	3.3	3.0	4.1	7.7	6.7	7.8	7.2	4.8	2.4	2.4
	PrecMax	71.8	8.8	6.9	9.9	7.6	11.2	17.9	11.1	16.8	21.0	14.3	6.9	6.1
	PrecMin	37.0	0.0	0.2	0.3	0.7	0.6	2.8	2.2	2.1	3.1	0.3	0.1	0.4
	PrecStd	8.8	2.2	1.5	2.6	1.6	2.6	3.3	2.4	3.1	3.3	3.5	1.9	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.2	86.3	88.0	90.3	93.4	95.2	95.3	96.7	95.0	90.9	87.7	84.3
		MCWB	70.5	71.5	72.5	71.6	73.8	75.9	80.3	81.0	81.1	77.8	75.2	73.6
	2%	DB	80.8	82.3	84.1	88.1	90.8	91.5	91.4	93.2	91.2	89.6	84.3	81.8
		MCWB	69.4	70.4	70.5	71.4	72.6	76.6	77.8	79.1	78.8	77.7	73.9	72.3
	5%	DB	78.5	81.2	81.7	86.1	89.6	90.6	90.7	91.0	90.1	87.7	81.8	80.7
		MCWB	67.2	68.9	68.6	70.5	72.6	76.4	77.8	78.6	78.3	76.5	71.6	71.4
	10%	DB	74.7	78.9	80.5	83.7	86.5	89.5	89.8	89.9	88.1	85.7	80.5	77.5
		MCWB	65.5	66.9	67.9	70.0	72.6	76.3	77.7	78.5	77.2	75.3	70.3	68.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.6	74.5	75.3	76.2	78.2	80.9	82.6	84.1	83.5	80.7	76.6	75.4
		MCDB	79.6	82.1	83.5	85.1	86.5	89.1	91.4	90.8	90.0	86.1	83.1	81.5
	2%	WB	71.9	72.6	73.2	75.1	76.6	79.2	80.9	82.7	81.6	79.1	75.2	74.0
		MCDB	77.8	79.7	80.3	83.3	85.6	87.6	88.4	88.6	86.9	84.8	82.5	80.2
	5%	WB	70.0	71.2	71.6	73.8	75.4	78.2	79.8	81.0	80.1	78.0	73.8	72.7
		MCDB	74.6	77.8	78.7	81.1	83.8	86.7	86.5	86.6	86.2	83.6	79.8	78.4
	10%	WB	68.1	69.5	69.8	72.5	74.5	77.4	78.5	79.4	78.4	76.8	72.2	71.3
		MCDB	72.4	75.3	76.0	79.9	82.7	85.9	85.7	86.3	85.1	82.9	77.7	76.0
Mean Daily Temperature Range	5% DB	MDBR	23.0	23.4	24.2	23.1	21.6	18.6	17.2	16.6	16.6	17.9	21.0	20.7
		MCDBR	23.9	23.1	24.0	23.7	24.2	20.9	18.2	18.1	17.8	17.5	20.2	19.7
		MCWBR	13.1	11.1	11.1	9.6	8.9	7.7	6.8	6.9	6.5	7.2	9.8	10.6
	5% WB	MCDBR	20.0	20.0	21.2	19.8	19.9	18.0	16.4	16.4	16.3	15.4	17.7	17.5
		MCWBR	13.0	10.5	11.2	9.3	8.4	7.8	7.1	7.0	6.6	7.0	8.8	10.1
Clear-Sky Solar Irradiance	taub	0.347	0.362	0.377	0.392	0.420	0.453	0.467	0.456	0.425	0.404	0.365	0.356	
	taud	2.511	2.482	2.429	2.370	2.337	2.317	2.270	2.328	2.411	2.428	2.486	2.510	
	Ebn at Noon	285	290	290	287	278	266	263	266	272	272	277	277	
	Edh at Noon	29	32	36	39	41	41	43	41	36	34	30	28	
All-Sky Solar Radiation	RadAvg	1122	1366	1662	1929	1970	1802	1788	1731	1549	1421	1183	1021	
	RadStd	77	71	98	76	149	154	119	104	76	89	56	72	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (43 neighbors)	+0.74	+1.44	N/A	N/A	N/A	N/A	-2	-52	+277	+209

Nomenclature: See separate page