

DOBBINS AFB, GA, USA

WMO: 722270

Lat: 33.917N

Lon: 84.517W

Elev: 1068

StdP: 14.14

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 13864

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.1	24.1	4.1	7.1	26.2	8.1	8.7	30.4	23.5	34.2	21.4	36.2	10.1	310	0.394

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.3	93.1	74.1	91.2	73.9	89.5	73.6	77.3	87.7	76.4	86.4	75.5	85.0	7.5	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.5	134.0	81.0	73.4	129.5	80.2	72.8	126.7	79.7	41.3	88.0	40.4	86.3	39.6	85.4	81.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.4	17.1	15.1	13.4	96.0	5.8	3.5	9.2	98.6	5.9	100.6	2.6	102.6	-1.6	105.1		
			11.4	79.1	5.5	1.2	7.5	80.0	4.3	80.7	1.3	81.4	-2.7	82.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.3	41.7	46.6	53.8	62.8	70.4	77.4	79.7	78.9	73.8	62.7	52.5	46.4
	DBStd	15.07	9.86	10.01	9.25	6.99	6.28	3.80	3.38	3.50	5.37	7.36	7.75	8.86
	HDD50	777	292	168	69	4	0	0	0	0	0	4	61	179
	HDD65	2842	722	518	360	121	30	0	0	0	5	130	378	578
	CDD50	5269	35	72	186	388	634	822	921	896	714	397	137	67
	CDD65	1859	0	2	12	56	199	372	456	431	269	57	4	1
	CDH74	16191	0	9	102	527	1608	3323	4252	3862	2078	412	17	1
	CDH80	6076	0	0	8	82	468	1314	1800	1574	744	85	1	0
Wind	WSAvg	6.4	7.8	7.9	7.9	7.1	6.1	5.6	5.5	5.1	5.0	5.8	6.0	7.0
Precipitation	PrecAvg	52.6	4.7	4.8	5.2	3.8	4.1	4.2	5.2	4.3	3.9	3.3	4.3	4.2
	PrecMax	71.4	7.7	8.3	9.5	7.7	11.1	10.1	13.8	7.7	11.7	9.5	10.5	10.2
	PrecMin	31.3	2.4	1.9	1.9	0.9	1.7	1.7	1.7	1.2	0.4	0.2	1.0	1.3
	PrecStd	9.5	1.4	1.5	2.1	1.6	2.0	2.1	2.8	1.9	2.8	2.3	2.2	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.8	75.3	81.1	85.2	90.3	94.2	95.3	95.7	93.2	87.3	76.3	71.7
		MCWB	59.8	62.7	63.0	66.1	70.5	74.5	74.2	75.4	70.8	70.9	62.4	63.0
	2%	DB	65.4	69.9	77.0	82.4	87.4	91.5	93.0	92.3	90.3	81.8	72.4	68.4
		MCWB	56.3	59.5	61.4	65.1	69.9	74.4	74.8	74.4	71.2	67.4	60.0	62.2
	5%	DB	61.6	66.3	73.0	80.0	85.1	89.6	90.9	90.3	87.5	78.5	69.4	64.8
		MCWB	55.9	57.8	58.9	63.5	69.2	73.9	74.8	74.1	71.7	65.5	58.6	59.6
	10%	DB	57.2	62.9	69.4	77.1	82.5	87.3	88.9	88.0	84.5	75.2	66.1	60.9
		MCWB	51.8	55.0	57.2	62.3	68.4	72.8	74.4	73.5	70.8	64.2	58.0	55.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.4	65.1	66.0	70.1	73.4	77.9	78.5	78.4	76.0	73.5	68.1	68.3
		MCDB	66.6	70.6	74.5	79.3	83.4	88.8	89.3	89.3	84.8	80.2	71.1	70.0
	2%	WB	60.2	62.9	64.3	68.1	72.1	76.6	77.3	77.2	74.6	71.3	65.0	64.3
		MCDB	63.8	68.0	71.5	77.4	82.4	87.4	87.8	87.1	83.2	78.1	67.7	65.9
	5%	WB	57.1	60.5	62.7	66.5	71.1	75.4	76.4	76.2	73.4	69.2	62.8	60.4
		MCDB	60.2	64.9	69.8	75.6	81.1	86.1	86.5	85.6	81.3	75.1	66.1	63.5
	10%	WB	52.9	57.4	60.2	65.0	70.0	74.4	75.5	75.2	72.4	67.0	59.8	57.0
		MCDB	56.2	60.3	66.8	73.3	79.3	84.1	85.1	84.0	80.2	72.3	64.1	59.9
Mean Daily Temperature Range	5% DB	MDBR	18.6	19.2	20.6	21.6	19.5	18.0	17.3	16.9	17.6	20.1	20.6	16.9
		MCDBR	22.2	23.2	25.3	24.9	22.0	20.5	19.8	19.6	21.5	22.8	23.4	19.9
		MCWBR	15.5	14.5	12.4	10.3	7.8	7.1	6.0	6.0	7.0	10.0	13.3	13.7
	5% WB	MCDBR	17.0	18.9	20.2	19.9	18.5	18.2	17.6	16.7	17.0	17.0	17.1	16.5
		MCWBR	14.4	13.9	11.6	9.7	7.6	7.2	6.2	5.9	6.6	9.5	12.9	13.8
Clear-Sky Solar Irradiance	taub	0.310	0.314	0.348	0.387	0.445	0.474	0.517	0.517	0.417	0.364	0.335	0.311	
	taud	2.534	2.519	2.449	2.322	2.199	2.159	2.053	2.042	2.308	2.453	2.476	2.550	
	Ebn at Noon	287	298	294	285	269	260	248	246	268	276	275	280	
	Edh at Noon	26	29	34	40	46	48	53	53	39	31	27	24	
All-Sky Solar Radiation	RadAvg	840	1017	1365	1728	1911	1957	1871	1731	1497	1259	936	711	
	RadStd	53	128	115	113	157	156	137	100	147	158	100	75	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (39 neighbors)	+0.83	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+265	+185

Nomenclature: See separate page