

DOBBINS AFB, GA, USA

WMO: 722270

Lat: 33.917N

Lon: 84.517W

Elev: 326

StdP: 97.48

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 13864

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.2	-4.4	-15.5	1.0	-3.2	-13.3	1.2	-0.9	10.5	1.2	9.5	2.3	4.5	310	0.394

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	33.9	23.4	32.9	23.3	31.9	23.1	25.2	30.9	24.7	30.2	24.1	29.5	3.3	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.6	19.1	27.2	23.0	18.5	26.8	22.7	18.1	26.5	78.2	31.1	76.1	30.2	74.2	29.7	27.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.7	(b) 7.6	(c) 6.8	(e) -10.3	(f) 35.6	(g) 3.2	(h) 2.0	(i) -12.6	(j) 37.0	(k) -14.5	(l) 38.1	(m) -16.3	(n) 39.2	(o) -18.7	(p) 40.6		
(a) 8.7	(b) 7.6	(c) 6.8	(e) -11.4	(f) 26.1	(g) 3.0	(h) 0.7	(i) -13.6	(j) 26.6	(k) -15.4	(l) 27.0	(m) -17.1	(n) 27.4	(o) -19.3	(p) 27.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.8	5.4	8.1	12.1	17.1	21.4	25.2	26.5	26.1	23.2	17.0	11.4	8.0
	DBStd	8.37	5.48	5.56	5.14	3.89	3.49	2.11	1.88	1.95	2.98	4.09	4.30	4.92
	HDD10.0	432	162	93	38	2	0	0	0	0	0	2	34	99
	HDD18.3	1579	401	288	200	67	17	0	0	0	3	72	210	321
	CDD10.0	2927	19	40	103	216	352	457	512	498	397	221	76	37
	CDD18.3	1033	0	1	7	31	111	207	253	239	149	32	2	1
	CDH23.3	8995	0	5	57	293	893	1846	2362	2146	1154	229	9	1
	CDH26.7	3376	0	0	4	46	260	730	1000	874	413	47	1	0
Wind	WSAvg	2.9	3.5	3.5	3.5	3.2	2.7	2.5	2.5	2.3	2.2	2.6	2.7	3.1
Precipitation	PrecAvg	1335	120	121	132	97	103	107	131	108	100	85	109	107
	PrecMax	1814	196	210	241	196	283	257	350	195	296	242	266	258
	PrecMin	796	62	48	47	24	43	42	42	31	11	6	25	32
	PrecStd	241	35	39	53	40	52	53	71	47	70	58	55	51
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.5	24.1	27.3	29.5	32.4	34.5	35.2	35.4	34.0	30.7	24.6	22.1
		MCWB	15.5	17.0	17.2	18.9	21.4	23.6	23.4	24.1	21.6	21.6	16.9	17.2
	2%	DB	18.6	21.1	25.0	28.0	30.8	33.1	33.9	33.5	32.4	27.7	22.5	20.2
		MCWB	13.5	15.3	16.3	18.4	21.1	23.5	23.8	23.6	21.8	19.7	15.6	16.8
	5%	DB	16.4	19.0	22.8	26.7	29.5	32.0	32.7	32.4	30.8	25.8	20.8	18.2
		MCWB	13.3	14.3	14.9	17.5	20.7	23.3	23.8	23.4	22.0	18.6	14.8	15.3
	10%	DB	14.0	17.2	20.8	25.0	28.0	30.7	31.6	31.1	29.2	24.0	18.9	16.0
		MCWB	11.0	12.8	14.0	16.8	20.2	22.7	23.6	23.0	21.5	17.9	14.5	13.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.4	18.4	18.9	21.2	23.0	25.5	25.8	25.8	24.5	23.0	20.1	20.2
		MCDB	19.2	21.4	23.6	26.3	28.6	31.6	31.8	31.8	29.4	26.8	21.7	21.1
	2%	WB	15.7	17.2	17.9	20.1	22.3	24.8	25.2	25.1	23.7	21.9	18.3	18.0
		MCDB	17.7	20.0	21.9	25.2	28.0	30.8	31.0	30.6	28.5	25.6	19.8	18.8
	5%	WB	13.9	15.8	17.1	19.2	21.7	24.1	24.7	24.5	23.0	20.7	17.1	15.8
		MCDB	15.7	18.3	21.0	24.2	27.3	30.1	30.3	29.8	27.4	23.9	18.9	17.5
	10%	WB	11.6	14.1	15.7	18.3	21.1	23.6	24.1	24.0	22.4	19.4	15.5	13.9
		MCDB	13.4	15.7	19.3	22.9	26.3	29.0	29.5	28.9	26.8	22.4	17.9	15.5
Mean Daily Temperature Range	5% DB	MDBR	10.3	10.7	11.4	12.0	10.8	10.0	9.6	9.4	9.8	11.2	11.4	9.4
		MCDBR	12.3	12.9	14.1	13.8	12.2	11.4	11.0	10.9	11.9	12.6	13.0	11.0
		MCWBR	8.6	8.1	6.9	5.7	4.4	3.9	3.4	3.3	3.9	5.6	7.4	7.6
	5% WB	MCDBR	9.4	10.5	11.2	11.1	10.3	10.1	9.8	9.3	9.4	9.4	9.5	9.2
		MCWBR	8.0	7.7	6.5	5.4	4.2	4.0	3.5	3.3	3.6	5.3	7.2	7.6
Clear-Sky Solar Irradiance	taub	0.310	0.314	0.348	0.387	0.445	0.474	0.517	0.517	0.417	0.364	0.335	0.311	
	taud	2.534	2.519	2.449	2.322	2.199	2.159	2.053	2.042	2.308	2.453	2.476	2.550	
	Ebn at Noon	906	940	928	900	848	819	781	774	845	869	866	884	
	Edh at Noon	82	92	107	127	146	151	167	167	122	98	86	77	
All-Sky Solar Radiation	RadAvg	2.65	3.21	4.30	5.45	6.03	6.17	5.90	5.46	4.72	3.97	2.95	2.24	
	RadStd	0.17	0.40	0.36	0.35	0.49	0.49	0.43	0.32	0.46	0.50	0.32	0.24	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (39 neighbors)	+0.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+147	+103

Nomenclature: See separate page