

EVERGREEN, AL, USA

WMO: 722276

Lat: 31.416N

Lon: 87.044W

Elev: 258

StdP: 14.56

Time Zone: -6.00 (NAC)

Period: 99-19

WBAN: 53820

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.0	27.9	10.4	9.4	34.6	15.9	12.4	39.5	18.9	63.9	17.2	60.3	2.4	340	0.357

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.9	95.9	75.7	93.7	76.0	91.9	75.7	79.7	89.6	78.7	88.4	78.0	87.5	5.6	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.2	142.9	83.5	76.2	137.9	82.7	75.3	133.7	82.0	43.2	89.3	42.3	88.7	41.4	87.7	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.6	14.2	12.2	DB	19.0	98.4	3.7	3.1	16.3	100.6	14.1	102.5	12.1	104.2	9.3	106.5
			WB	17.3	81.3	3.6	0.8	14.8	81.9	12.7	82.3	10.6	82.8	8.0	83.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.1	48.8	52.8	59.1	65.6	73.0	79.3	81.1	81.1	77.0	67.0	56.7	51.2
	DBStd	13.65	10.33	9.38	8.38	6.66	5.42	3.23	2.55	3.09	4.77	7.74	8.25	9.41
	HDD50	376	151	72	20	1	0	0	0	0	0	1	28	103
	HDD65	1949	510	355	217	72	10	0	0	0	2	72	272	439
	CDD50	6265	114	150	303	470	714	879	965	965	810	527	229	139
	CDD65	2361	7	13	35	90	259	429	500	500	362	132	24	10
	CDH74	22182	33	67	325	951	2597	4128	4848	4694	3121	1213	166	39
	CDH80	9603	6	5	40	221	1050	1968	2322	2260	1353	360	18	0
(14) Wind	WSAvg	4.3	5.2	5.5	5.5	5.2	4.3	3.6	3.1	3.1	3.5	4.0	4.2	4.8
(15) Precipitation	PrecAvg	59.2	5.1	4.9	4.9	4.2	4.0	5.4	5.7	6.0	4.7	3.3	4.8	6.1
	PrecMax	84.2	11.4	13.3	13.1	10.0	9.7	10.3	10.3	12.2	10.0	8.1	10.4	18.4
	PrecMin	42.6	1.9	1.6	0.7	0.7	0.6	1.9	1.4	2.4	0.7	0.3	2.0	2.2
	PrecStd	9.9	2.0	2.7	3.0	2.6	2.2	2.5	2.6	2.6	2.6	2.4	2.4	3.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.4	80.3	83.9	87.7	94.0	97.5	97.7	99.4	95.6	90.4	82.2	78.0
		MCWB	65.0	67.7	65.3	69.5	73.0	73.7	76.3	75.7	75.8	71.9	68.3	67.6
	2%	DB	73.1	75.5	80.9	84.9	90.7	94.6	94.7	95.9	92.5	87.0	78.8	74.6
		MCWB	64.6	64.6	65.5	68.2	71.8	74.8	76.6	76.7	74.9	71.3	67.1	67.0
	5%	DB	70.0	72.4	78.0	82.5	88.5	92.5	92.8	93.0	90.4	83.9	75.2	71.6
		MCWB	63.4	63.5	63.7	67.0	71.2	74.8	76.8	76.9	74.8	69.6	64.8	65.4
	10%	DB	66.1	69.5	74.5	80.4	86.1	90.2	90.7	90.8	88.0	81.2	72.5	67.7
		MCWB	60.8	61.8	62.4	65.9	70.6	74.5	76.6	76.9	74.3	68.3	63.9	63.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.2	70.0	70.6	73.9	76.3	79.6	81.1	81.2	78.9	76.9	73.4	71.7
		MCDB	73.7	76.4	76.5	81.7	86.6	89.6	90.4	90.7	88.3	83.6	77.1	75.5
	2%	WB	67.0	68.0	68.8	71.9	75.1	78.3	79.6	80.0	77.8	75.1	71.0	68.8
		MCDB	71.0	73.4	75.1	79.0	84.7	88.3	89.9	89.7	86.9	81.7	74.7	72.1
	5%	WB	64.8	65.8	67.0	70.4	74.0	77.4	78.5	78.9	76.9	73.5	68.4	66.4
		MCDB	68.4	70.6	73.5	77.4	83.2	87.3	88.5	88.4	85.7	79.9	73.4	70.0
	10%	WB	62.0	63.5	65.2	68.8	72.9	76.4	77.9	78.0	76.0	71.7	65.5	63.6
		MCDB	66.1	67.3	71.9	75.9	81.8	85.5	87.5	87.1	84.4	77.7	70.1	66.7
(35) Mean Daily Temperature Range	5% DB	MDBR	22.8	23.3	24.9	25.3	24.0	20.8	19.9	19.8	20.9	24.5	25.5	22.3
		MCDBR	23.6	24.4	26.5	27.1	26.3	24.7	22.7	23.1	23.2	26.2	26.3	23.3
		MCWBR	15.8	14.6	13.2	12.2	10.0	8.0	7.8	8.0	8.9	12.1	15.4	16.3
		MCDBR	19.1	19.8	20.3	20.2	20.9	19.8	19.6	19.6	18.9	19.2	20.1	19.6
	5% WB	MCWBR	14.5	14.5	11.9	10.6	8.8	7.9	8.0	7.9	8.1	10.0	13.9	15.8
(40) Clear-Sky Solar Irradiance	taub		0.324	0.340	0.362	0.389	0.435	0.465	0.528	0.510	0.440	0.375	0.347	0.329
	taud		2.542	2.500	2.433	2.359	2.264	2.235	2.070	2.116	2.291	2.448	2.474	2.539
	Ebn at Noon		287	292	292	286	272	263	246	249	264	276	275	279
	Edh at Noon		27	31	35	39	43	45	52	49	40	32	29	26
(44) All-Sky Solar Radiation	RadAvg		919	1099	1485	1822	1997	1939	1870	1749	1592	1377	1047	802
	RadStd		66	144	129	153	125	159	117	110	111	160	94	82

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.39	N/A	N/A	N/A	N/A	N/A	N/A	-302	+461	+252
(47) Regional (44 neighbors)		+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+270	+171

Nomenclature: See separate page