

PRYOR FIELD, AL, USA

WMO: 722279

Lat: 34.653N

Lon: 86.945W

Elev: 592

StdP: 14.38

Time Zone: -6.00 (NAC)

Period: 99-19

WBAN: 53852

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.6	22.5	7.0	8.0	23.4	10.8	9.7	26.5	24.3	50.4	21.1	50.2	6.3	350	0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.5	95.0	75.0	92.9	74.8	90.8	74.5	78.5	88.3	77.7	87.7	76.8	86.4	7.0	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.8	137.8	82.9	74.9	133.8	82.0	73.9	129.0	80.7	42.4	88.6	41.4	87.5	40.4	86.6	82.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.1	17.8	15.9		11.6	98.6	4.6	3.2	8.3	100.9	5.6	102.8	3.1	104.6	-0.3	106.9
				10.6	80.6	4.3	1.0	7.6	81.4	5.1	82.0	2.7	82.6	-0.4	83.3
				DB											
				WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.6	41.0	45.1	52.9	61.8	70.0	77.4	79.5	78.9	73.5	62.4	51.3	44.2
	DBStd	15.80	10.93	9.92	9.35	7.91	6.55	4.08	3.62	4.09	6.08	8.39	9.01	9.58
	HDD50	940	321	197	79	9	0	0	0	0	0	8	90	236
	HDD65	3097	744	560	385	151	32	0	0	0	11	150	418	646
	CDD50	5169	43	59	169	363	621	821	913	896	705	393	130	56
	CDD65	1850	1	2	10	55	187	371	448	431	266	70	8	1
	CDH74	17399	0	5	102	470	1653	3569	4363	4139	2373	673	48	4
	CDH80	7329	0	0	12	86	554	1603	1975	1939	973	181	6	0
(14) Wind	WSAvg	6.3	7.5	7.9	7.9	7.7	6.4	5.4	4.6	4.2	4.8	5.6	6.4	7.0
(15) Precipitation	PrecAvg	54.4	5.5	5.2	5.3	4.8	4.2	3.8	5.0	3.7	3.5	3.0	4.2	6.4
	PrecMax	68.7	11.1	10.3	10.0	9.8	10.2	8.1	10.4	8.1	7.4	7.1	7.4	18.0
	PrecMin	30.5	2.2	2.6	1.4	1.8	0.5	0.9	1.8	1.1	0.2	0.0	1.8	2.1
	PrecStd	8.9	2.1	2.3	2.0	2.1	2.6	2.2	1.9	1.5	2.2	2.0	1.6	3.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.2	74.0	81.5	85.7	91.5	96.3	97.2	99.3	95.1	88.9	80.7	72.4
		MCWB	62.5	63.3	62.9	67.0	72.2	74.0	75.6	74.5	73.1	71.0	65.9	64.1
	2%	DB	65.8	69.6	76.7	82.4	88.4	93.3	94.0	95.1	92.1	84.3	73.5	67.8
		MCWB	60.3	61.3	61.9	65.9	70.8	73.9	76.0	75.6	73.1	69.0	61.7	62.2
	5%	DB	62.9	65.7	72.5	79.8	85.9	91.1	91.6	92.4	89.2	81.3	70.4	63.9
		MCWB	58.0	57.8	59.9	64.9	69.6	73.4	76.1	75.3	72.5	66.2	61.2	59.3
	10%	DB	58.8	61.6	68.7	76.1	83.0	88.9	89.8	90.0	85.9	77.5	66.6	60.2
		MCWB	54.2	54.4	58.5	63.5	68.8	72.9	75.7	75.2	71.6	64.8	59.1	55.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.7	66.2	66.9	71.2	75.0	78.4	80.2	79.7	77.4	74.6	69.2	66.5
		MCDB	68.5	71.2	74.3	80.5	84.2	88.7	89.3	89.6	87.1	81.9	73.1	69.9
	2%	WB	61.9	63.9	64.5	68.8	73.2	77.1	78.9	78.3	76.0	72.5	66.5	63.3
		MCDB	64.8	68.2	72.3	78.0	83.5	87.8	88.6	88.4	85.8	80.6	71.4	66.4
	5%	WB	58.9	60.0	62.6	67.3	72.1	76.0	78.0	77.4	74.8	70.0	63.9	60.3
		MCDB	62.5	63.6	70.1	75.9	81.9	86.2	87.7	87.6	84.0	77.0	68.2	63.7
	10%	WB	54.7	56.3	60.3	65.5	70.8	74.9	77.1	76.4	73.5	67.7	60.8	56.1
		MCDB	57.8	60.4	67.4	73.5	79.9	84.5	86.5	86.0	81.6	74.4	65.3	59.4
(35) Mean Daily Temperature Range	5% DB	MDBR	18.4	19.4	21.4	22.0	20.8	20.8	19.5	20.6	22.3	23.7	22.5	18.4
		MCDBR	20.3	23.6	26.2	24.5	23.8	24.3	22.3	24.2	25.4	27.1	26.2	20.7
		MCWBR	15.5	15.8	14.2	11.1	9.0	8.2	8.0	8.3	9.6	12.4	15.3	15.7
	5% WB	MCDBR	17.7	18.3	21.0	20.2	19.4	20.1	19.3	20.3	20.8	20.2	18.9	18.6
		MCWBR	15.0	14.6	13.1	11.0	8.6	8.0	8.2	8.2	9.0	10.8	13.6	15.7
(40) Clear-Sky Solar Irradiance	taub		0.322	0.327	0.369	0.401	0.449	0.480	0.521	0.530	0.432	0.380	0.341	0.319
	taud		2.480	2.464	2.370	2.275	2.187	2.130	2.038	1.999	2.263	2.390	2.442	2.504
	Ebn at Noon		281	292	286	281	267	258	246	241	262	269	270	274
	Edh at Noon		27	31	36	42	47	49	54	55	40	33	28	25
(44) All-Sky Solar Radiation	RadAvg		777	943	1310	1698	1866	1981	1890	1752	1519	1222	891	665
	RadStd		61	117	122	116	145	155	104	95	133	159	95	63

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+257	+184

Nomenclature: See separate page