

BIRMINGHAM SHUTTLESWORTH, AL, USA

WMO: 722280

Lat: 33.566N

Lon: 86.745W

Elev: 188

StdP: 99.09

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13876

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.3	-3.9	-14.4	1.1	-2.0	-12.1	1.4	0.1	9.4	9.6	8.8	9.5	3.0	0	0.400

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	35.3	23.6	34.0	23.6	32.9	23.5	25.8	31.3	25.3	30.8	24.8	30.0	3.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.4	19.8	28.1	23.8	19.1	27.6	23.3	18.5	27.2	80.5	31.5	78.1	30.9	76.0	30.1	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.3	7.4	6.6	-10.0	36.5	2.5	1.9	-11.8	37.9	-13.3	39.0	-14.7	40.1	-16.6	41.4		
(5)			-10.9	26.7	2.4	0.9	-12.7	27.3	-14.1	27.9	-15.5	28.4	-17.2	29.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.7	6.9	9.3	13.3	17.6	21.9	25.7	27.2	27.1	24.2	18.2	12.3	8.5	(6)
(7)		DBStd	8.40	6.06	5.63	5.25	4.17	3.52	2.32	1.83	2.19	3.23	4.50	4.82	5.43	(7)
(8)		HDD10.0	371	136	76	29	2	0	0	0	0	0	2	31	95	(8)
(9)		HDD18.3	1411	356	257	169	62	12	0	0	0	3	58	188	306	(9)
(10)		CDD10.0	3189	39	55	130	231	369	469	534	529	425	257	99	50	(10)
(11)		CDD18.3	1191	1	3	12	41	124	220	276	271	178	56	7	2	(11)
(12)		CDH23.3	11236	1	8	88	336	1082	2095	2829	2752	1588	424	30	2	(12)
(13)		CDH26.7	4562	0	0	10	59	349	885	1267	1258	628	102	3	0	(13)
(14)	Wind	WSAvg	2.7	3.2	3.3	3.4	3.2	2.7	2.3	2.2	2.1	2.3	2.4	2.6	2.9	(14)
(15)	Precipitation	PrecAvg	1385	130	116	154	123	126	107	130	99	99	70	110	123	(15)
(16)		PrecMax	1943	236	449	401	349	437	230	258	276	265	191	245	355	(16)
(17)		PrecMin	996	28	30	43	11	22	17	8	10	4	2	42	21	(17)
(18)		PrecStd	229	53	73	79	73	81	58	64	65	70	45	50	75	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.4	24.6	28.1	30.0	33.0	35.8	36.3	37.8	35.4	31.3	26.7	23.0	(19)
(20)			MCWB	16.9	17.9	17.8	19.4	22.1	23.1	24.4	24.0	22.4	20.8	18.8	18.3	(20)
(21)		2%	DB	20.2	22.1	25.7	28.4	31.3	33.9	34.8	35.5	33.6	29.2	23.7	21.1	(21)
(22)			MCWB	15.8	16.9	17.1	18.9	21.8	23.2	24.3	23.8	22.3	20.2	17.1	17.2	(22)
(23)		5%	DB	18.3	20.2	23.9	27.0	30.1	32.6	33.5	33.8	32.0	27.5	22.1	19.3	(23)
(24)			MCWB	15.2	15.1	15.9	18.1	21.1	23.1	24.2	23.8	22.2	19.3	16.8	16.3	(24)
(25)		10%	DB	16.6	18.4	21.9	25.4	28.7	31.3	32.3	32.4	30.3	25.8	20.3	17.3	(25)
(26)			MCWB	13.7	14.0	15.2	17.5	20.7	22.9	24.0	23.7	21.9	18.7	15.9	14.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.7	19.4	20.3	22.0	24.6	26.2	27.1	26.3	24.7	23.7	21.3	20.1	(27)
(28)			MCD B	20.7	22.6	23.6	26.4	29.6	31.8	32.6	32.8	29.8	27.2	23.1	21.8	(28)
(29)		2%	WB	17.3	18.3	18.9	20.8	23.5	25.2	26.0	25.6	24.1	22.5	19.7	18.3	(29)
(30)			MCD B	19.3	21.0	23.0	25.2	28.5	30.7	31.2	31.6	29.2	26.7	21.6	20.0	(30)
(31)		5%	WB	15.8	16.9	17.8	20.0	22.7	24.6	25.5	25.1	23.6	21.6	18.3	16.9	(31)
(32)			MCD B	17.8	19.4	21.9	24.5	27.7	29.8	30.8	30.7	28.5	25.2	21.0	18.9	(32)
(33)		10%	WB	14.2	15.1	16.6	19.0	21.9	24.0	25.0	24.6	23.1	20.5	16.7	14.9	(33)
(34)			MCD B	16.5	17.4	20.7	23.3	26.7	28.9	30.1	29.9	27.7	23.8	19.4	16.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.4	10.9	11.7	12.1	11.0	10.2	9.8	10.1	10.7	11.6	11.6	10.0	(35)
(36)			MCDBR	10.8	12.0	13.2	12.9	12.1	12.1	11.5	12.0	12.4	12.6	12.4	10.5	(36)
(37)			MCWBR	7.6	7.5	6.7	5.5	4.4	4.1	3.5	3.6	4.1	5.3	6.9	7.7	(37)
(38)		5% WB	MCD BR	9.0	9.8	10.6	10.3	10.1	10.0	9.9	9.8	9.6	9.2	9.2	9.3	(38)
(39)			MCWBR	7.5	7.6	6.6	5.5	4.5	4.1	3.8	3.5	3.7	5.1	6.7	8.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.317	0.324	0.360	0.395	0.456	0.479	0.526	0.526	0.432	0.369	0.341	0.320	(40)	
(41)		taud	2.530	2.505	2.424	2.309	2.178	2.154	2.043	2.031	2.286	2.451	2.470	2.534	(41)	
(42)		Ebn at Noon	901	929	916	894	838	816	775	767	832	865	861	875	(42)	
(43)		Edh at Noon	83	94	110	129	149	152	169	169	125	98	87	79	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.62	3.14	4.29	5.49	5.99	6.15	5.95	5.49	4.82	4.01	2.96	2.23	(44)	
(45)		RadStd	0.20	0.42	0.39	0.39	0.47	0.47	0.38	0.30	0.43	0.52	0.32	0.23	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.46	N/A	N/A	N/A	N/A	N/A	N/A	-100	+151	+108
(47) Regional (40 neighbors)		+0.48	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+152	+110

Nomenclature: See separate page