

NORTHPORT 2 S, AL, USA

WMO: 722288

Lat: 33.2125N

Lon: 87.5914W

Elev: 150

StdP: 14.62

Time Zone: -6.00 (NAC)

Period: 09-19

WBAN: 73801

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 21.9	(c) 26.1	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 19.4	(c) 96.7	(d) N/A	(e) 94.5	(f) N/A	(g) 92.5	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) N/A	(b) N/A	(c) N/A	(e) 15.6	(f) 99.0	(g) 5.0	(h) 3.3	(i) 12.0	(j) 101.4	(k) 9.1	(l) 103.4	(m) 6.3	(n) 105.2	(o) 2.6	(p) 107.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.6	44.7	50.1	56.7	64.3	72.2	79.7	81.5	81.0	76.8	65.5	53.9	48.3		
	DBStd	15.05	10.69	10.38	9.24	6.53	6.46	3.79	3.23	3.55	5.54	8.14	8.58	9.09		
	HDD50	597	231	118	43	1	0	0	0	0	0	2	55	147		
	HDD65	2419	631	428	284	90	22	0	0	0	2	96	346	520		
	CDD50	5940	68	121	250	431	687	892	976	961	805	481	172	96		
	CDD65	2285	2	11	26	70	244	442	511	496	357	110	13	3		
	CDH74	22117	5	43	193	661	2237	4531	5168	4811	3334	1058	67	9		
	CDH80	9784	0	2	23	109	838	2182	2458	2276	1539	348	9	0		
(14) Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(15) Precipitation	PrecAvg	52.6	5.3	5.1	5.7	4.9	4.0	4.3	4.8	3.6	3.2	3.2	4.4	4.7		
	PrecMax	75.4	9.6	14.5	17.7	15.0	11.1	12.0	12.3	7.4	8.7	9.1	11.4	10.4		
	PrecMin	35.4	1.1	1.3	1.2	0.4	0.4	0.4	0.9	0.7	0.8	0.1	1.0	1.0		
	PrecStd	9.6	2.0	2.8	3.2	2.9	2.6	2.5	2.6	1.8	2.2	2.3	2.2	2.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.4	78.9	83.0	85.6	92.8	99.3	98.5	99.2	97.1	91.4	80.4	75.2		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	69.7	74.7	79.2	83.1	89.9	95.5	95.3	96.4	94.3	87.3	75.2	70.8		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	65.8	70.5	75.6	80.9	87.4	93.0	93.2	93.6	91.8	84.0	72.1	67.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	62.0	67.0	71.9	78.2	85.2	90.8	91.1	91.0	89.1	80.2	68.9	63.6		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	5% DB	MDBR	20.3	20.2	21.6	22.8	21.7	20.6	19.4	19.5	21.5	23.4	23.3	18.6		
		MCDBR	22.0	21.9	24.0	24.5	23.9	24.0	22.0	23.4	24.5	26.8	24.3	21.3		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.324	0.335	0.365	0.402	0.451	0.482	0.534	0.533	0.443	0.374	0.347	0.324		
	taud		2.519	2.482	2.418	2.303	2.212	2.155	2.033	2.029	2.269	2.452	2.465	2.534		
	Ebn at Noon		283	291	289	282	267	258	244	242	261	274	272	277		
	Edh at Noon		27	31	35	41	46	48	54	54	41	31	28	25		
(44) All-Sky Solar Radiation	RadAvg		842	1010	1376	1746	1921	1993	1916	1762	1557	1291	954	719		
	RadStd		68	138	128	136	142	155	120	109	135	159	100	72		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (35 neighbors)	+0.85	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+257	+185

Nomenclature: See separate page