

NEW ORLEANS INTL, LA, USA

WMO: 722310

Lat: 29.997N

Lon: 90.278W

Elev: 1

StdP: 101.31

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 12916

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.6	2.6	-8.2	1.9	3.3	-5.7	2.3	5.7	10.8	12.2	9.6	10.9	4.1	0	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.8	34.7	25.5	33.8	25.4	32.9	25.3	27.1	31.6	26.8	31.1	26.4	30.7	3.3	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.4	29.1	25.6	20.9	28.9	25.2	20.4	28.6	85.2	31.7	83.4	31.2	81.8	30.7	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.3	8.4	7.6	DB	-2.3	36.1	2.4	1.1	-4.0	36.9	-5.4	37.6	-6.7	38.2	-8.4	39.0
			WB	-4.2	28.0	2.1	0.6	-5.7	28.4	-6.9	28.8	-8.1	29.2	-9.6	29.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.3	12.2	14.4	17.5	21.0	25.1	27.8	28.6	28.7	27.0	22.4	17.0	13.6
	DBStd	6.97	5.39	5.15	4.35	3.36	2.47	1.63	1.38	1.48	2.15	3.77	4.31	5.11
	HDD10.0	83	39	17	3	0	0	0	0	0	0	0	3	21
	HDD18.3	663	199	130	68	14	1	0	0	0	0	11	76	164
	CDD10.0	4208	107	138	236	331	467	533	576	580	511	384	212	133
	CDD18.3	1746	9	18	42	96	209	283	317	322	261	137	35	17
	CDH23.3	16779	21	56	173	580	1803	3033	3567	3689	2633	1011	160	53
	CDH26.7	6158	0	3	11	98	584	1217	1476	1559	946	245	17	2
Wind	WSAvg	3.5	4.1	4.1	4.0	4.2	3.6	2.9	2.6	2.6	3.1	3.5	3.6	3.9
Precipitation	PrecAvg	1630	136	112	127	127	136	180	175	159	153	97	98	129
	PrecMax	2510	475	273	252	389	404	505	284	385	545	324	347	615
	PrecMin	1189	6	20	14	3	12	61	76	40	24	7	11	33
	PrecStd	296	105	71	61	98	101	100	54	85	109	80	78	108
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.3	27.0	27.9	30.1	33.2	35.1	35.7	35.7	35.1	32.1	28.5	26.7
		MCWB	20.6	21.8	21.4	22.5	23.9	24.7	25.8	25.7	25.1	24.2	22.3	21.9
	2%	DB	23.7	25.1	26.7	28.9	31.9	33.8	34.4	34.6	33.2	30.5	26.8	24.9
		MCWB	19.7	20.7	20.7	22.2	23.7	25.0	25.7	25.7	24.8	23.5	21.7	21.0
	5%	DB	22.1	23.5	25.4	27.8	30.9	32.8	33.4	33.6	32.2	29.2	25.2	23.1
		MCWB	18.8	19.7	20.3	21.6	23.5	24.9	25.7	25.7	24.6	23.0	20.7	20.3
	10%	DB	20.5	22.0	23.9	26.7	29.9	31.8	32.4	32.6	31.1	28.0	23.7	21.5
		MCWB	18.0	19.1	19.6	21.0	23.1	24.8	25.5	25.7	24.4	22.5	20.0	19.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.8	23.0	23.0	24.5	26.1	27.1	27.8	27.9	26.9	26.4	24.2	23.0
		MCDB	23.8	25.0	25.5	27.8	30.5	31.7	32.5	32.3	31.0	29.1	26.0	25.1
	2%	WB	20.8	21.8	22.2	23.7	25.2	26.6	26.9	27.3	26.5	25.5	23.0	22.0
		MCDB	22.7	23.9	24.8	26.8	29.5	31.1	31.6	31.7	30.5	28.2	25.1	23.7
	5%	WB	19.7	20.8	21.4	23.0	24.6	26.1	26.6	26.8	26.0	24.8	21.9	20.9
		MCDB	21.5	22.8	24.1	26.0	28.7	30.4	31.3	31.1	29.7	27.4	24.4	22.7
	10%	WB	18.3	19.6	20.6	22.4	24.1	25.7	26.2	26.5	25.6	24.1	20.8	19.6
		MCDB	20.1	21.5	23.2	25.4	28.0	29.9	30.7	30.7	29.2	26.8	23.2	21.2
Mean Daily Temperature Range	5% DB	MDBR	9.2	9.1	9.2	9.1	8.7	8.0	7.8	7.8	7.8	8.7	9.4	8.9
		MCDBR	9.9	9.3	9.1	9.2	9.2	9.0	9.0	8.9	8.8	8.9	9.7	9.6
		MCWBR	6.7	5.9	4.7	4.3	3.4	3.1	3.0	3.1	3.2	3.9	5.6	6.5
	5% WB	MCDBR	8.6	8.5	8.2	8.1	8.3	7.9	8.1	8.0	7.5	7.2	8.8	8.9
		MCWBR	6.6	6.4	5.4	4.9	3.5	3.3	3.3	3.2	3.2	3.9	6.4	7.0
Clear-Sky Solar Irradiance	taub	0.339	0.361	0.375	0.420	0.446	0.468	0.513	0.507	0.450	0.385	0.360	0.347	
	taud	2.530	2.481	2.426	2.305	2.268	2.250	2.154	2.165	2.295	2.464	2.474	2.523	
	Ebn at Noon	896	904	911	876	851	827	789	790	826	866	862	868	
	Edh at Noon	88	100	113	131	137	139	153	149	127	101	92	85	
All-Sky Solar Radiation	RadAvg	3.00	3.54	4.76	5.79	6.34	6.03	5.70	5.39	5.10	4.52	3.44	2.67	
	RadStd	0.26	0.47	0.41	0.48	0.34	0.50	0.42	0.46	0.40	0.49	0.32	0.25	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	+0.55	N/A	N/A	N/A	N/A	N/A	N/A	-70	+185	+134	(46)	
(47)	Regional (23 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+141	+96	(47)	

Nomenclature: See separate page