

HAMMOND, LA, USA

WMO: 722312

Lat: 30.521N

Lon: 90.418W

Elev: 13

StdP: 101.16

Time Zone: -6.00 (NAC)

Period: 02-19

WBAN: 03908

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.2	(c) -0.2	(d) -9.0	(e) 1.7	(f) 6.7	(g) -6.3	(h) 2.2	(i) 6.3	(j) 9.0	(k) 11.0	(l) 8.3	(m) 11.6	(n) 1.2	(o) 10	(p) 0.361

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 10.8	(c) 36.3	(d) 26.2	(e) 35.9	(f) 25.8	(g) 34.1	(h) 25.2	(i) 28.5	(j) 33.3	(k) 27.8	(l) 32.2	(m) 27.2	(n) 31.4	(o) 2.3	(p) 0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.4	23.3	30.5	27.0	22.8	30.1	26.2	21.6	29.3	91.7	33.2	88.3	33.0	85.4	30.5	34.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.1	(b) 7.2	(c) 6.0	(e) -4.7	(f) 37.5	(g) 2.3	(h) 1.8	(i) -6.4	(j) 38.7	(k) -7.7	(l) 39.7	(m) -9.0	(n) 40.7	(o) -10.6	(p) 42.0		
(a) 8.1	(b) 7.2	(c) 6.0	(e) -5.7	(f) 28.1	(g) 2.2	(h) 1.4	(i) -7.3	(j) 29.1	(k) -8.6	(l) 29.9	(m) -9.8	(n) 30.6	(o) -11.4	(p) 31.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.5	10.5	13.5	17.0	20.0	24.2	27.7	28.4	28.7	26.7	21.5	15.5	12.2
	DBStd	7.50	5.47	5.21	4.61	3.62	3.07	1.81	1.57	1.86	2.23	4.26	4.84	5.23
	HDD10.0	131	60	21	4	1	0	0	0	0	0	0	9	36
	HDD18.3	839	248	149	81	24	2	0	0	0	0	20	112	203
	CDD10.0	3974	77	119	222	301	441	531	571	579	501	357	173	103
	CDD18.3	1642	6	15	40	74	184	281	313	321	251	119	26	11
	CDH23.3	16415	22	72	269	706	1833	3008	3307	3465	2406	1105	178	43
CDH26.7	7245	1	6	39	160	736	1479	1597	1714	1089	394	28	2	
Wind	WSAvg	2.0	2.3	2.6	2.6	2.7	2.1	1.6	1.3	1.4	1.5	1.8	2.0	2.2
Precipitation	PrecAvg	1594	148	129	141	130	132	151	163	141	110	111	105	132
	PrecMax	2053	393	260	296	252	328	309	382	331	303	273	266	374
	PrecMin	1104	15	21	18	11	10	38	76	51	19	0	21	44
	PrecStd	272	88	70	71	70	96	73	61	68	74	75	68	71
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.0	27.5	29.0	31.2	34.9	37.5	37.3	37.6	36.3	33.0	29.1	26.3
		MCWB	20.2	20.8	20.4	21.4	24.2	25.3	25.7	26.3	26.0	23.4	21.7	21.0
	2%	DB	23.0	25.9	27.7	29.8	32.9	36.1	36.1	36.3	34.8	32.4	27.4	24.8
		MCWB	18.7	19.7	19.9	21.7	24.2	25.3	25.8	26.8	24.9	23.0	20.7	20.5
	5%	DB	22.1	23.6	26.3	28.0	32.3	34.1	34.9	35.9	33.0	30.9	25.2	22.6
		MCWB	18.4	18.7	19.3	20.8	23.9	24.6	25.5	26.3	24.6	22.5	20.3	19.5
	10%	DB	19.8	22.1	24.9	27.5	31.0	32.9	33.0	33.8	32.5	28.8	23.7	21.0
		MCWB	17.0	18.7	18.9	20.3	23.1	24.9	25.7	25.9	24.4	21.8	19.0	18.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.9	22.4	23.1	25.0	26.9	28.8	28.7	29.9	28.4	27.3	24.3	22.8
		MCDB	23.9	25.5	26.0	27.4	31.2	33.9	33.8	35.3	33.2	30.6	26.8	24.7
	2%	WB	20.9	21.3	22.0	23.8	25.8	27.8	28.0	28.8	27.4	25.8	22.8	21.4
		MCDB	22.4	23.6	25.4	27.3	30.2	32.5	32.8	33.6	31.3	28.9	25.4	23.6
	5%	WB	19.0	20.6	21.2	22.9	25.1	27.0	27.4	27.9	26.5	24.7	21.6	20.3
		MCDB	21.2	22.6	24.2	26.1	29.9	31.4	31.9	32.3	30.3	28.0	24.2	22.2
	10%	WB	17.5	19.2	20.3	22.1	24.4	26.1	26.7	27.2	25.7	23.7	20.4	18.8
		MCDB	18.9	21.5	23.2	25.6	28.7	30.5	30.8	31.2	29.7	27.1	22.9	20.4
Mean Daily Temperature Range	5% DB	MDBR	11.9	11.6	12.6	13.0	12.1	11.1	10.6	10.8	11.2	13.3	13.4	11.7
		MCDBR	12.3	11.7	12.5	13.2	12.7	12.7	12.0	12.2	12.0	13.6	13.5	12.0
		MCWBR	8.4	6.9	6.2	6.3	4.8	4.0	3.9	4.2	4.5	5.7	7.9	8.2
	5% WB	MCDBR	10.4	9.7	10.2	10.5	10.8	10.9	10.2	10.6	10.0	9.7	10.5	10.2
		MCWBR	8.1	7.0	6.2	6.3	4.5	4.6	4.3	4.4	4.2	5.0	7.3	7.8
Clear-Sky Solar Irradiance	taub	0.332	0.357	0.372	0.412	0.440	0.469	0.512	0.505	0.449	0.380	0.353	0.341	
	taud	2.526	2.457	2.410	2.304	2.262	2.226	2.136	2.152	2.278	2.448	2.469	2.513	
	Ebn at Noon	901	906	912	882	856	826	789	791	825	868	866	870	
	Edh at Noon	87	102	114	131	138	142	155	151	129	102	92	85	
All-Sky Solar Radiation	RadAvg	2.90	3.42	4.59	5.67	6.19	5.99	5.79	5.47	5.07	4.43	3.35	2.59	
	RadStd	0.26	0.48	0.40	0.45	0.37	0.52	0.43	0.44	0.40	0.53	0.31	0.25	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (22 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+141	+96

Nomenclature: See separate page