

NEW ORLEANS LAKEFRONT, LA, USA

WMO: 722315

Lat: 30.049N

Lon: 90.029W

Elev: 9

StdP: 14.69

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 53917

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.6	38.9	18.4	13.9	38.7	23.4	17.7	41.9	31.1	47.2	28.0	48.4	15.2	0	0.480

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.0	93.6	78.6	92.6	78.4	91.1	78.0	81.5	89.6	80.7	88.8	80.1	88.0	8.4	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.3	152.1	86.0	78.8	149.4	85.6	77.6	143.5	84.8	45.1	89.9	44.2	88.8	43.4	87.6	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
26.7	23.9	20.5	DB	29.4	97.9	4.4	3.8	26.2	100.6	23.6	102.9	21.1	105.0	17.9	107.8	
			WB	25.4	83.2	3.9	1.4	22.6	84.3	20.3	85.1	18.1	85.9	15.2	87.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	71.7	54.5	58.9	64.6	71.4	78.6	83.5	85.1	85.4	82.1	73.7	63.9	57.5
	DBStd	12.64	9.25	8.58	7.57	5.94	4.49	2.91	2.81	2.90	3.70	6.25	7.40	8.57
	HDD50	112	58	19	5	0	0	0	0	0	0	0	3	27
	HDD65	1045	344	203	101	16	0	0	0	0	0	11	109	261
	CDD50	8018	196	269	458	641	885	1006	1089	1096	964	736	419	259
	CDD65	3477	18	33	88	207	421	556	624	631	514	282	75	28
	CDH74	35328	52	99	304	1164	3747	6446	7747	7961	5596	1874	256	82
	CDH80	13678	3	6	25	222	1196	2633	3495	3674	2006	389	25	4
(14) Wind	WSAvg	10.2	11.4	11.4	11.3	11.5	9.8	8.6	8.2	8.2	9.3	10.5	11.0	11.4
(15) Precipitation	PrecAvg	62.4	5.5	4.4	5.4	5.6	5.2	6.6	6.7	6.0	5.2	3.5	4.1	5.0
	PrecMax	95.8	18.1	9.7	10.3	14.6	15.9	20.0	12.8	13.6	16.7	9.9	14.1	20.6
	PrecMin	42.2	0.2	1.0	1.1	0.2	0.4	1.8	1.9	2.0	0.8	0.2	0.4	1.1
	PrecStd	12.0	4.2	2.6	2.4	4.0	3.7	4.1	2.5	3.0	3.5	2.6	3.1	3.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.2	81.1	82.4	88.2	91.4	94.2	96.6	96.7	93.7	89.0	82.5	80.2
		MCWB	70.1	70.7	70.8	74.2	76.3	78.1	80.2	79.9	78.0	77.4	72.8	71.1
	2%	DB	74.8	77.2	80.1	84.3	90.1	92.6	93.5	93.4	91.3	86.0	80.0	76.0
		MCWB	68.4	69.2	69.4	72.4	75.6	77.8	78.7	78.9	77.4	75.6	71.4	69.8
	5%	DB	72.1	73.7	77.5	82.2	88.2	91.0	92.3	92.4	90.1	83.9	77.0	73.2
		MCWB	66.8	67.7	68.4	71.3	74.8	77.4	78.6	78.7	77.3	74.6	69.9	68.7
	10%	DB	68.2	71.7	74.9	80.7	86.2	89.9	90.7	90.8	88.3	81.9	74.1	70.2
		MCWB	64.1	66.7	67.7	70.7	74.1	77.2	78.5	78.5	76.7	73.6	68.1	66.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.7	72.8	73.5	76.3	79.1	81.3	82.4	82.8	81.6	79.7	75.3	73.2
		MCDB	76.2	77.6	79.0	83.2	88.5	89.6	92.1	91.4	89.5	84.7	80.1	76.8
	2%	WB	69.7	70.9	71.9	75.0	77.6	80.2	81.3	81.7	80.2	78.1	73.3	71.3
		MCDB	74.1	75.2	76.8	81.2	85.9	88.5	89.9	89.7	87.5	83.2	77.6	74.7
	5%	WB	67.4	69.1	70.5	73.8	76.6	79.3	80.5	80.9	79.1	76.8	71.3	69.3
		MCDB	71.3	73.4	75.4	79.8	84.5	87.6	88.9	88.8	86.1	82.0	75.9	72.9
	10%	WB	64.3	66.9	69.0	72.7	75.7	78.4	79.9	80.1	78.3	75.5	69.3	66.7
		MCDB	67.4	70.8	74.0	78.6	83.1	86.4	88.1	88.0	85.1	80.7	73.9	69.8
(35) Mean Daily Temperature Range	5% DB	MDBR	13.5	13.6	13.7	13.5	12.9	11.9	11.2	11.0	10.9	11.8	12.9	12.8
		MCDBR	16.9	15.9	14.7	14.3	13.8	13.0	12.6	12.2	12.3	12.0	14.6	16.3
		MCWBR	11.4	9.8	7.8	6.7	5.3	5.1	5.2	5.2	5.0	5.9	8.6	11.5
	5% WB	MCDBR	15.8	14.8	13.8	13.3	13.1	12.2	11.9	11.5	11.2	10.8	13.8	15.2
		MCWBR	12.1	10.6	8.9	7.8	5.8	5.5	5.6	5.6	5.4	6.2	10.3	11.9
(40) Clear-Sky Solar Irradiance	taub		0.338	0.359	0.375	0.418	0.445	0.467	0.513	0.505	0.452	0.386	0.360	0.345
	taud		2.539	2.492	2.436	2.318	2.278	2.258	2.159	2.178	2.293	2.468	2.481	2.532
	Ebn at Noon		285	287	289	279	270	262	250	251	261	274	273	276
	Edh at Noon		28	31	35	41	43	44	48	47	40	32	29	27
(44) All-Sky Solar Radiation	RadAvg		949	1123	1511	1836	2012	1929	1819	1719	1622	1433	1091	849
(45)	RadStd		81	150	130	154	108	155	134	142	124	154	99	76

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+252	+167

Nomenclature: See separate page