

NEW ORLEANS LAKEFRONT, LA, USA

WMO: 722315

Lat: 30.049N

Lon: 90.029W

Elev: 3

StdP: 101.29

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 53917

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.0	3.8	-7.5	2.0	3.7	-4.8	2.5	5.5	13.9	8.4	12.5	9.1	6.8	0	0.480

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.1	34.2	25.9	33.7	25.8	32.8	25.6	27.5	32.0	27.1	31.6	26.7	31.1	3.7	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	21.7	30.0	26.0	21.3	29.8	25.3	20.5	29.4	87.0	32.1	84.8	31.6	83.0	30.9	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.9	10.7	9.2	-1.4	36.6	2.5	2.1	-3.2	38.1	-4.6	39.4	-6.0	40.6	-7.8	42.1
			-3.7	28.5	2.2	0.8	-5.2	29.0	-6.5	29.5	-7.7	30.0	-9.3	30.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.0	12.5	15.0	18.1	21.9	25.9	28.6	29.5	29.6	27.9	23.2	17.7	14.2
	DBStd	7.02	5.14	4.77	4.21	3.30	2.50	1.62	1.56	1.61	2.05	3.47	4.11	4.76
	HDD10.0	62	32	11	3	0	0	0	0	0	0	0	2	15
	HDD18.3	581	191	113	56	9	0	0	0	0	0	6	61	145
	CDD10.0	4454	109	149	254	356	492	559	605	609	536	409	233	144
	CDD18.3	1932	10	18	49	115	234	309	347	351	286	157	42	16
	CDH23.3	19627	29	55	169	647	2082	3581	4304	4423	3109	1041	142	46
	CDH26.7	7599	2	3	14	123	664	1463	1942	2041	1114	216	14	2
(14) Wind	WSAvg	4.6	5.1	5.1	5.1	5.2	4.4	3.8	3.7	3.7	4.2	4.7	4.9	5.1
(15) Precipitation	PrecAvg	1586	139	113	137	141	132	167	170	152	133	89	103	128
	PrecMax	2433	461	246	261	370	403	507	324	346	423	251	358	524
	PrecMin	1073	6	26	29	5	9	45	49	50	20	6	11	28
	PrecStd	304	107	65	62	101	93	104	63	75	88	67	80	92
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.2	27.3	28.0	31.2	33.0	34.6	35.9	35.9	34.3	31.7	28.1	26.8
		MCWB	21.2	21.5	21.6	23.4	24.6	25.6	26.8	26.6	25.6	25.2	22.7	21.7
	2%	DB	23.8	25.1	26.7	29.1	32.3	33.7	34.2	34.1	32.9	30.0	26.7	24.5
		MCWB	20.2	20.7	20.8	22.5	24.2	25.5	26.0	26.0	25.2	24.2	21.9	21.0
	5%	DB	22.3	23.2	25.3	27.9	31.2	32.8	33.5	33.6	32.3	28.8	25.0	22.9
		MCWB	19.3	19.8	20.2	21.8	23.8	25.2	25.9	25.9	25.1	23.7	21.0	20.4
	10%	DB	20.1	22.0	23.8	27.1	30.1	32.2	32.6	32.7	31.3	27.7	23.4	21.2
		MCWB	17.8	19.3	19.8	21.5	23.4	25.1	25.8	25.8	24.8	23.1	20.1	19.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.1	22.6	23.0	24.6	26.1	27.4	28.0	28.2	27.6	26.5	24.1	22.9
		MCDB	24.6	25.4	26.1	28.4	31.4	32.0	33.4	33.0	32.0	29.3	26.7	24.9
	2%	WB	21.0	21.6	22.2	23.9	25.3	26.8	27.4	27.6	26.8	25.6	23.0	21.8
		MCDB	23.4	24.0	24.9	27.3	29.9	31.4	32.2	32.0	30.8	28.4	25.3	23.7
	5%	WB	19.7	20.6	21.4	23.2	24.8	26.3	26.9	27.2	26.2	24.9	21.8	20.7
		MCDB	21.8	23.0	24.1	26.6	29.2	30.9	31.6	31.5	30.1	27.8	24.4	22.7
	10%	WB	18.0	19.4	20.6	22.6	24.3	25.8	26.6	26.7	25.7	24.2	20.7	19.3
		MCDB	19.7	21.5	23.3	25.9	28.4	30.2	31.2	31.1	29.5	27.1	23.3	21.0
(35) Mean Daily Temperature Range	5% DB	MDBR	7.5	7.5	7.6	7.5	7.2	6.6	6.2	6.1	6.1	6.6	7.2	7.1
		MCDBR	9.4	8.8	8.2	7.9	7.6	7.2	7.0	6.8	6.9	6.7	8.1	9.1
	5% WB	MCWBR	6.3	5.5	4.3	3.7	2.9	2.8	2.9	2.8	2.8	3.3	4.8	6.4
		MCWBR	8.8	8.2	7.7	7.4	7.3	6.8	6.6	6.4	6.2	6.0	7.7	8.5
(40) Clear-Sky Solar Irradiance	taub		0.338	0.359	0.375	0.418	0.445	0.467	0.513	0.505	0.452	0.386	0.360	0.345
		taud	2.539	2.492	2.436	2.318	2.278	2.258	2.159	2.178	2.293	2.468	2.481	2.532
	Ebn at Noon		897	906	911	878	851	827	788	792	824	865	862	869
		Edh at Noon	87	99	111	130	136	138	152	147	127	100	91	84
(44) All-Sky Solar Radiation	RadAvg		2.99	3.54	4.76	5.79	6.34	6.08	5.73	5.42	5.11	4.52	3.44	2.67
	RadStd		0.25	0.47	0.41	0.48	0.34	0.49	0.42	0.45	0.39	0.48	0.31	0.24

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+140	+93

Nomenclature: See separate page