

BATON ROUGE, LA, USA

WMO: 722320

Lat: 30.537N

Lon: 91.147W

Elev: 64

StdP: 14.66

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13970

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.2	31.5	14.6	11.5	37.2	19.2	14.5	40.7	21.9	68.9	19.5	65.6	3.7	10	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.9	95.0	77.4	93.3	77.3	91.9	76.9	80.4	88.8	79.7	88.1	79.0	87.3	6.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.4	147.9	83.7	77.5	143.3	83.0	76.8	140.1	82.6	44.0	89.1	43.1	87.8	42.4	87.5	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.8	16.6	14.4	DB	22.4	97.7	4.0	3.0	19.5	99.8	17.2	101.5	14.9	103.2	12.0	105.3
			WB	20.3	82.0	3.8	1.2	17.6	82.9	15.3	83.5	13.2	84.2	10.5	85.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.4	51.9	55.8	61.8	68.0	75.5	80.8	82.5	82.6	78.7	69.4	59.7	53.8
	DBStd	13.22	10.28	9.93	8.57	6.95	5.16	3.31	2.60	2.97	4.48	7.48	8.39	9.86
	HDD50	251	103	48	13	0	0	0	0	0	0	0	15	72
	HDD65	1537	421	285	162	49	4	0	0	0	1	44	200	371
	CDD50	6981	161	211	379	542	790	924	1008	1009	860	602	306	189
	CDD65	2790	15	27	63	140	329	474	543	544	411	181	41	22
	CDH74	26262	42	121	373	1096	2995	4773	5668	5666	3705	1486	248	89
	CDH80	10681	1	9	37	231	1097	2131	2546	2626	1540	436	24	3
(14) Wind	WSAvg	6.0	6.9	7.4	7.2	7.3	6.3	5.4	4.8	4.5	4.8	5.1	5.6	6.3
(15) Precipitation	PrecAvg	60.3	5.4	5.2	4.7	5.3	4.7	5.2	5.9	5.7	4.7	3.8	4.3	5.1
	PrecMax	88.3	15.0	14.8	12.7	14.8	14.7	23.2	11.2	14.5	13.9	14.5	13.5	15.9
	PrecMin	38.1	0.5	0.6	0.3	0.4	0.4	0.1	1.9	0.4	0.8	0.0	0.2	1.8
	PrecStd	11.9	3.1	3.2	2.7	4.0	3.1	4.8	2.6	3.1	3.3	3.2	3.0	2.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.4	81.4	83.4	87.4	92.1	96.3	96.2	97.6	95.3	90.6	82.9	80.2
		MCWB	67.7	69.0	69.3	71.9	74.4	75.9	77.4	77.7	75.9	73.6	71.0	70.3
	2%	DB	74.6	77.8	80.8	84.9	90.1	93.5	94.3	95.1	92.3	87.6	79.8	76.7
		MCWB	65.8	67.0	68.0	70.9	74.1	76.4	77.8	78.1	75.7	73.2	69.5	68.8
	5%	DB	71.4	74.6	78.4	82.8	88.3	91.8	92.6	93.3	90.4	84.9	76.8	73.3
		MCWB	64.8	65.8	67.0	70.0	73.5	76.4	77.8	78.1	75.4	71.8	67.6	67.4
	10%	DB	68.2	71.6	75.5	80.5	86.3	90.0	90.9	91.4	88.4	82.1	74.0	70.1
		MCWB	62.8	65.0	65.4	68.6	72.9	76.2	77.6	77.7	74.9	70.5	66.5	65.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.5	71.8	72.9	75.8	79.1	80.4	81.8	82.2	80.0	78.1	74.3	72.4
		MCDB	74.5	76.3	78.4	82.4	86.6	88.5	89.8	90.7	87.5	84.0	77.9	76.3
	2%	WB	68.6	69.9	71.0	74.0	77.2	79.4	80.3	80.5	78.8	76.5	72.3	70.5
		MCDB	72.5	74.8	76.2	80.1	84.7	87.9	88.8	89.1	86.4	82.7	76.5	74.7
	5%	WB	66.5	68.2	69.6	72.8	75.9	78.4	79.5	79.8	77.9	75.2	70.4	68.8
		MCDB	70.2	73.0	75.1	78.7	83.3	86.8	88.0	88.4	85.5	81.3	75.0	72.7
	10%	WB	63.9	66.0	68.1	71.4	75.0	77.8	78.7	79.0	77.0	73.5	68.1	66.1
		MCDB	67.2	70.6	73.6	77.4	82.3	86.1	87.0	87.4	84.4	78.8	72.8	69.5
(35) Mean Daily Temperature Range	5% DB	MDBR	20.1	20.1	20.9	20.9	19.6	17.8	16.9	17.6	18.8	21.6	21.9	20.0
		MCDBR	20.5	20.5	20.6	20.4	20.2	19.6	18.6	19.5	20.4	21.4	22.3	20.3
		MCWBR	13.5	11.9	10.1	8.9	6.9	6.1	6.0	6.1	7.1	9.1	12.9	13.4
	5% WB	MCDBR	17.4	17.9	17.6	17.4	17.5	17.0	16.8	17.4	16.9	17.3	19.1	18.1
		MCWBR	13.4	12.5	10.8	9.3	7.1	6.5	6.4	6.4	6.8	8.8	13.4	13.8
(40) Clear-Sky Solar Irradiance	taub		0.332	0.353	0.370	0.414	0.439	0.479	0.504	0.497	0.444	0.378	0.353	0.344
	taud		2.522	2.466	2.411	2.293	2.261	2.191	2.155	2.174	2.296	2.451	2.466	2.498
	Ebn at Noon		286	289	290	279	272	259	252	253	263	276	275	274
	Edh at Noon		28	32	36	42	44	47	48	47	40	32	29	27
(44) All-Sky Solar Radiation	RadAvg		912	1071	1443	1783	1945	1896	1843	1740	1603	1400	1054	814
	RadStd		85	155	124	131	118	169	137	151	129	167	101	84

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.76	N/A	N/A	N/A	N/A	N/A	N/A	-133	+270	+191
(47) Regional (21 neighbors)		+0.70	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+247	+160

Nomenclature: See separate page