

BATON ROUGE, LA, USA

WMO: 722320

Lat: 30.537N

Lon: 91.147W

Elev: 20

StdP: 101.09

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13970

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.1	-0.3	-9.7	1.6	2.9	-7.1	2.1	4.9	9.8	20.5	8.7	18.7	1.6	10	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	35.0	25.2	34.1	25.2	33.3	25.0	26.9	31.6	26.5	31.2	26.1	30.7	3.0	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.8	21.1	28.7	25.3	20.5	28.3	24.9	20.0	28.1	84.5	31.7	82.3	31.0	80.7	30.8	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.4	7.4	6.4	-5.3	36.5	2.2	1.6	-6.9	37.7	-8.2	38.6	-9.5	39.6	-11.1	40.7		
			-6.5	27.8	2.1	0.7	-8.0	28.3	-9.3	28.6	-10.4	29.0	-12.0	29.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	20.2	11.0	13.2	16.6	20.0	24.2	27.1	28.1	25.9	20.8	15.4	12.1		
		DBStd	7.34	5.71	5.52	4.76	3.86	2.87	1.84	1.44	1.65	2.49	4.16	5.48		
		HDD10.0	139	57	27	7	0	0	0	0	0	0	8	40		
		HDD18.3	854	234	158	90	27	2	0	0	1	24	111	206		
		CDD10.0	3878	89	117	211	301	439	513	560	478	334	170	105		
		CDD18.3	1550	8	15	35	78	183	263	302	302	228	101	23		
		CDH23.3	14590	23	67	207	609	1664	2652	3149	3148	2058	826	138		
		CDH26.7	5934	1	5	21	128	609	1184	1414	1459	856	242	13		
(14)	Wind	WSAvg	2.7	3.1	3.3	3.2	3.2	2.8	2.4	2.1	2.0	2.2	2.3	2.5		
(15)	Precipitation	PrecAvg	1532	137	132	119	135	120	132	151	144	120	97	109		
		PrecMax	2244	380	377	323	377	373	589	285	368	354	368	344		
		PrecMin	968	13	16	8	10	9	3	49	10	20	0	6		
		PrecStd	303	80	82	68	101	78	122	65	78	83	81	76		
(20)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.8	27.4	28.6	30.8	33.4	35.7	35.7	36.4	35.2	32.6	28.3		
			MCWB	19.9	20.5	20.7	22.1	23.5	24.4	25.2	25.4	24.4	23.1	21.7		
		2%	DB	23.7	25.5	27.1	29.4	32.3	34.2	34.6	35.0	33.5	30.9	26.6		
			MCWB	18.8	19.4	20.0	21.6	23.4	24.7	25.4	25.6	24.3	22.9	20.8		
		5%	DB	21.9	23.7	25.8	28.2	31.3	33.2	33.7	34.0	32.4	29.4	24.9		
			MCWB	18.2	18.8	19.4	21.1	23.1	24.7	25.4	25.6	24.1	22.1	19.8		
		10%	DB	20.1	22.0	24.2	26.9	30.2	32.2	32.7	33.0	31.3	27.8	23.4		
			MCWB	17.1	18.3	18.6	20.3	22.7	24.6	25.3	25.4	23.8	21.4	19.1		
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.4	22.1	22.7	24.3	26.2	26.9	27.7	27.9	26.7	25.6	23.5		
			MCDB	23.6	24.6	25.8	28.0	30.3	31.4	32.1	32.6	30.8	28.9	25.5		
		2%	WB	20.3	21.1	21.7	23.3	25.1	26.3	26.9	27.0	26.0	24.7	22.4		
			MCDB	22.5	23.8	24.5	26.7	29.3	31.1	31.5	31.7	30.2	28.2	24.7		
		5%	WB	19.2	20.1	20.9	22.7	24.4	25.8	26.4	26.6	25.5	24.0	21.3		
			MCDB	21.2	22.8	23.9	26.0	28.5	30.5	31.1	31.3	29.7	27.4	23.9		
		10%	WB	17.7	18.9	20.1	21.9	23.9	25.4	26.0	26.1	25.0	23.1	20.1		
			MCDB	19.6	21.5	23.1	25.2	27.9	30.0	30.6	30.8	29.1	26.0	22.7		
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.2	11.2	11.6	11.6	10.9	9.9	9.4	9.8	10.4	12.0	12.2		
			MCDBR	11.4	11.4	11.4	11.3	11.2	10.9	10.3	10.8	11.3	11.9	12.4		
		5% WB	MCWBR	7.5	6.6	5.6	4.9	3.8	3.4	3.3	3.4	4.0	5.1	7.2		
			MCDBR	9.7	9.9	9.8	9.7	9.7	9.5	9.4	9.6	9.4	9.6	10.6		
			MCWBR	7.4	6.9	6.0	5.2	4.0	3.6	3.6	3.5	3.8	4.9	7.5		
(40)	Clear-Sky Solar Irradiance	taub	0.332	0.353	0.370	0.414	0.439	0.479	0.504	0.497	0.444	0.378	0.353	0.344		
		taud	2.522	2.466	2.411	2.293	2.261	2.191	2.155	2.174	2.296	2.451	2.466	2.498		
		Ebn at Noon	901	910	914	881	856	818	796	798	830	870	866	865		
		Edh at Noon	88	101	114	133	138	147	152	148	126	101	92	86		
(44)	All-Sky Solar Radiation	RadAvg	2.88	3.38	4.55	5.62	6.13	5.98	5.81	5.49	5.05	4.41	3.32	2.56		
		RadStd	0.27	0.49	0.39	0.41	0.37	0.53	0.43	0.47	0.41	0.53	0.32	0.26		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.42	N/A	N/A	N/A	N/A	N/A	N/A	-74	+150	+106
(47)	Regional (21 neighbors)	+0.39	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+137	+89

Nomenclature: See separate page