

SLIDELL, LA, USA

WMO: 722330

Lat: 30.343N

Lon: 89.822W

Elev: 8

StdP: 101.23

Time Zone: -6.00 (NAC)

Period: 99-19

WBAN: 53865

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.3	-0.9	-9.2	1.7	3.5	-6.9	2.1	3.6	8.5	11.3	7.8	12.6	1.2	10	0.360

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.3	34.4	25.2	33.5	25.2	32.7	25.0	27.0	31.3	26.6	30.9	26.2	30.4	2.8	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.1	21.5	28.9	25.5	20.7	28.7	25.0	20.1	28.4	84.7	31.2	82.6	30.5	81.0	30.6	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.7	6.9	5.8	DB	-5.5	36.5	1.7	1.6	-6.7	37.6	-7.7	38.5	-8.6	39.4	-9.9	40.5	
			WB	-6.5	27.8	1.8	0.7	-7.8	28.3	-8.8	28.7	-9.8	29.1	-11.1	29.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.0	10.8	13.0	16.4	19.7	23.6	26.9	27.7	27.8	25.7	20.6	15.0	12.1
	DBStd	7.26	5.60	5.26	4.65	3.63	2.97	1.66	1.31	1.63	2.26	4.24	4.71	5.39
	HDD10.0	142	59	26	7	1	0	0	0	0	0	0	10	39
	HDD18.3	877	241	161	93	27	3	0	0	0	0	28	120	205
	CDD10.0	3787	83	111	204	293	422	507	548	553	472	328	160	104
	CDD18.3	1481	7	13	32	69	167	257	290	294	223	97	21	12
	CDH23.3	14144	10	43	160	534	1629	2703	3015	3051	2017	830	123	28
	CDH26.7	5521	0	1	11	77	531	1193	1329	1352	797	222	9	0
Wind	WSAvg	2.2	2.6	2.8	2.7	2.8	2.4	1.9	1.5	1.5	1.8	2.0	2.2	2.5
Precipitation	PrecAvg	1607	150	108	134	120	133	156	182	154	119	102	115	129
	PrecMax	2361	459	221	277	315	542	523	353	275	340	306	331	465
	PrecMin	1015	8	21	8	3	4	15	71	69	32	0	24	48
	PrecStd	332	113	61	73	74	124	112	70	59	84	79	87	88
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.6	26.7	27.8	29.8	32.9	35.5	35.3	36.0	34.4	32.2	27.8	25.6
		MCWB	20.2	20.6	20.5	21.6	23.3	24.3	25.4	25.6	25.0	23.9	21.7	21.5
	2%	DB	22.9	24.7	26.7	28.5	31.7	33.9	34.0	34.2	32.8	30.5	26.3	24.0
		MCWB	19.3	19.8	20.1	21.7	23.3	24.5	25.4	25.7	24.6	23.1	21.2	20.7
	5%	DB	21.5	22.9	25.2	27.5	30.9	32.8	33.0	33.4	32.0	29.0	24.8	22.5
		MCWB	18.6	19.2	19.7	21.0	23.1	24.5	25.4	25.6	24.4	22.4	19.9	19.9
	10%	DB	19.9	21.5	23.7	26.4	29.6	32.0	32.3	32.5	31.0	27.7	23.1	21.1
		MCWB	17.7	18.5	19.0	20.3	22.6	24.4	25.2	25.5	24.1	21.8	19.1	19.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.7	22.2	22.6	24.2	25.5	27.1	27.4	27.9	26.6	25.9	23.9	23.3
		MCDB	23.2	24.6	25.2	26.7	29.3	31.6	32.0	32.4	30.3	28.8	25.8	24.3
	2%	WB	20.6	21.2	21.8	23.5	24.9	26.4	26.8	27.3	26.0	25.0	22.6	21.6
		MCDB	22.0	23.3	24.3	26.2	28.8	30.9	31.3	31.5	29.7	28.2	24.8	23.1
	5%	WB	19.4	20.3	21.2	22.9	24.4	25.8	26.4	26.8	25.6	24.3	21.4	20.6
		MCDB	20.9	22.3	23.8	25.7	28.3	30.3	30.8	31.0	29.5	27.6	23.9	22.0
	10%	WB	18.0	19.0	20.4	22.2	23.9	25.5	25.9	26.3	25.2	23.4	20.3	19.3
		MCDB	19.4	21.0	22.9	25.0	27.8	29.8	30.2	30.6	29.2	26.4	22.8	20.7
Mean Daily Temperature Range	MDBR	11.4	11.4	11.8	11.5	11.0	9.8	9.2	9.3	10.2	12.2	13.1	11.3	
		MCDBR	10.5	10.6	11.1	11.2	11.1	10.9	10.2	10.3	10.8	11.8	12.4	10.5
		MCWBR	7.2	6.7	5.9	5.6	4.6	3.9	3.8	3.7	4.4	5.6	7.5	7.4
	5% WB	MCDBR	8.9	9.1	9.1	8.7	9.1	9.4	9.1	9.1	9.0	9.0	10.1	9.1
		MCWBR	7.0	6.8	5.8	5.4	4.2	3.9	3.8	3.8	4.0	5.0	7.3	7.5
Clear-Sky Solar Irradiance	taub	0.333	0.354	0.372	0.414	0.444	0.469	0.519	0.506	0.456	0.384	0.356	0.341	
	taud	2.536	2.484	2.428	2.313	2.265	2.236	2.125	2.160	2.265	2.454	2.475	2.529	
	Ebn at Noon	901	910	913	881	852	826	783	791	820	865	865	873	
	Edh at Noon	87	99	112	130	137	141	157	150	131	101	91	84	
All-Sky Solar Radiation	RadAvg	2.97	3.51	4.71	5.76	6.31	6.13	5.82	5.52	5.14	4.50	3.42	2.65	
	RadStd	0.26	0.49	0.40	0.47	0.36	0.49	0.43	0.44	0.39	0.50	0.31	0.24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.71	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (27 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+138	+90

Nomenclature: See separate page